

Long-Range Response to Transmission Line Disturbances in DC Electricity Grids

Darka Labavić, Raluca Suciuc, Hildegard Meyer-Ortmanns, and Stefan Kettemann^a

Jacobs University Bremen, Germany School of Engineering and Science, Jacobs University Bremen, Bremen 28759, Germany

Abstract We consider a DC electricity grid composed of transmission lines connecting power generators and consumers at its nodes. The DC grid is described by nonlinear equations derived from Kirchhoff's law. For an initial distribution of consumed and generated power, and given transmission line conductances, we determine the geographical distribution of voltages at the nodes. Adjusting the generated power for the Joule heating losses, we then calculate the electrical power flow through the transmission lines. Next, we study the response of the grid to an additional transmission line between two sites of the grid and calculate the resulting change in the power flow distribution. This change is found to decay slowly in space, with a power of the distance from the additional line. We find the geographical distribution of the power transmission, when a link is added. With a finite probability the maximal load in the grid becomes larger when a transmission line is added, a phenomenon that is known as Braess' paradox. We find that this phenomenon is more pronounced in a DC grid described by the nonlinear equations derived from Kirchhoff's law than in a linearised flow model studied previously in Ref. [1]. We observe furthermore that the increase in the load of the transmission lines due to an added line is of the same order of magnitude as Joule heating. Interestingly, for a fixed system size the load of the lines increases with the degree of disorder in the geographical distribution of consumers and producers.

1 Introduction

The stability of electricity grids requires to protect it against fluctuations of the electricity generators and consumers, and disturbances in the transmission lines [2,3]. Therefore, the electrical power system must be constructed in such a way that, when subjected to a physical disturbance, it regains an operating equilibrium without exceeding bounds in the fluctuations of the system variables. Since this is a highly complex and nonlinear problem, the study of its dependence on the network topology, the operating conditions and forms of disturbances requires to make modeling assumptions [2]. Recently, the Braess' paradox, known from traffic flows, has been found to be relevant in power grids as well [4]. In the context of power grids the Braess' paradox amounts to a decrease in the overall performance, although a transmission line was added rather than removed. The reason is that the added line may

^a e-mail: s.kettemann@jacobs-university.de

lead to an increase of the load in some other transmission lines, even beyond their maximal capacity. On the other hand, it was found that the danger of a blackout, the total disruption of the electricity grid, can be reduced by decentralisation of the power generation [4,5].

A realistic model of electricity grids should take into account the voltage fluctuations as well as fluctuations in the incoming and outgoing electrical power [2]. In AC grids random phase fluctuations of the impedances and frequency must be considered as well [2]. As a first step towards a prediction of the stability of realistic power grids against a change in the transmission lines we study here DC power grids and study the power flow through all links of the network as described by a set of nonlinear equations that are equivalent to Kirchhoff's law at each site. We then add a single transmission line in the center of our regular grid and analyze the spatial dependence of the induced change in the load of the transmission lines.

Thereby, we aim to address the following questions about the stability of the network: how is the power transmitted through the transmission lines distributed and what is the probability to come close to its power capacity limit as a function of the network parameters and the distribution of the consumer and generator power? How does that distribution change, when one transmission line is added? In particular, we are interested in the spatial distribution of the resulting changes in transmission power, and how this change decays with the spatial distance r to the perturbation. Does it typically decay exponentially or with a power law with that distance? A power law decay would indicate a nonlocal effect of the perturbation on the power grid stability.

Towards this end our strategy is the following: we choose a realistic value V_0 for the nominal voltage, which is the voltage to be received by the consumers, and the conductance of the transmission lines. For a given randomly chosen distribution of consumers and generators $\{P_i^0\}$ and the given value V_0 we determine the corresponding set of voltages $\{V_i\}$ from a linearised set of equations. We next choose the resulting set of voltages V_i as starting point to determine the induced power flow F_{ij} through the network links (i, j) , including the Joule heat dP_{ij}^J . This flow is the quantity of our main interest, in particular how this flow changes if one transmission line is added. Along with that, we obtain the additional power dP_i that has to be produced at a site i to compensate for the loss via Joule heat. When the generator power is adjusted that way, the set of voltages $\{V_i\}$ then solves the nonlinear set of equations for V_i , which follow from Kirchhoffs laws, and we can analyse the results for the power transmission F_{ij} .

1.1 DC Power Grid

Let us consider a DC power grid with N sites denoted by the index i . The conservation of power yields at every node the equation

$$P_i = \sum_{j \neq i} F_{ij} \quad (1.1)$$

for all nodes $i = 1, \dots, N$. Here, $P_i > 0$, if there is an electricity generator at site i , while $P_i < 0$, when power is consumed at site i . F_{ij} is the power transported from site i to site j . When the voltage at site i is V_i , the transmitted power F_{ij} is related to the electrical current I_{ij} between sites i and j by $F_{ij} = V_i I_{ij}$. These currents are related to the voltage difference by Ohm's law $I_{ij}/G_{ij} = V_i - V_j$, where G_{ij} is the conductance of the transmission line between sites i and j . Thus, choosing the local power P_i for all sites i and the conductances G_{ij} , the voltages V_i are determined by

the equations

$$P_i = V_i \sum_j G_{ij}(V_i - V_j), \quad (1.2)$$

which are N nonlinear equations for the N voltages V_i . We can rewrite these equations, by relating the power P_i to currents I_i , which are incoming/outgoing at sites i as $P_i = I_i V_i$. Inserting this in Eq. (1.2), we obtain

$$I_i = \sum_j G_{ij}(V_i - V_j), \quad (1.3)$$

which is nothing than Kirchhoff's law at site i . If we consider for a given electricity grid the distribution of incoming and outgoing power $\{P_i\}$ as given (rather than the currents I_i), we need to solve Eq. (1.2), which is nonlinear in V_i . The power loss due to Joule heating in transmission line (i, j) is given by

$$dP_{ij}^Q = G_{ij}(V_i - V_j)^2 = F_{ij} + F_{ji}. \quad (1.4)$$

Here, the link (i, j) is oriented such that $F_{ij} > 0$. It is this Joule heating at link (i, j) that should be compensated for by the power generators. In realistic transmission lines the Joule heating dP_{ij}^Q does not exceed several percent of the transmitted power F_{ij} under stable operation conditions.

It should be noticed that the authors of [1], who demonstrated the Braess' paradox in a flow model, consider a different set of equations (Eq. 20 of Ref. [1] in Appendix A2), which is linear and corresponds in our notation to

$$P_i^0 \equiv V_0 \sum_j G_{ij}(V_i - V_j), \quad (1.5)$$

with $\sum_i P_i^0 = 0$. Here V_0 is the nominal grid voltage. This equation was derived from a Lagrangian by minimizing the total dissipative power under the constraint of energy conservation at site i , $\sum_{j=1}^N F_{ij} = P_i$, with F_{ij} the power transmitted from node i to node j . We note that the physical Kirchhoff's laws for DC electricity grids rather result in the nonlinear equations Eq. (1.2). Our motivation to reconsider the problem studied in Ref. [5] was to compare the order of magnitude of the Joule heating with the changes in the transmitted power due to an added link capacity, in particular to see whether the inclusion of the Joule heating increases or decreases the chance for a Braess paradox to occur in the DC grid. So we choose the quadratic equations Eq. (1.2) as our starting point.

In order to find solutions to these nonlinear equations we proceed along the following steps:

- We first solve the linearised equations Eqs. (1.5) for an ideal DC grid with $\sum_i P_i^0 = 0$, to find the set of V_i at all nodes i for a randomly chosen distribution $\{P_i^0\}$.
- Next we use this set of V_i to calculate the total power transmitted from node i into the link (i, j) as given by

$$F_{ij} = V_i G_{ij} (V_i - V_j), \quad (1.6)$$

where the power flows from i to j , when $V_i > V_j$.

- In order to solve the nonlinear equations Eq. (1.2) by this set of $\{V_i\}$ the power distribution $\{P_i^0\}$ must be modified to an adjusted set of P_i , by adding

$$dP_i(\{V_j\}) = (V_i - V_0) \sum_j G_{ij} (V_i - V_j), \quad (1.7)$$




Figure 1. a) Geometry of a 10×10 lattice, where black/white links are equidistant by an even/odd number of links r from the added link (dashed line in the centre of the grid). b) Distribution of the change in the power transmission ΔF_{ij} , after adding a link between two consumers (white dots) as indicated by the lines whose white/gray intensity corresponds to the change in MW as defined in the color bar. c) Distribution of the change in the load after adding a link between a consumer (white dot) and a generator (black dot).

on each node, so that the adjusted P_i in Eq. (1.2) results from the given $\{P_i^0\}$ and the calculated $\{dP_i\}$. Summing over all nodes, we find $\sum_i P_i = \sum_i dP_i = \sum_i dP_i^\Omega = dP^\Omega$, where dP_i^Ω is given by the sum over j of Eq. (1.4). (Note that according to this definition the double sum in $\sum_i dP_i = \sum_{i,j} F_{ij}$ is unrestricted in i and j , while the double sum in $\sum_i dP_i^\Omega = \sum_{i,j} (F_{ij} + F_{ji})$ runs only over directed links (i, j) , depending on the relative size of the voltages.) Thus, as expected, dP^Ω is the total power dissipated as Joule heating in the electricity grid, which must be additionally produced by the power engines if one wants to guarantee that the consumers get the needed power.

Note that the following conditions must be imposed for stable grid operation:

1. Joule heating dP_{ij}^Ω must be smaller than the power injected in link (i, j) , F_{ij} . This yields $V_i - V_j < V_i$, or $V_j > 0$ for all j .
2. Joule heating dP_{ij}^Ω should not exceed the power capacity, here chosen as $F_{ij}^{max} = V_0^2 G_{ij}$ (as if the maximal voltage drop off over a line is determined by the nominal voltage). This gives $|V_i - V_j| < V_0$ for all (i, j) .
3. The total power capacity of all transmission lines connected to node i should exceed the injected power P_i , yielding $V_0^2 \sum_j G_{ij} \gg |P_i|$.
4. Breakdown of a transmission line occurs if the transmitted power F_{ij} approaches or exceeds the power capacity F_{ij}^{max} . Thus, to ensure grid stability one needs to impose $F_{ij} < F_{ij}^{max}$. This gives the condition $|V_i(V_i - V_j)| < V_0^2$ for all (i, j) .

With the equations Eq. (1.2) we can answer the following questions about the stability of the network: How close is the power transmitted via the link (i, j) , $F_{ij} = G_{ij}V_i(V_i - V_j)$ to the power capacity $F_{ij}^{max} = V_0^2 G_{ij}$ of that link? In order to study this systematically, we then find the distribution of $|F_{ij}|$. How does the distribution of F_{ij} change, when a link (m, n) with conductance G_{mn} is added? In particular, we are interested in the spatial distribution of the resulting changes ΔF_{ij} , and in how this change decays with the spatial distance r to the perturbation. Does it typically decay exponentially or with a power law with that distance? A power law decay would indicate a nonlocal effect of the perturbation on the power grid stability.




Figure 2. Distribution of the ratio of Joule heating dP_{ij}^Ω and the transmitted power F_{ij} . Light/dark color represents a higher/lower ratio for the unperturbed grid.

2 Numerical Results

We choose a square lattice with dimensions $L_x \times L_y$, with periodic boundary conditions, shown in Fig. 1a, with a random geographical distribution of producers ($P_p^0 = P_0$, black dots) and consumers ($P_c^0 = -P_0$, white dots), which satisfies the condition $\sum_i P_i = 0$, $i = 1, \dots, N$. Each node is connected to the four nearest neighbours by transmission lines with conductance G_{ij} , which we take as $G_{ij} = G_0 A_{ij}$, where A_{ij} is the adjacency matrix of the square lattice. We choose G_0 such that the losses due to the Joule heating in the transmission lines are of the order of 1% of the power P_0 . In order to calculate the load F_{ij} of each link, we solve the system of N linear equations (1.5), where N is the total number of nodes, $N = L_x L_y$. The rank of the system (1.5) is $N - 1$, so a solution, if it exists, has one of the V_i undetermined. For every configuration we choose the set of voltages $\{V_i\}$ such that the minimal voltage $\min\{V_i\} = V_0$ is guaranteed, so that the consumer gets at least the nominal voltage.

In order to study how the change in the load after adding an additional link spreads on the lattice, we measure the change in the load $\Delta F_{ij} = F_{ij}^{after} - F_{ij}^{before}$ as a function of the distance from the added link. Let l_m and l_n represent nodes on the lattice between which the link is added. We define the radial distance r of a link from the added link as the minimal number of steps required to reach that link from one of the nodes l_m or l_n . Equidistant links around the added link (dashed line) whose distance r is an even/odd number are plotted by black/white lines in Fig. 1a for a 10×10 square lattice with periodic boundary conditions. Fig. 1b and 1c show typical distributions of ΔF_{ij} on a 10×10 lattice. There is a difference in the distribution of ΔF_{ij} , when we add a link between two nodes of different type (producer and consumer), Fig. 1c, and between the same types (two producers, or two consumers), Fig. 1b. Typically an added link between nodes of different type is surrounded by links whose load has decreased, Fig. 1c, while an added link between nodes of the same type is surrounded by both links with decreased and increased transmission power.

We fix the parameters to $V_0 = 10kV$, $P_i = \pm 100MW$. The conductance $G_0 = 10/\Omega$ is chosen to satisfy the condition that the loss due to Joule heating is less than 10% of the power transmission per link. With this choice of parameters the voltage differences are $\Delta V_{ij} = V_i - V_j < 1kV$, so that the Joule heating of the link (i, j) , $dP_{ij}^\Omega = G_0 \Delta V_{ij}^2 < 10 kV^2/\Omega = 10MW = 10\%$ of P^0 . Fig. 2 shows the distribution of Joule heating on a lattice relative to the load F_{ij} . We find that for these parameters, it does indeed not exceed about 10% of the transmitted power.




Figure 3. Color online. Average of the power flow $\langle |\Delta F_{ij}(r)| \rangle$ as function of the distance r to the added transmission line for different sizes $L \times L$ with, from bottom to top, $L = 10, 20, 30, 40, 50$, respectively. Numerical results (points) are shown together with the fit to $f(r) = ar^{-b}$ (values for a and b are given in the inset according to $\ln a - b \log r$).




Figure 4. Color online. Saturation value $|\Delta F_{ij}(r = L - 1)|$ as a function of L .

In order to get the average power transmission change as a function of the distance r , we next sum the absolute values of all changes $|\Delta F_{ij}(r)|$ at links at the same distance r , divide it by the number of such links M_r , and average over 10000 realizations of the power distribution $\{P_i\}$. Fig. 3 shows the resulting average change $\langle |\Delta F_{ij}(r)| \rangle$ as a function of the distance r . The data are fitted with a power function $f(r) = ar^{-b}$, in a double logarithmic plot. We can clearly distinguish different short and long range behavior. For small r , at a distance of a few lattice constants, we find a power law behaviour with power $b \approx 2.1$, see the inset of Fig. 3.

We find that for a given system size L , $|\Delta F_{ij}|$ saturates at large distances $r \rightarrow L$. The saturation here refers to the fact that it no longer decays but fluctuates around a certain value over a few sites before the maximal distance is reached. However, this saturation value of $|\Delta F_{ij}|$ depends on the system size and decays with L , as shown in Fig. 4, where $|\Delta F_{ij}(r_{\max})|$ is plotted taking the value at the largest possible distance to the perturbation r_{\max} as a function of L . This clearly confirms that this saturation is a finite size effect.

Plotting only the values $\langle |\Delta F_{ij}(r)| \rangle$ at intermediate distances r , disregarding the data in the saturation region in order to avoid this finite size effect, as done in Fig. 5,




Figure 5. Color online. Zoom into the intermediate distance regime, where data for $|\Delta F_{ij}(r)|$ obey a power law $f(r) = ar^{-b}$, with a smaller power, see the inset (data in the saturation regime are here not shown).




Figure 6. Color online. a) Change in the load at $r = 1$ as a function of the system size L . Black dots represent data averaged over 10000 realizations of the power distribution, red (grey) ones over 1000. b) Change in the load at $r = 1$ as a function of the number of swapped links for $L = 10$ to illustrate the effect of disorder.

we find that all data for different system sizes L fit again a power law $f(r) = ar^{-b}$, but with a smaller power b approaching $b \approx 1.3$ for the largest grids considered here.

Next, we study another effect which depends on the systems size L : Fig. 6a shows $|\Delta F_{ij}|$ for the smallest radius $r_1 = 1$ as a function of L as averaged over 1000 and 10000 ensembles of power distributions. We notice a systematic linear increase of the $|\Delta F_{ij}(r_1)|$ with the increase of L . This increase is due to the increase in the voltage difference as the grid size increases. It is challenging to trace back, in which way the larger system size leads to an average increase in $V_i - V_j$ between neighboured sites close to the perturbation, although the equations do not show an obvious source of size dependence. In view of that we look at the voltage distribution for a fixed lattice size, but consider different power distributions, which differ by their degree of order. We start with an ordered $L \times L$ lattice, for which entire rows of consumers alternate with rows composed of only producers. We then choose randomly between one and L (producer, consumer)-pairs and switch their positions to induce more and more disorder in the geographical distribution of consumers and producers. In Fig. 6b we plot the maximum value of voltages for $L = 30$ and $L = 50$ as a function of that kind




Figure 7. Color online. a) Histogram of the change of F_{ij} on all links after adding a link for 10000 realizations of P_i^0 in a 10×10 grid. Positive (negative) values represent an increase (decrease) of the load. b) Zoom around the peak value (upper figure) and tails of the distribution (lower figure). c) Probability of the change in the maximum load after adding a link, relative to the power capacity $V_0^2 G_0$. A finite probability for a positive value indicates Braess' paradoxon.

of power distribution disorder. As the minimum voltage is fixed to V_0 , an increase of the maximum voltage V_i^{\max} corresponds to an increase of the maximum difference of the voltages, which is proportional to $\max\{F_{ij}\}$. So for a fixed system size and different degrees of randomness in the power distribution, we see a tendency of an increase of $\max\{F_{ij}\}$ with increasing randomness. On the other hand, if we compare two systems with the same kind of random distributions of $\{P_i\}$, which just differ by their size, our conjecture is that one of the reasons for an increase in the load around the perturbation is the increased total amount of disorder in a larger system. This conjecture will be further pursued in a future publication. Another reason for such an increase of the load in the transmission lines can be due to an increasing resistance of the electricity grid with the system size, and the resulting increase of the maximal voltage V_i^{\max} when the minimal voltage is fixed to V_0 .

Next, we study the distribution in the change in transmitted power when a transmission line is added. In particular, we are interested in the probability with which Braess paradox occurs, meaning that the transmission line which transmits the largest amount of power transmits even more power after another line was added. In Fig. 7a we show the distribution of the change in the transmission power ΔF_{ij} in units of MW as a histogram obtained from all the transmission lines (i, j) of the electricity grid, except for the added one. For comparison, we also show the histogram of the change in ΔF_{ij}^0 , the change of $F_{ij}^0 = V_0 G_{ij}(V_i - V_j)$ (which is the quantity studied in Ref. [5]). We note that the distribution of the change in the real power transmission ΔF_{ij} , including Joule heating, has a wider distribution with longer tails to positive, and more prominently to negative values. In Fig. 7b we show zooms around the peak value (upper figure) and the tails of the distribution (lower figure) to show this small effect more clearly. In Fig. 7c we plot the probability for a change of the maximal transmitted power $\Delta \text{Max}(F_{ij})$ relative to the power capacity $V_0^2 G_0$, as obtained from 10000 ensembles. A finite probability to have a positive change in the transmitted power indicates Braess' paradoxon. For the chosen parameter values, the load still

remains within 25% of the power capacity limit of the transmission lines, so that the overall performance is not seriously affected. Choosing different initial parameters, in particular, increasing the injected power P_0 , would bring the maximal power transmission closer to the transmission capacity and the addition of a line can result in a power outage of the electricity grid.

3 Conclusions

We studied the response of a square lattice grid to an additional transmission line between two sites of the grid. We calculated the induced change in the power flow distribution, and found that it decays slowly, with a power of the distance from the additional line. The power law exponent at small distances, $b = b_n \approx 2.1$, is larger compared to the one obtained at long distances, where we find $b = b_l < 1.6$, approaching $b_l \approx 1.3$ in the largest grid. We therefore conclude that the addition of a link has a long-range effect, at least on the square electricity grid model with nearest neighbour coupling studied here. When the spatial distance r to the perturbation approaches the system size L , we observe a saturation of the load change. This value decays however with L with a power law, establishing the saturation as a finite size effect.

With a finite probability the maximal transmitted power $\Delta\text{Max}(F_{ij})$ increases when a transmission line is added to the electricity grid, a phenomenon known as Braess' paradoxon. This effect becomes more pronounced when the nonlinear equations Eq. 1.2 derived from Kirchhoff's law are considered rather than linearised equations as in previous studies [1]. Induced changes in the load distribution on AC grids and in more realistic grid topologies will be studied in future work. In particular we shall study the role of randomness in the arrangement of consumers and producers in view of degrading the overall performance of the grid.

References

1. D. Witthaut and M. Timme, Eur. Phys. J. B **86**, 377 (2013).
2. C. Y. Chung, L. Wang, F. Howell, and P. Kundur, IEEE Transactions on Power Systems **19**, 1387 (2004).
3. S. Massoud Amin and A. M. Giacomoni, in *Fundamentals of Materials for Energy and Environmental Sustainability*, edited by D. S. Ginley and D. Cahen (Cambridge Univ. Press, 2011).
4. M. Rohden, A. Sorge, M. Timme, and D. Witthaut, Phys. Rev. Lett. **109**, 064101 (2012).
5. D. Witthaut and M. Timme, New J. Phys. **14**, 083036 (2012).