Designing for Situation Awareness of Future Power Grids: An Indicator System Based on Linear Eigenvalue Statistics of Large Random Matrices

Xing He, Robert C. Qiu, Fellow, IEEE, Qian Ai, Member, IEEE, Lei Chu, Xinyi Xu, Zenan Ling

Abstract—Future power grids are fundamentally different from current ones, both in size and in complexity; this trend imposes challenges for situation awareness (SA) based on classical indicators, which are usually model-based and deterministic. As an alternative, this paper proposes a statistical indicator system based on linear eigenvalue statistics (LESs) of large random matrices: 1) from a data modeling viewpoint, we build, starting from power flows equations, the random matrix models (RMMs) only using the real-time data flow in a statistical manner; 2) for a data analysis that is fully driven from RMMs, we put forward the high-dimensional indicators, called LESs that have some unique statistical features such as Gaussian properties; and 3) we develop a three-dimensional (3D) power-map to visualize the system, respectively, from a high-dimensional viewpoint and a low-dimensional one. Therefore, a statistical methodology of SA is employed; it conducts SA with a model-free and data-driven procedure, requiring no knowledge of system topologies, units operation/control models, causal relationship, etc. This methodology has numerous advantages, such as sensitivity, universality, speed, and flexibility. In particular, its robustness against bad data is highlighted, with potential advantages in cyber security. The theory of big data based stability for on-line operations may prove feasible along with this line of work, although this critical development will be reported elsewhere.

Index Terms—random matrix theory, situation awareness, data-driven, high dimension, indicator, linear eigenvalue statistic, visualization.

I. INTRODUCTION

T HE modern power gird is one of the most complex engineering systems in existence; the North American power grid is recognized as the supreme engineering achievement in the 20th century [1]. The complexity of the future's electrical grid is ever increasing: 1) the evolution of the grid network, especially the expansion in size; 2) the penetration of renewable/distributed resources, flexible/controllable electronic components, or even prosumers with dual loadgenerator behavior [2]; and 3) the revolution of the operation mechanism, e.g., demand-side management. Also, the financial, the environmental and the regulatory constrains are pushing the electrical grid towards its stability limit.

All these driving forces demand a new prominence to the term *situation awareness* (SA). The SA is essential for power grid security; inadequate SA is identified as one of the root causes for the largest blackout in history—the 14 August 2003 Blackout in the United States and Canada [3].

A. Main Objective and Related Researches

SA is a big topic; its time requirements are varying—from a few milliseconds for transient procedure, several minutes for long-time emergency of the line thermal ratings [4], to months or even years for grid planning. This paper is mainly concerned about short-time phenomena and timely SA with real-time data flow.

1

There are numerous studies about utilizing phasor measurement units (PMUs) to improve wide-area monitoring, protection and control [5-7]. Data management for PMU-centric datasets is highly demanding and critical to the future grid. The advantage of efficient, PMU-based metrics is model-free and in real-time, without knowledge of network parameters or topology. Based solely on PMUs data, we argue that such an approach is well suitable for near-real-time applications. Singular Value Decomposition (SVD) is used in such large systems [8]. Giri [9] points out that good advanced analytics and a visualization framework is able to present the operator with a comprehensive, holistic portrayal of current grid condition. Xu [10] initiates power disturbance data analytics to explore potential applications of power quality monitoring data; the mathematical foundations and working architectures are not included in his work. Lim [8] proposes a voltage stability and conditioning monitor that is model-free and in real-time. Simpson [11] derives a closed-form condition under which a power network is safe from voltage collapse; the condition combines the complex structure of the network with the reactive power demands of loads to produce a node-bynode measure of grid stress, a prediction of the largest nodal voltage deviation, and an *estimate* of the distance to collapse.

B. Contribution and Previous Work

Random Matrix Theory (RMT) tools are really underestimated in power girds—there are about 1,000 IEEE journals/magazines related to RMT from 2012 to 2015; most of those are in the field of information, communication, signal processing. RMT can also lead to lots of fruitful results in power systems—we have already proposed the first systematic architecture of RMT approach in power systems [12], and also given some practical applications related to the anomaly detection [12] and the correlation analysis [13]. These studies introduce the RMT to power grids and show some unique advantages; for instance, anomaly detection using high-dimensional indicators (e.g., MSR¹ τ_{MSR} : $\tau_{MSR} = \tau_0$), is

This work was partly supported by National Natural Science Foundation of China (No. 51577115 and No. 61571296).

¹ Mean Spectral Radius, proposed in [12]

much more sensitive and effective than using classical one (e.g. voltage magnitude on node *i* at time *j*: $0.94 < v_{i,j} < 1.06$). They lead to a conclusion that the data-driven methodology, rather than the model-based alternative, is more suitable for a *complex, large-scale interconnected grid* with massive data.

The previous work used a relative rough statistical model and a certain indicator, i.e. τ_{MSR} ; this paper continues with the line and gives a more concrete treatment—making full use of the massive data in order to obtain an indicator system for the timely SA. The core function of this indicator system is to tell *signals* from *noises*:

- *Noises*: conventional incidents, e.g., sample errors, and irregular power fluctuations of small loads/generators.
- *Signals*: anomaly events, e.g., faults, network reconfigurations, and dramatic power changes on some bus.

Although Ring Law and Marchenko-Pastur (M-P) Law have already been proposed in previous two studies, they are simply reviewed here, for the current paper to be self-contained. Some contributions are pointed out as follows: 1) Universality principle is needed to justify the use of RMT in engineering systems; 2) Linear Eigenvalue Statistics (LESs)—their definitions, statistical features, and engineering performance metrics against bad data², as well as their comparison with classical indicators—are investigated as the major contribution; 3) Random matrix models (RMMs) and the hypothesis testing, as the pre-requisite for conducting data-driven SA via the LES indicator system, are introduced to tie together the physical system measurements with data analysis tools/methods.

II. BACKGROUND AND DATA-DRIVEN MODELING FOR POWER GRIDS

The nomenclature is given as Table I.

TABLE I: Some Frequently Us	ed Notations in	the Theory
-----------------------------	-----------------	------------

Notations	Meanings
$\mathbf{X}, \mathbf{x}, x, x_{i,j}$	a matrix, a vector, a single value, an entry of a matrix
$\hat{\mathbf{X}}, \hat{\mathbf{x}}, \hat{x}$	hat: raw data
$\tilde{\mathbf{X}}, \tilde{\mathbf{x}}, \tilde{x}, \tilde{\mathbf{Z}}$	tilde: intermediate variables, formed by normalization
N, T, c	the numbers of rows and columns; $c = N/T$
$\mathbf{X}_{N \times T}, \mathbf{X}_N$	matrix X of size $N \times T$, $N \times N$
R	standard Gaussian random matrix, with i.i.d. entries $r_{i,j}$
r	Gaussian random variable with mean 0 and variance 1
S	covariance matrix of $\mathbf{X}_{N \times T}$: $\mathbf{S}_N = 1/T \mathbf{X} \mathbf{X}^H$
\mathbb{C},\mathbb{R}	complex space, real space
$\tau, \tau_{\rm MSR}$	linear eigenvalue statistics, mean spectral radius
$arphi, \widehat{arphi}$	the test function and its Fourier transformation
λ	the eigenvalue
X	random variable
$\mathbb{E}(X), \mathbb{D}(X)$	expectation, variance for X
$\mu(\mathbf{x}), \sigma^2(\mathbf{x})$	mean, variance for \mathbf{x}
X°	$X - \mathbb{E}(X)$
s(z)	Stieltjes transform

A. Situation Awareness in Power Grids

The massive data compose the profile of the actual grid present state; SA aims to translate the present state into perceived state for decision-making, shown as Fig. 1 [14, 15].



Fig. 1: SA for the operational decision-making [15]

In [16], SA is defined as the *perception* of the elements in an environment, the *comprehension* of their meaning, and the *projection* of their status in the near future. This paper is aimed at the use of model-free and data-driven methodology for the comprehension of the power grid.

B. Load Behavior, Power Flow, and Voltage Stability

Power flow equations define the equilibrium operating condition for a synchronous power grid. Viewed abstractly, the physical power system may be viewed as an analog power flow solution engine, taking power injection variations as *inputs*, and "computing" bus voltage magnitude/phasors as *outputs*.

Load variations, as the inputs, can be separated into two time scales—the fast one and the slow one [8]. Within a short time, the fast time scale variation (time scale of *seconds*) plays a dominant part; we may expect it to display small magnitude random jump behavior, filtered by the electrical characteristics of the distribution system [17]—a load at a bulk distribution bus aggregates the behavior of potentially millions of individual power consuming devices, displaying on-off behavior governed by human users or local control systems. To model the fast time scale stochastic variation in a load, early studies tended to employ white noise; more recent studies have adopted Ornstein-Uhlenbeck process models [8, 18, 19]. We choose the white noise model for this initial study.

In the power flow equations, the four related parameters, $\mathbf{P}, \mathbf{Q}, \mathbf{V}$, and $\boldsymbol{\theta}$, obey the equations [8]:

$$\begin{bmatrix} \Delta \mathbf{P} \\ \Delta \mathbf{Q} \end{bmatrix} = \mathbf{J} \begin{bmatrix} \Delta \boldsymbol{\theta} \\ \Delta \mathbf{V} \end{bmatrix} = \begin{bmatrix} \frac{\partial \Delta \mathbf{P}}{\partial \boldsymbol{\theta}} & \frac{\partial \Delta \mathbf{P}}{\partial \mathbf{V}} \\ \frac{\partial \Delta \mathbf{Q}}{\partial \boldsymbol{\theta}} & \frac{\partial \Delta \mathbf{Q}}{\partial \mathbf{V}} \end{bmatrix} \begin{bmatrix} \Delta \boldsymbol{\theta} \\ \Delta \mathbf{V} \end{bmatrix} = \begin{bmatrix} \mathbf{H} & \mathbf{N} \\ \mathbf{K} & \mathbf{L} \end{bmatrix} \begin{bmatrix} \Delta \boldsymbol{\theta} \\ \Delta \mathbf{V} \end{bmatrix}$$
(1)

then, taking the matrix inverse of the Jacobian matrix J in (1) yields the desired input-output relationship (2):

$$\begin{bmatrix} \Delta \boldsymbol{\theta} \\ \Delta \mathbf{V} \end{bmatrix} = \begin{bmatrix} \mathbf{M} & -\mathbf{M}\mathbf{N}\mathbf{L}^{-1} \\ -\mathbf{L}^{-1}\mathbf{K}\mathbf{M} & \mathbf{L}^{-1} + \mathbf{L}^{-1}\mathbf{K}\mathbf{M}\mathbf{N}\mathbf{L}^{-1} \end{bmatrix} \begin{bmatrix} \Delta \mathbf{P} \\ \Delta \mathbf{Q} \end{bmatrix}_{(2)}$$

where $\mathbf{M} = (\mathbf{H} - \mathbf{N}\mathbf{L}^{-1}\mathbf{K})^{-1}$. In (2), loads injections variations $\Delta \mathbf{P}, \Delta \mathbf{Q}$ are taken as input vectors, and $\Delta \mathbf{V}, \Delta \boldsymbol{\theta}$ as output vectors.

²E.g., data errors, or even data losses in the core area

Thus, for a certain grid where \mathbf{Q} is almost constant, the model between \mathbf{V} and \mathbf{P} is obtained:

$$\Delta \mathbf{V} = \mathbf{\Xi} \Delta \mathbf{P}, \quad \text{with } \mathbf{\Xi} = -\mathbf{L}^{-1} \mathbf{K} \mathbf{M}. \tag{3}$$

Here, the matrix Ξ is *deterministic*, although unknown. The uncertainty of the entries in Ξ is neglected for mathematical tractability in this initial study. Even if Ξ is a random matrix, the machinery of RMT is sufficient to deal with the problem at hand.

C. From Random Vector to Random Matrix Model (RMM)

Considering T random vectors observed at time instants i = 1, ..., T, we form a random matrix as follows

$$[\Delta \mathbf{V}_1, \cdots, \Delta \mathbf{V}_T] = [\mathbf{\Xi}_1 \Delta \mathbf{P}_1, \cdots, \mathbf{\Xi}_T \Delta \mathbf{P}_T].$$
(4)

In an equilibrium operating system, the voltage magnitude vector injections \mathbf{V} with entries $V_i, i = 1, \dots, N$ and the phase angle vector injections $\boldsymbol{\theta}$ with entries $\theta_i, i = 1, \dots, N$ do not change a lot. Without dramatic topology changes, rich statistical empirical evidence indicates that the Jacobian matrix \mathbf{J} keeps nearly constant, so does $\boldsymbol{\Xi}$. Also, we can estimate the changes of $\mathbf{V}, \boldsymbol{\theta}$, and $\boldsymbol{\Xi}$ only with the *empirical* approach. Thus we rewrite (4) as:

$$\mathbb{V} = \Xi_N \mathbb{P}_{N \times T} \tag{5}$$

where $\mathbb{V} = [\Delta \mathbf{V}_1, \dots, \Delta \mathbf{V}_T]$, $\mathbf{\Xi} = \mathbf{\Xi}_1 = \dots = \mathbf{\Xi}_T$, and $\mathbb{P} = [\Delta \mathbf{P}_1, \dots, \Delta \mathbf{P}_T]$. Here \mathbb{V} and \mathbb{P} are random matrices. In particular, \mathbb{P} is a random matrix with Gaussian random variables as its entries.

D. Hypothesis Testing for Anomaly Detection

One of the common ways to perform data-driven anomaly detection is to employ statistical models which are usually trained out using data from *faulty and nominal behavior* in a batch mode. However, it is difficult to anticipate, *a priori*, all the possible ways in which failures may occur, especially when a new vehicle model is introduced [20]. As an alternative, based on RMM we can build the statistical models only using sampling data and employ hypothesis testing for anomaly detection. Moreover, together with methods/tools such as moving split window [12], augmented matrix [13], we design SA functions such as fault isolation/classification/diagnosis.

For a system described as II-C, we assume that we sample fast enough and there are no line/unit tripping events³ occurring, according to the arguments in II-B. With the above assumptions, $\Delta \mathbf{P}_i$ is, as a result, modeled as Gaussian random vectors, as done in [8]. Then, as (5), the Gaussian random matrix $\mathbb{P}_{N \times T}$ is employed to model the system power injections, and the corresponding \mathbb{V} is obtained. The \mathbb{V} is turned \mathbb{V} with a normalization procedure in [12]. For the normalized matrix \mathbb{V} , we formulate our problem of anomaly detection in terms of

³See section *I*, examples of the events include changes of network topology, dramatic increases of power demand at some bus, and so on.

the binary hypothesis testing: no event exists \mathcal{H}_0 , and signal exists \mathcal{H}_1 :

$$\mathcal{H}_{0}: \tilde{\mathbb{V}} = \tilde{\Xi} \mathbf{R}_{N \times T}$$
$$\mathcal{H}_{1}: \tilde{\mathbb{V}} \neq \tilde{\Xi} \mathbf{R}_{N \times T}$$
(6)

where **R** is the standard Gaussian random matrix, i.e., its entries $r_{i,j}$ are independent identically distributed (i.i.d.) Gaussian. The sample covariance matrix **S** is defined as:

$$\mathbf{S} = \frac{1}{T} \mathbf{X} \mathbf{X}^H \tag{7}$$

For R, a special case, its sample covariance matrix is

$$\mathbf{S}_0 = \frac{1}{T} \mathbf{R} \mathbf{R}^H \tag{8}$$

If signals (see *I-B*) exist in the system, \mathcal{H}_0 will be reject.

E. RMM Analysis

Consider the sample covariance matrix of $\tilde{\mathbb{V}}$ defined in (6) under \mathcal{H}_0 .:

$$\underline{\mathbf{B}}_{N} = \frac{1}{T} \tilde{\mathbb{V}} \tilde{\mathbb{V}}^{H} = \frac{1}{T} \tilde{\mathbf{\Xi}} \mathbf{R} \mathbf{R}^{H} \tilde{\mathbf{\Xi}}^{H} = \tilde{\mathbf{\Xi}} \mathbf{S} \tilde{\mathbf{\Xi}}^{H}$$
(9)

Firstly, we define the following notations [21]:

$$\underline{\mathbf{C}}_N = \mathbf{S}_0 \mathbf{T} \tag{10}$$

$$\underline{\mathbf{D}}_N = \mathbf{T}^{1/2} \mathbf{S}_0 \mathbf{T}^{1/2}$$
(11)

$$\overline{\mathbf{C}}_T = \frac{1}{T} \mathbf{R}^H \mathbf{T} \mathbf{R}$$
(12)

where $\mathbf{T} = \tilde{\mathbf{\Xi}}^H \tilde{\mathbf{\Xi}}$ is a non-negative Hermitian matrix; \mathbf{T} is deterministic and independent of \mathbf{S}_0 . $\underline{\mathbf{B}}$, $\underline{\mathbf{C}}$, $\underline{\mathbf{D}}$, and $\overline{\mathbf{C}}$ share the same non-null eigenvalues [21]. We need this fact to use Lemma II.1.

Lemma II.1 (2010, [22], Section 2.4). Let \mathbf{S}_n be the sample covariance matrix defined in (7) with i.i.d. components and let \mathbf{T}_n be a sequence of nonnegative definite Hermitian matrices of size $p \times p$. Define $\mathbf{B}_n = \mathbf{S}_n \mathbf{T}_n$ and assume the following.

- Entries $x_{i,j}$ of **X** are *i.i.d.* with mean 0 and variance 1.
- X's sample size ratio $p/n \rightarrow y > 0$ when $n \rightarrow \inf$.
- \mathbf{T}_n is either deterministic or independent of \mathbf{S}_n .
- Almost surely, the sequence $H_n = F^{\mathbf{T}_n}$ of the empirical spectral distribution (ESD) of \mathbf{T}_n weakly converges to a nonrandom probability measure H.

Then almost surely, $F^{\mathbf{B}_n}$ weakly converges to a nonrandom probability measure $F_{y,H}$. Moreover its Stieltjes transform s(z) is implicitly defined by the equation

$$s(z) = \int \frac{1}{t(1 - y - yzs(z)) - z} dH(t), z \in \mathbb{C}^{+}$$
 (13)

Comparing with (10) indicates that (10) complies all the assumptions in Lemma II.1, by noting that the entries of **X** are Gaussian random variables, thus a special case of i.i.d..

The standard M-P distribution is easily recovered from (13). In this case, $\mathbf{T}_n = \mathbf{I}_p$ so that $H = \delta_1$, and (13) becomes:

$$s(z) = \frac{1}{1 - y - yzs(z) - z}$$
(14)

Consider another form, a $p \times n$ matrix

$$\mathbf{Y}_n = \frac{1}{\sqrt{n}} \boldsymbol{\Sigma}_n^{1/2} \mathbf{X}_n, \tag{15}$$

where Σ_n is a nonnegative definite Hermitian matrix and \mathbf{X}_n is a random matrix with i.i.d. real or complex standardized entries. The fluctuations of the LES [23]

$$\operatorname{Tr} \varphi \left(\mathbf{Y}_{n} \mathbf{Y}_{n}^{H} \right) = \sum_{i=1}^{p} \varphi \left(\lambda_{i} \right), \quad \lambda_{i} = \text{eigenvalues of } \mathbf{Y}_{n} \mathbf{Y}_{n}^{H}$$
(16)

are shown in [24] to be Gaussian, in the regime that both the dimensions p and n goes to infinity at the same pace and in the case where φ is an analytical function. Note that

$$\operatorname{Tr} \varphi \left(\mathbf{Y}_{n} \mathbf{Y}_{n}^{H} \right) = \operatorname{Tr} \varphi \left(\frac{1}{\sqrt{n}} \boldsymbol{\Sigma}_{n}^{1/2} \mathbf{X}_{n} \mathbf{X}_{n}^{H} \boldsymbol{\Sigma}_{n}^{1/2} \right)$$
$$= \operatorname{Tr} \varphi \left(\boldsymbol{\Sigma}_{n}^{1/2} \mathbf{S}_{n} \boldsymbol{\Sigma}_{n}^{1/2} \right) = \operatorname{Tr} \varphi \left(\mathbf{S}_{n} \boldsymbol{\Sigma}_{n} \right)$$
(17)

As a result, we build the *connection* between large random matrices and big data analytics. Fully driven by sampling data, we can obtain the experimental LESs via (16). Note that the **Y** in (16) is tied together with the sampling raw data \mathbb{V} through (6), (9), (10), and (17). We see [25] for more details about the mathematical foundations.

III. MATHEMATICAL STATISTICS ON LARGE RANDOM MATRICES

A. From Physical Grid to Random Matrix Model

For a power grid, there exist various parameters (e.g., frequency, voltage, current, and power). Among these, we often choose bus voltage magnitudes for further analysis. According to (4), we can obtain a random data matrix denoted as $\Omega_{n\times t}$ with t observations for a n-dimensional random vector.

The $\Omega_{n\times t}$ is in a high-dimensional space but not an infinite one; more explicitly, we are interested in the practical regime for a system of n = 100-3000 nodes. Any temporal and spacial sections can be considered in Ω , e.g., selecting T data points from t, and N nodes from n. These data points $\hat{v}_{i,j}$ form a matrix, denoted as $\hat{\mathbf{X}}_{N\times T}$. Note that $\Omega_{n\times t}$ can be updated as time goes by in a manner that the last column is the nearly real-time data.

The $\hat{\mathbf{X}}$ is a random matrix due to the presence of ubiquitous uncertainties in the system. Furthermore, we can convert $\hat{\mathbf{X}}$ into a normalized matrix $\tilde{\mathbf{X}}$ row-by-row:

$$\tilde{\mathbf{x}}_{i} = \frac{1}{\sigma_{i}(\hat{\mathbf{x}}_{i})} (\hat{\mathbf{x}}_{i} - \mu_{i}(\hat{\mathbf{x}}_{i})), \quad 1 \leq i \leq N$$
(18)

where $\hat{\mathbf{x}}_i = (\hat{x}_{i,1}, \dots, \hat{x}_{i,T})$. The μ_i denotes the mean for every node $i = 1, \dots, N$, and the σ_i denotes the standard deviation. Then we can conduct RMM analysis according to *II-E*.

B. Random Matrix Theory (RMT)

The mathematical tools of RMT include the Ring Law, the M-P Law, and the MSR.

1) Single Ring Theorem:

The Single Ring Theorem [26, 27] describes the ESD of a large generic matrix with prescribed singular values, i.e. an $N \times N$ matrix of the form $\mathbf{A} = \mathbf{U}_1 \Upsilon \mathbf{U}_2$, with \mathbf{U}_1 and \mathbf{U}_2 some independent Haar-distributed unitary matrices and Υ a deterministic matrix whose singular values are the ones prescribed.

2) Marchenko-Pastur Law (M-P Law): In II-C, we show that the ESD follows the generalized M-P distribution and satisfies the condition of being compactly supported limit measure. As a result, the Single Ring Theorem says that the empirical distribution is a single ring on the complex plane.

Lemma III.1 (Marchenko-Pastur Law, 1967, [28]). Assume a $N \times T$ random matrix **X** obeys condition⁴ **C1** with $C_0 \ge 4$, and $N, T \to \infty$ such that $\lim_{N\to\infty} N/T = c \in (0, 1]$, the ESD of the matrix **S** defined in (7) converges in distribution to the *M*-*P* Law with a density function:

$$\rho_{mp}(\lambda) = \begin{cases} \frac{1}{2\pi\lambda c\sigma^2} \sqrt{(a_+ - \lambda)(\lambda - a_-)} & \text{, } a_- \leqslant \lambda \leqslant a_+ \\ 0 & \text{, otherwise} \end{cases}$$
(19)

where $a_{\pm} = \sigma^2 (1 \pm \sqrt{c})^2$.

For the special case of i.i.d., see III-B4.

3) Universality Principle:

This principle [29] enables us to obtain the exact asymptotic distributions of various test statistics without restrictive distributional assumptions of matrix entries [30]. For a real system, we cannot expect the matrix entries to follow i.i.d. distribution. One can perform various hypothesis tests under the assumption that the matrix entries are not Gaussian distributed but use the same test statistics as in the Gaussian case. Numerous studies using both simulations and experiments demonstrate that the Ring Law and the M-P Law are universally valid—the asymptotic results are remarkably accurate for relatively moderate matrix sizes such as tens [12]. This is the very reason why RMT can handle practical massive systems.

4) Independent Identically Distributed Case:

For a rectangular $N \times T$ random matrix **X**, the entries are i.i.d. variables, satisfying

$$\mathbb{E}(X_{i,j}) = 0, \quad \mathbb{E}(X_{i,j}X_{m,n}) = \delta_{i,m}\delta_{j,n}\sigma^2$$
(20)

where δ is the Kronecker Delta Function defined as

$$\delta_{\alpha,\beta} = \begin{cases} 1 & \alpha = \beta \\ 0 & \alpha \neq \beta. \end{cases}$$

For the normalized data matrix $\hat{\mathbf{X}}$ obtained as (18), according to [31], we define its singular value equivalent as

$$\mathbf{X}_u = \sqrt{\tilde{\mathbf{X}} \tilde{\mathbf{X}}^H} \mathbf{U}, \ \mathbf{U} \in \mathbb{C}^{N imes N}$$
 is a Haar unitary matrix.

Then, for L independent matrices $\mathbf{X}_{u,i}$, we consider their product

$$\mathbf{Z} = \prod_{i=1}^{L} \mathbf{X}_{u,i}.$$

⁴The matrix ensemble is said to obey condition **C1** with constant C_0 if the random variables $X_{i,j}$ are jointly independently, having zero mean and variance one, and obey the moment condition $\sup \mathbb{E}|X_{i,j}|^{C_0} \leq C$.

The product \mathbf{Z} is converted into $\tilde{\mathbf{Z}}$ as

$$\tilde{\mathbf{z}}_i = \mathbf{z}_i / (\sqrt{N}\sigma_i(\mathbf{z}_i)), \quad 1 \leqslant i \leqslant N$$

where $\mathbf{z}_i = (z_{i,1}, \cdots, z_{i,N})$. Based on (??) and (19), the ESD of \mathbf{Z} converges almost surely to the same limit given by [32]

$$\rho_{\rm ring}(\lambda) = \begin{cases} \frac{1}{\pi cL} |\lambda|^{(2/L-2)} &, (1-c)^{L/2} \leqslant |\lambda| \leqslant 1\\ 0 &, \text{ otherwise} \end{cases}$$
(21)

as $N, T \to \infty$ with the ratio $c = N/T \in (0, 1]$. 5) Mean Spectral Radius (MSR):

The geometrically motivated MSR is a statistic that is a complicated function of collected data vectors; it may also be viewed as a certain LES, as defined in (16). For any matrix, such as \mathbf{Z} , we can obtain its eigenvalues $\lambda_i(\mathbf{Z}), i = 1, ..., N$ on the complex plane. The mean value of all these eigenvalues' radii is denoted as τ_{MSR} :

$$\tau_{\rm MSR} = \frac{1}{N} \sum_{i=1}^{N} |\lambda_i(\tilde{\mathbf{Z}})|, \qquad (22)$$

where N is typically large, say in the order of 100 - 3000. The large value of N has a far-reaching effect. That is the reason why the Gaussian properties of such LESs as $\tau_{\rm MSR}$ may be justified [22, 25]. The facts are analogues of the CLTs in classical probability.

IV. LINEAR EIGENVALUE STATISTICS OF LARGE RANDOM MATRICES

A. Linear Eigenvalue Statistics

1) Definition:

The LES τ of an arbitrary matrix $\mathbf{\Gamma} \in \mathbb{C}^{N \times N}$ is defined via the continuous test function $\varphi : \mathbb{C} \to \mathbb{C}$. [23, 33]

$$\tau(\varphi, \mathbf{\Gamma}) = \mathcal{N}_N[\varphi] = \sum_{i=1}^N \varphi(\lambda_i) = \operatorname{Tr}\varphi(\mathbf{\Gamma})$$
(23)

where the trace of the function of a random matrix is involved.

It is very interesting to study the special case for a Gaussian random matrix. For power grids, the universality principle is extremely relevant in this context.

2) Law of Large Numbers:

The law of Large Numbers tells us that $N^{-1}\mathcal{N}_N[arphi]$ converges in probability to the limit

$$\lim_{N \to \infty} \frac{1}{N} \mathcal{N}_N[\varphi] = \int \varphi(\lambda) \rho(\lambda) \, d\lambda \tag{24}$$

where $\rho(\lambda)$ is the probability density function of λ .

3) Central Limit Theorem of LES:

The CLT [23, 33–38], as the natural second step, aims to study the LES fluctuations. Consider another form of covariance matrix:

$$\mathbf{M} = \frac{1}{N} \mathbf{X} \mathbf{X}^{H} = \frac{1}{c} \mathbf{S}_{N}$$
(25)

According to (19), its ESD converges to

$$\rho_{mp_2}(\lambda) = \begin{cases} \frac{1}{2\pi\lambda\sigma^2}\sqrt{(b_+ - \lambda)(\lambda - b_-)} & \text{, } b_- \leqslant \lambda \leqslant b_+\\ 0 & \text{, otherwise} \end{cases}$$
(26)

where $b_{\pm} = \sigma^2 (1 \pm 1/\sqrt{c})^2$.

The CLT for M is given as follows [33]:

Theorem IV.1 (M. Sheherbina, 2009). Let the real valued test function φ satisfy condition $\|\varphi\|_{3/2+\varepsilon} < \infty$ ($\varepsilon > 0$). Then $\mathcal{N}_N^{\circ}[\varphi]$ defined in (24), in the limit $N, T \to \infty, c = N/T \leq 1$, converges in the distribution to the Gaussian random variable with zero mean and the variance:

$$V_{SC}\left[\varphi\right] = \frac{2}{c\pi^2} \iint_{-\frac{\pi}{2} < \theta_1, \theta_2 < \frac{\pi}{2}} \psi^2\left(\theta_1, \theta_2\right) \left(1 - \sin\theta_1 \sin\theta_2\right) d\theta_1 d\theta_2 + \frac{\kappa_4}{\pi^2} \left(\int_{-\frac{\pi}{2}}^{\frac{\pi}{2}} \varphi\left(\zeta\left(\theta\right)\right) \sin\theta d\theta\right)^2$$
(27)

where $\psi(\theta_1, \theta_2) = \frac{\left[\zeta(\theta)\right] \left[\theta = \theta_2}{\left[\zeta(\theta)\right] \left[\theta = \theta_2\right]}, \left[\zeta(\theta)\right] \left[\theta = \theta_1 = \zeta(\theta_1) - \zeta(\theta_2), \theta = \theta_2$ and $\zeta(\theta) = 1 + 1/c + 2/\sqrt{c}\sin\theta$; $\kappa_4 = \mathbb{E}(X^4) - 3$ is the 4-th cumulant of entries of X.

B. LES Designs and the Theoretical Values

A typical scenario is assumed to obtain the theoretical values: N = 118, T = 240, and c = N/T = 0.4917.

1) LES for Ring Law:

The MSR defined as (22) is in a special form of a LES. Since $\lambda_i(\mathbf{Z}), i = 1, ..., N$ are highly correlated random variables; each one is a complicated function of the raw random matrices $\hat{\mathbf{X}}$, and thus τ_{MSR} itself is a random variable, the sum of dependant random variables divided by the total number. The self-averaging property [25] with a large matrix size N is remarkable. According to (21) and (24), the theoretical expectation of the random variable τ_{MSR} , as $N \rightarrow \infty$, approaches asymptotically the limit:

$$\mathbb{E}(\tau_{\text{MSR}}) = \iint_{\text{Area}} \rho_{\text{ring}}(r) \times r \cdot r \, \mathrm{d}r \, \mathrm{d}\theta$$
$$= \int_{0}^{2\pi} \int_{\sqrt{1-c}}^{1} \frac{1}{c\pi} r \cdot r \, \mathrm{d}r \, \mathrm{d}\theta = 0.8645$$
(28)

In practice, we can use this asymptotic limit to replace the true value (unknown) for a finite value of N, when N is sufficiently large.

2) LES for Covariance Matrices:

1. Chebyshev Polynomials (T_2) : $\varphi(\lambda) = 2x^2 - 1$

$$\tau_{T_2} = \sum_{i=1}^{N} (2\lambda_i^2 - 1), \qquad (29)$$

and according to (23), (24), and (26), we obtain

$$\mathbb{E}(\tau_{T_2}) = N \int \varphi(\lambda) \rho_{\text{mp2}}(\lambda) \, d\lambda = 1338.3.$$
(30)

According to (27), we write the variance as

$$\mathbb{D}(\tau_{T_2}) = 665.26. \tag{31}$$

Similarly, for a rectangular data matrix Γ , according to (23), we can obtain various LESs $\tau(\varphi, \Gamma)$ via designing different test functions, as well as their theoretical values. Here we list some classical test functions:

- 2. Chebyshev Polynomials (T_3) : $\varphi(x) = 4x^3 3x$
- 3. Chebyshev Polynomials (T₄): $\varphi(x) = 8x^4 8x^2 + 1$
- 4. Generalized variance or determinant (DET): $\varphi(x) =$ $\ln(x)$

5. Likelihood-ratio test (LRT): $\varphi(x) = x - \ln(x) - 1$

The methodology of SA based on a class of LESs, including technical route, concrete procedures, evaluation system, and advantages over classical one, is another meaningful topic. Here, we do not expand on this and just show the characteristics from the indicator perspective.

According to IV-B, numerous LESs are able to be designed for a ceratin RMM X. With these LESs, the high-dimensional indicator system is built; it gives us a multiple view angle to gain insight into the system—the test function is similar to a filter in some sense. Table II lists the features of the LES indicator and makes a comparison with the classical one.

As pointed out in Table II, the LES indicator system provides a much better way, compared to the classical one, to utilize the massive data for a complex system. The relation of the former to the later, in some sense, is just like that of the quantum physics⁵ to the classical one. Instead of accurate measurements and descriptions (for the mass, position, velocity, etc), the later gives probabilistic statistics. By comparing the experimental values (always fully data-driven) with ideal theoretical values (guaranteed by theorems), the complicated system is understood statistically.

In short, with the help of RMT, we can investigate a datadriven methodology, based on which we can turn the real power grid into RMMs, using measurements such as PMUs. With a pure mathematical procedure, a class of statistical indicators is formed as a new epistemology for the grid. Some advantages of this epistemology—such as data-driven and model-free, speed, reasonableness, sensitivity—have already been shown in our previous work [12, 13]; we will show its flexibility and robustness against bad data in the *Section V*.

V. FUNCTIONS DESIGN WITH LES AND RELATED CASES

For the background, we adopt IEEE 118-bus system with 6 partitions [12] (Fig. 8). The SA functions, *anomaly detection* and *fault diagnosis*, and *correlation analysis* based on MSR, have already been designed in our previous work [12] and [13] respectively. This paper pushes the design forward.

A. SA based on Theoretical Exception

We assume the events as shown in Table III; the final result is illustrated as the solid blue line in Fig. 2. According to III-A, we obtain a data source $\Omega_{\mathbf{V}}: \hat{v}_{i,j} \in \mathbb{R}^{118 \times 1600}$ for N =118 nodes with T = 1600 time instants. Noting that the grid fluctuations are set by γ_{Acc} and γ_{Mul} as [12]

$$\tilde{y}_{\text{load}_nt} = y_{\text{load}_nt} \times (1 + \gamma_{\text{Mul}} \times r_1) + \gamma_{\text{Acc}} \times r_2 \tag{32}$$

where r_1 and r_2 are standard Gaussian random variable.

STAGE	E1	E2	E3	E4
TIME (S)	1-400	401-800	801-1200	1201-1600
$P_{\text{BUS-52}}$ (MW)	18	18	300	t/3 - 100
$P_{Fluctuation}$	none	small: γ_{Ac}	$_{c}=0.1, \gamma_{Mu}=0.$	001

TABLE III: Series of Events

 $*P_{\text{Bus-52}}$ is power demand of bus-52.

⁵The quantum physics is one of the greatest achievements in the history of physics; it is unreasonably effective and still influences and puzzles us deeply nowadays [39].

With the previous work [12], the τ_{MSR} -t curve is obtained, as illustrated in Fig. 2, to conduct anomaly detection. The τ_{MSR} starts the dramatic changes at the instants t=801 s and t=1378 s; these are right the beginning for the event of stepchange and voltage collapse, respectively.



Fig. 2: $\tau_{MSR}t$ -curve and stage division

1) LES Designs and Static Stability Evaluation:

Keep N=118 and T=240. According to *IV-B*, numerous LESs τ are designed and they empirically converge in the distribution to the Gaussian variables with means $\mathbb{E}(\tau)$ and variances $\mathbb{D}(\tau)$. These theoretical values are able to be obtained via a similar statistical process to (28), (29), (30), and (31), and are shown in **E0** part of Table IV.

On the other side, the experimental LESs at each time instant t, denoted as $\tau_{\varphi}(t)$, are obtained via a *fully data driven* procedure, in turn, as (18), (25) and (23). Duration a stage, we acquire $\tau_{\varphi}(t_1), \dots, \tau_{\varphi}(t_k)$, and then, their statistics—Mean $\mu(\tau)$ and Variance $\sigma(\tau)$. Table IV is mainly such an illustration of these statistics for the given case. Taking the raw data about voltage magnitude as an example, following steps are needed as the preprocess:

- We can set the data-processing interval, i.e. the step between $\tau_{\varphi}(t_j)$ and $\tau_{\varphi}(t_{j+1})$, to a single sampling time point (i.e. $\Delta t_{\text{DP}} = 1$) to conduct one-by-one moving splitwindow analysis, or to T points (i.e. $\Delta t_{\text{DP}} = T$) to make $\tau_{\varphi}(t_1), \dots, \tau_{\varphi}(t_k)$ independent⁶ on the time series.
- There exist, in a system, numerous PV nodes and $V\theta$ nodes whose voltage magnitudes keep constant and will lead to a singular matrix; there are also some small signals, causing by input noises, needed to be filtered. Therefore, we add a small random fluctuation; the signal-to-noise ratio (SNR) is set as 0.002 experientially, i.e., $v_{ij} = v_{ij} + 0.002r$, where r is a Gaussian random variable.
- The normalization is introduced as (18).

Above steps will change the theoretical variation to some value, denoted as $\mathbb{D}_1(\tau)$; $\mathbb{D}_1(\tau)$ is able to be obtained in advance by simulations using the ideal inputs, i.e., standard random matrix $\mathbf{X}_{118\times 240}$, with the same data preprocessing.

Suppose the sampling frequency is high enough and the $\Delta t_{\rm DP} = T$. Thus, for a constant state, such as E1: no fluctuations around 18 MW, we can obtain more than 40

⁶They do not shall a same vector.

LES IndicatorClassical Indicatordata-driven and model freemodel basedsupported by novel theoremssupported by tradition lawsunclearly defined engineering conceptclearly defined onesensors and network of high quality are requiredsensors and network are OK is enoughprobabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datasensitive to individual datapure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T) the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemdecoupling based on assumptions and simplifications		
data-driven and model freemodel basedsupported by novel theoremssupported by tradition lawsunclearly defined engineering conceptclearly defined onesensors and network of high quality are requiredsensors and network are OK is enoughprobabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datasensitive to individual datapure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T) the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemin a fix/inflexible form	LES Indicator	Classical Indicator
supported by novel theoremssupported by tradition lawsunclearly defined engineering conceptclearly defined onesensors and network of high quality are requiredsensors and network are OK is enoughprobabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datasensitive to individual datarobust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T) the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemdecoupling based on assumptions and simplifications	data-driven and model free	model based
unclearly defined engineering conceptclearly defined onesensors and network of high quality are requiredsensors and network are OK is enoughprobabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datathe value relies on a few data (<model's dimensions)<="" td="">robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T)the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemin a fix/inflexible form</model's>	supported by novel theorems	supported by tradition laws
sensors and network of high quality are requiredsensors and network are OK is enoughprobabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datathe value relies on a few data (<model's dimensions)<="" td="">robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T)the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemdecoupling based on assumptions and simplifications</model's>	unclearly defined engineering concept	clearly defined one
probabilistic valueaccurate onestatistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datathe value relies on a few data (<model's dimensions)<="" td="">robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T)the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)naturally decoupling the interconnected systemdecoupling based on assumptions and simplifications</model's>	sensors and network of high quality are required	sensors and network are OK is enough
statistic in high dimensionsoften in low dimensionsthe value relies on massive (all) datathe value relies on a few data (<model's dimensions)<="" td="">robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errorssystem errors are inevitablerandom errors can be estimated with the model size (N, T)the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)readily transformation in statistical space (preprocessing)in a fix/inflexible formnaturally decoupling the interconnected systemdecoupling based on assumptions and simplifications</model's>	probabilistic value	accurate one
the value relies on massive (all) datathe value relies on a few data (<model's dimensions)<="" th="">robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errors random errors can be estimated with the model size (N, T)system errors are inevitable the errors depend on the model building procedurecompatible with diverse data readily transformation in statistical space (preprocessing) naturally decoupling the interconnected systemonly for the assigned ones (relying on the model) in a fix/inflexible form decoupling based on assumptions and simplifications</model's>	statistic in high dimensions	often in low dimensions
robust against bad data and insensitive to individual datasensitive to sample selections and the trainingpure statistical procedure without system errors random errors can be estimated with the model size (N, T)system errors are inevitable the errors depend on the model building procedurecompatible with diverse data readily transformation in statistical space (preprocessing) naturally decoupling the interconnected systemonly for the assigned ones (relying on the model) in a fix/inflexible form decoupling based on assumptions and simplifications	the value relies on massive (all) data	the value relies on a few data (<model's dimensions)<="" td=""></model's>
pure statistical procedure without system errors random errors can be estimated with the model size (N, T) system errors are inevitable the errors depend on the model building procedurecompatible with diverse data readily transformation in statistical space (preprocessing) naturally decoupling the interconnected systemonly for the assigned ones (relying on the model) in a fix/inflexible form decoupling based on assumptions and simplifications	robust against bad data and insensitive to individual data	sensitive to sample selections and the training
random errors can be estimated with the model size (N, T)the errors depend on the model building procedurecompatible with diverse dataonly for the assigned ones (relying on the model)readily transformation in statistical space (preprocessing)in a fix/inflexible formnaturally decoupling the interconnected systemdecoupling based on assumptions and simplifications	pure statistical procedure without system errors	system errors are inevitable
compatible with diverse dataonly for the assigned ones (relying on the model)readily transformation in statistical space (preprocessing)in a fix/inflexible formnaturally decoupling the interconnected systemdecoupling based on assumptions and simplifications	random errors can be estimated with the model size (N, T)	the errors depend on the model building procedure
readily transformation in statistical space (preprocessing) naturally decoupling the interconnected systemin a fix/inflexible form decoupling based on assumptions and simplifications	compatible with diverse data	only for the assigned ones (relying on the model)
naturally decoupling the interconnected system decoupling based on assumptions and simplifications	readily transformation in statistical space (preprocessing)	in a fix/inflexible form
	naturally decoupling the interconnected system	decoupling based on assumptions and simplifications

independent RMMs $\mathbf{X}_i \in \mathbb{R}^{118 \times 240}$ $(i = 1, \dots, 40, \dots)$. E1– E3 parts show these experimental statistics; sorted by the deviations of the means from its theoretical predictions, it goes that E1 < E2 < E3.

2) LES System Performance for SA in this Case:

Back to the assumed scenes, according to the anomaly source $P_{\text{Bus-52}}$ and window size *T*, we divide the temporal space into 7 stages: S1–S7, shown as Fig. 2. Parts S1–S7 in Table IV show the performance of the designed LESs. Roughly speaking, sorted by the means they are arranged as S1 < S2 < S3 < S5 < S6 << S4 << S7, and by the variances as max(S1, S3, S5) << S2 << S4 << S6 << S7.

We summarize the performance of the LES system in SA: a). The LES system is effective for stability evaluation. By comparing the deviation between the experimental value and the theoretical/empirical value for different system operating periods (E1 < E2 < E3), it come to a conclusion that *the more steady the system is, the less the deviation becomes.*

b). When the system is under equilibrium operating situations without anomaly events occurring (E1, E2, E3), its LESs τ follow a Gaussian distribution,⁷ which in turn validates the theories in (16).

c). The RMMs and LESs are able to be linked to some novel models, such as the *matrix-valued Brownian Movement*. It is another topic and we will not expand here.

d). Different test functions $\varphi(\lambda)$ have different characteristics and effectiveness; the signal may be sensitive to some test functions but not others. A test function is akin to a filter in some sense. Hence, we can balance the reliability and sensitivity for the detection in a special circumstance. Moreover, beyond benefiting anomaly detection (aiming to distinguish signals from noises), the test functions give us much more selections to handle the complicate situation and have the potential to trace a specific anomaly (aiming to distinguish the mixed signals).

e). Low c_v means high precision and repeatability of the assay [40]; from the aspect of c_v , MSR performs best. Especially, for a special purpose, e.g. the lowest c_v or the lowest bias, there exists an optimal combination of Chebyshev Polynomials for the test function.

TABLE IV: LESs and their Values

	MSR	T_2	T_3	T_4	DET	LRF
E0: The	oretical Valu	e				
$\mathbb{E}(au)$	0.8645	1338.3	10069	8.35E4	48.322	73.678
$\mathbb{D}_{\mathrm{T}}(\tau)$	_	665.26	93468	1.30E7	1.3532	1.4210
$\mathbb{D}_1(\tau)$	4.4E - 6	62.550	22197	4.25E6	0.3589	0.3646
c_v	0.0024	0.0059	0.0148	0.0274	0.0124	0.0082
E1 [inde	pendent, 40]	: No fluctu	ations aro	und 18 MW	/	
μ_0	1.0001	0.9909	0.9865	0.9775	0.9885	0.9932
c_{T0}	-	0.8832	0.9743	1.0453	0.8525	0.8461
E2 [inde	pendent, 40]	: Small flu	ctuations a	around 18 M	ΛW	
μ_0	0.9382	1.2091	1.6950	2.6860	0.6465	1.2196
c_{T0}	-	1.8532	2.2643	2.7016	2.1945	1.2051
E3 [inde	pendent, 40]	: Small flu	ctuations a	around 300	MW	
μ_0	0.9064	1.2765	2.0098	3.7752	0.4095	1.3753
c_{T0}	-	2.0341	2.7852	3.5392	3.2977	0.9713
S1 [0240):0400, 161]:	No fluctu	ations arou	und 18 MW		
μ_0	1.0029	0.9856	0.9763	0.9678	1.0010	0.9861
c_0	0.7022	0.5407	0.6013	0.6008	0.7150	0.7519
S2 [040]	1:0639, 239]:	Transition	stage from	m S1 to S3		
μ_0	0.9714	1.1045	1.3517	1.8213	0.8314	1.0966
c_0	6.0177	8.9959	9.9893	10.982	7.5281	5.6884
S3 [0640):0800, 161]:	Small flue	ctuations a	round 18 N	IW	
μ_0	0.9518	1.1801	1.6208	2.5243	0.7239	1.1669
c_0	0.6892	1.0035	1.1688	1.2319	1.0925	0.6587
S4 [080]	1:1039, 239]:	A step sig	gnal (18 M	IW † 300 N	MW) is inclu	uded
μ_0	0.6170	8.4518	153.47	2712.4	-3.081	3.6629
c_0	20.335	22.620	13.930	10.413	-12.92	10.796
S5 [1040):1200, 161]:	Small flue	ctuations a	round 300	MW	
μ_0	0.9051	1.3204	2.3883	5.5954	0.3439	1.4169
c_0	0.9242	1.4981	1.8841	2.2357	2.5537	0.6236
S6 [120]	1:1377, 177]:	A ramp s	ignal (300	MW > 35	59 MW) is i	ncluded
μ_0	0.7921	3.4210	33.153	377.95	-0.789	2.1595
c_0	32.664	66.503	46.417	33.682	-65.47	23.718
S7 [1378:1600, 223]: Static voltage collapse						
μ_0	0.3976	10.832	239.38	5831.3	-16.98	12.781
c_0	91.867	100.67	70.117	51.575	-22.80	30.070

 $c_v = \sqrt{\mathbb{D}_1(\tau)}/\mathbb{E}(\tau)$ is the coefficient of variation;

 $c_{\text{T0}} = \sigma(\tau)/\sqrt{\mathbb{D}_{\text{T}}}, c_0 = \sigma(\tau)/\mu(\tau)/c_v, \text{ and } \mu_0 = \mu(\tau)/\mathbb{E}(\tau).$

B. Other LES Functions and the Visualization

We can also utilize LESs to implement some other concrete functions, e.g., fault diagnosis. By introducing the augmented matrix $(\mathbf{A} = [\mathbf{B}; \mathbf{C}])$ which consists of the basic status data (B) and the factor data (C), our previous work [13] conducts the correlation analysis with the LESs of A and B. It is a feasible data-driven approach to find out the causing factor of the anomaly with no knowledge in advance.

The LES is a statistical indicator; its value depends on a large number of sample data points $\hat{x}_{i,j}$ in the form of the entries of the matrix X. It means that LES τ is universal with the least assumptions and robust against individual bad data. Then, a case is designed to validate the robustness. Furthermore, the case also gives the visualization of the system from LES indicator perspective; meanwhile, a comparison with perspective of low-dimensional indicator, e.g., raw data V, is made.

We keep the assumed scenario in Table III, and take $\tau_{\rm LRF}$ as the test function. We obtain a local $\mu_0 = \tau_{\rm LRF} / \mathbb{E}(\tau_{\rm LRF})$ for each region in a similar way to that of the whole system (118 nodes); thus, the μ_0 -t curves are plotted as Fig. 3. The division depends on the specific network structure; however, a potential problem lies here: how small the partition (Fig. 8) can be that keeps the theories still work. To find the answer we should study how to turn big data into tiny data [41]; it is another topic and we do not expand here.



Fig. 3: μ_0 -t Curve for Single Partitioning: A1–A6

With an interpolation method [42], a 3D power map is plotted as the illustration of μ_0 ; then the animation is produced. Fig. 4 and Fig. 6 depict some key frames of the animation about LES indicator μ_0 , whereas Fig. 5 and Fig. 7 about raw data \mathbf{V} . From Fig. 3 and the animation, we obtain:

a) In Fig 4, at t = 801 s, μ_0 of A3 area changes dramatically and keeps for T sampling points. The duration T is observed in the animation; it is also reflected by Fig. 3. Therefore, we deduce that some event occurs in A3; even we can go further that the event is a regional one and influential to A1, A2, A4, A5, and has little impact on A6. These conjectures, in a reasonable way, coincide with the common sense that there is a sudden load change in A3 at t=801 s as we assumed in Table III.

b) With sustainable growth of P_{Bus-52} , the whole system becomes more and more vulnerable. The vulnerability, before

the system has a breakdown due to voltage collapse, can be estimated in advance via the animation of μ_0 .

c) Subfigures of (c), (d), (e) are almost the same for Fig. 7, but not for Fig. 6; the animation demonstrates this phenomenon more clearly. That means, even with the most related data (data of A3) losses which will lead to an insufficient SA using V, the proper judgements can still be achieved by μ_0 .

d) In this way, the interconnected grid is decoupled naturally. We can conduct regional SA only with its own datasets; these datasets are relatively independent.

VI. CONCLUSION

This paper, motivated for the future's electrical grid, studies the situation awareness (SA) based on linear eigenvalue statistics (LESs). Three ingredients are essential for the data-driven SA: 1) data modeling-building the random matrix model (RMM) for a certain physical problem and employing the RMM to connect the sampling data with statistical theories/tools; 2) data analytics-conducting highdimensional analysis to obtain the statistical indicators LESs; 3) interpretation—interpreting and visualizing the indicators to gain insight into the system.

For engineering applications, based on the experimental LESs which are fully derived from the sampling data, various SA functions are studied; for example, by comparing the LESs with their theoretical prediction, the anomaly detection is conducted. In addition, the 3D power-map animation is developed for the visualization.

Future research directions include: (1) Model validation with different implementations of the grid, ranging from statistic, dynamic and real-world systems; (2) Data fusion with a number of random data matrices, using mathematical tools such as free probability; (3) The use of Gaussian random matrices in replacement for general data matrices that are obtained from the electrical grid. The universality principle of random matrix theory says that this replacement causes negligible errors. (4) The convergence rate of the central limit theorem, using the Berry-Essen type of inequalities [25], is used to study how fast the number of the data nodes (such as PMUs) converges to the limit.



(a) $t_s = 800 \text{ s}$

Fig. 7: Visualization of the Voltage $\hat{\mathbf{V}}$ without Data Set of A3



Fig. 8: Partitioning network for the IEEE 118-bus system. There are six partitions, i.e. A1, A2, A3, A4, A5, and A6.

REFERENCES

- [1] U. DOE, "Grid 2030: A national vision for electricity's second 100 years," US DOE Report, 2003.
- [2] S. Grijalva and M. U. Tariq, "Prosumer-based smart grid architecture enables a flat, sustainable electricity industry," in Innovative Smart Grid Technologies (ISGT), 2011 IEEE PES. IEEE, 2011, pp. 1-6.
- [3] U.-C. P. S. O. T. Force, S. Abraham, H. Dhaliwal, R. J. Efford, L. J. Keen, A. McLellan, J. Manley, K. Vollman, N. J. Diaz, T. Ridge et al., Final report on the August 14, 2003 blackout in the United states and Canada: causes and recommendations. US-Canada Power System Outage Task Force, 2004.
- [4] P. Wong, P. Albrecht, R. Allan, R. Billinton, Q. Chen, C. Fong, S. Haddad, W. Li, R. Mukerji, D. Patton et al., "The IEEE reliability test system-1996. a report prepared by the reliability test system task force of the application of probability methods subcommittee," Power Systems, IEEE Transactions on, vol. 14, no. 3, pp. 1010-1020, 1999.
- [5] A. Phadke and R. M. de Moraes, "The wide world of widearea measurement," Power and Energy Magazine, IEEE, vol. 6, no. 5, pp. 52-65, 2008.

- [6] V. Terzija, G. Valverde, D. Cai, P. Regulski, V. Madani, J. Fitch, S. Skok, M. M. Begovic, and A. Phadke, "Wide-area monitoring, protection, and control of future electric power networks," *Proceedings of the IEEE*, vol. 99, no. 1, pp. 80–93, 2011.
- [7] L. Xie, Y. Chen, and P. Kumar, "Dimensionality reduction of synchrophasor data for early event detection: Linearized analysis," *Power Systems, IEEE Transactions on*, vol. 29, no. 6, pp. 2784–2794, 2014.
- [8] J. M. Lim and C. L. DeMarco, "Svd-based voltage stability assessment from phasor measurement unit data," *IEEE Transactions on Power Systems*, vol. PP, no. 99, pp. 1–9, 2015.
- [9] J. Giri, M. Parashar, J. Trehern, and V. Madani, "The situation room: Control center analytics for enhanced situational awareness," *Power and Energy Magazine, IEEE*, vol. 10, no. 5, pp. 24–39, 2012.
- [10] W. Xu and J. Yong, "Power disturbance data analytics-new application of power quality monitoring data," *Proceedings of the CSEE*, vol. 33, no. 19, pp. 93–101, July 2013.
- [11] J. W. Simpson-Porco, F. Dörfler, and F. Bullo, "Voltage collapse in complex power grids," *Nature communications*, vol. 7, 2016.
- [12] X. He, Q. Ai, R. C. Qiu, W. Huang, L. Piao, and H. Liu, "A big data architecture design for smart grids based on random matrix theory," *ArXiv e-prints*, Jan. 2015, accepted by IEEE Trans on Smart Grid. [Online]. Available: http://arxiv.org/pdf/1501.07329.pdf
- [13] X. Xu, X. He, Q. Ai, and C. Qiu, "A correlation analysis method for power systems based on random matrix theory," *ArXiv e-prints*, Jun. 2015, accepted by IEEE Trans on Smart Grid. [Online]. Available: http://arxiv.org/pdf/1506.04854.pdf
- [14] X. He, R. C. Qiu, Q. Ai, L. Chu, and X. Xu, "Linear eigenvalue statistics: An indicator ensemble design for situation awareness of power systems," *ArXiv e-prints*, Dec. 2015. [Online]. Available: http://arxiv.org/pdf/1512.07082.pdf
- [15] M. Panteli, P. Crossley, D. S. Kirschen, D. J. Sobajic *et al.*, "Assessing the impact of insufficient situation awareness on power system operation," *Power Systems, IEEE Transactions on*, vol. 28, no. 3, pp. 2967–2977, 2013.
- [16] M. R. Endsley, Designing for situation awareness: An approach to user-centered design. CRC Press, 2011.
- [17] C. Brice and S. K. Jones, *Physically Based Stochastic Models of Power System Loads*. College Station, TX, USA: Texas A&M Research Foundation, 1982.
- [18] P. J. Brockwell and R. A. Davis, *Introduction to time series and forecasting*. Springer Science & Business Media, 2006.
- [19] M. Perninge, V. Knazkins, M. Amelin, and L. Söder, "Modeling the electric power consumption in a multi-area system," *European transactions on electrical power*, vol. 21, no. 1, pp. 413–423, 2011.
- [20] C. Sankavaram, A. Kodali, K. R. Pattipati, and S. Singh, "Incremental classifiers for data-driven fault diagnosis applied to automotive systems," *Access, IEEE*, vol. 3, pp. 407–419, 2015.
- [21] J. Yao, Z. Bai, and S. Zheng, Large Sample Covariance Matrices and High-Dimensional Data Analysis. Cambridge University Press, 2015.
- [22] Z. Bai and J. Silverstein, Spectral Analysis of Large Dimensional Random Matrices, second edition ed. Springer Verlag, 2010.
- [23] A. Lytova, L. Pastur *et al.*, "Central limit theorem for linear eigenvalue statistics of random matrices with independent entries," *The Annals of Probability*, vol. 37, no. 5, pp. 1778–1840, 2009.
- [24] J. Najim, "Gaussian fluctuations for linear spectral statistics of large random covariance matrices," arXiv preprint arXiv:1309.3728, 2013.
- [25] R. C. Qiu, Big Data for Complex Network. CRC, 2016, ch. Large Random Matrices and Big Data Analytics.
- [26] A. Guionnet, M. Krishnapur, and O. Zeitouni, "The single ring theorem," *Annals of Mathematics*, vol. 174, no. 2, pp. 1189– 1217, 2011.

- [27] T. Tao and V. Vu, "Random matrices: Sharp concentration of eigenvalues," *Random Matrices: Theory and Applications*, vol. 2, no. 03, p. 1350007, 2013.
- [28] V. A. Marčenko and L. A. Pastur, "Distribution of eigenvalues for some sets of random matrices," *Sbornik: Mathematics*, vol. 1, no. 4, pp. 457–483, 1967.
- [29] R. van Handel, "Probability in high dimension," Princeton University, ORF 570 Lecture Notes, June 2014.
- [30] R. Qiu and M. Wicks, Cognitive Networked Sensing and Big Data. Springer, 2013.
- [31] J. R. Ipsen and M. Kieburg, "Weak commutation relations and eigenvalue statistics for products of rectangular random matrices," *Physical Review E*, vol. 89, no. 3, 2014, Art. ID 032106.
- [32] R. Qiu and P. Antonik, Smart Grid and Big Data. John Wiley and Sons, 2015.
- [33] M. Shcherbina, "Central limit theorem for linear eigenvalue statistics of the wigner and sample covariance random matrices," *ArXiv e-prints*, Jan. 2011. [Online]. Available: http://arxiv.org/pdf/1101.3249.pdf
- [34] K. JOHANSSON, "On fluctuations of eigenvalues of random hermitian matrices," *Duke mathematical journal*, vol. 91, no. 1, pp. 151–204, 1998.
- [35] A. Guionnet, "Large deviations upper bounds and central limit theorems for non-commutative functionals of gaussian large random matrices," in *Annales de l'IHP Probabilités et statistiques*, vol. 38, no. 3, 2002, pp. 341–384.
- [36] Z. D. Bai, J. W. Silverstein *et al.*, "CLT for linear spectral statistics of large-dimensional sample covariance matrices," *Annals of Probability*, vol. 32, no. 1, p. 553, 2004.
- [37] G. W. Anderson and O. Zeitouni, "A CLT for a band matrix model," *Probability Theory and Related Fields*, vol. 134, no. 2, pp. 283–338, 2006.
- [38] G. Pan, Q. Shao, and W. Zhou, "Universality of sample covariance matrices: CLT of the smoothed empirical spectral distribution," *ArXiv e-prints*, Nov. 2011. [Online]. Available: http://arxiv.org/pdf/1111.5420.pdf
- [39] T. Capo, *History of quantum physics*. Liaoning Education Press, 2008.
- [40] F. W. Nutter Jr and P. M. Schultz, "Improving the accuracy and precision of disease assessments: selection of methods and use of computer-aided training programs," *Canadian Journal of Plant Pathology*, vol. 17, no. 2, pp. 174–184, 1995.
- [41] D. Feldman, M. Schmidt, and C. Sohler, "Turning big data into tiny data: Constant-size coresets for k-means, pca and projective clustering," in *Proceedings of the Twenty-Fourth Annual ACM-SIAM Symposium on Discrete Algorithms*. SIAM, 2013, pp. 1434–1453.
- [42] J. D. Weber and T. J. Overbye, "Voltage contours for power system visualization," *Power Systems, IEEE Transactions on*, vol. 15, no. 1, pp. 404–409, 2000.