

# Hybrid Top-Down and Bottom-Up Approach for Residential Load Compositions and Percentages

Ahmed S. Alahmed

Electrical Engineering Department  
King Fahd University of Petroleum and Minerals  
Dhahran, Saudi Arabia  
Email: alahmad@kfupm.edu.sa

Muhammed M. Almuahini

Electrical Engineering Department  
King Fahd University of Petroleum and Minerals  
Dhahran, Saudi Arabia  
Email: muhaini@kfupm.edu.sa

**Abstract**—Load points are one of the most vital parts of power systems. Due to the new load forms and programs introduced in the demand side, the load serving entities (LSEs) no longer deal with lump loads, but rather with more dynamic, rational and price elastic loads. The high inter-temporal and behavioral variability of the load profile makes it almost impossible for utilities and system operators to expect the demand curve with the needed accuracy. A sound granularity of the load compositions and consumption percentages and patterns throughout the year is essential for avoiding energy losses, designing demand side management programs and ensuring proper adjustments of electricity rates. In this paper, a simplistic model that can be followed by system operators to initially understand the customers consumption pattern and the household load structure is proposed. A top-down approach is combined and matched with a detailed bottom-up one, to extract load compositions and percentages. Real and local load profiles integrated with household statistical data such as device time of use (ToU), number of device units per house and activities exercised in households are all included in the model. The main results of the paper show the load composition in residential demand and the percentage of such composition under seasonal-based scenarios.

**Index Terms**—Microgrids, controllable loads, demand-side management, load percentages, load composition, load modelling

## I. INTRODUCTION

FOR a long time, electric utilities dealt with price-inelastic customers as technologies enabling load deferral and distributed generation were not widely deployed. Nowadays, utilities are dealing with rational customers who optimize their consumption based on the announced prices. Under all circumstances, electric energy supply must always meet electric energy demand, and any unbalance in this equation may lead to brown-outs or more severely a blackout. LSEs worldwide are buying costly new generation whenever they speculate an increase in the demand during the peak hours, whereas this increase in demand can be easily addressed by understanding the load composition and applying data-driven DSM programs targeting the loads compositions with highest consumption percentages. The capricious load profile

is no longer unanalyzable with the recent developments in Advanced Metering Infrastructure (AMI).

System operators need to understand the load profile accurately before implementing demand side management (DSM) or imposing any time of use tariff on certain devices. Given a certain load profile, the controller must have information the components that contributed to this profile and the percentage of each load type (Fig. 1). Saudi Arabia has one of the fastest growing energy demand around the world with a population growth of 20% between the years 2004 to 2010 [2]. For power systems such as the one in Saudi Arabia, 52% of the energy sales come from the residential sector and thus system operators must understand the load composition properly in order to target specific home devices for energy conservation awareness or DSM programs.




Fig. 1. Average and peak annual load profile.

Researchers tried to acquire a satisfactorily accurate determination of the household load composition using different techniques. There are approximately three known load modelling approaches : 1) component-based 2) measurement-based 3) A combination of the preceding two approaches (hybrid model). A comprehensive review about load modeling is given in [3].

Component based load modelling is a bottom-up method that aggregates the load information based on the composition of each load type and the characteristic of each load component. The component-based method was extensively studied

This work was supported by the Deanship of Scientific Research (DSR) at King Fahd University of Petroleum and Minerals (KFUPM) through Project No. IN161043.

A variant of this work has been published in [1].

in the literature [4, 5, 6, 7, 8, 9]. For example, in [4], the authors used component-based load modelling to reduce the error between reactive design and the actual real value. Their model engages quantitative analysis and test of a cluster of loads on a real configuration of a substation.

The measurement-based method is more widely used in microgrids (MG) given that faster sampling and higher accuracy of data can be acquired from the distributed phasor measurement units (PMU). The measurement-based approach, heavily relies on the data acquisition devices that are mounted at different locations in the system. The advantage of this method is the real-time accurately acquired data that does not require any estimation or variation of variables and thus it performs well in dynamic simulations. In [10, 11, 12, 13, 14, 15, 16], measurement-based method was used at different voltage levels. In [10], the static and dynamic load model in grid-connected and islanded low-voltage (LV) MG was investigated. The model was developed and then tested in a laboratory scale MG. In [11], online measurement data from Taiwan power system was gathered to derive, test and compare between different dynamic load models. The conducted numerical studies in the paper concluded that linear dynamic load models outperforms the nonlinear dynamic models when it comes to reactive power behavior modeling during disturbances. [12] utilizes the measurement-based method to build up a complete load model at distribution level. The authors compared their model with a composite load model at transmission level and another model at generation level. They showed that their model performs better in transient conditions. References [13] and [15] applied measurement-based dynamic load modelling using curve-fitting technique and vector-fitting technique, respectively. [16], discusses residential MG scheduling by utilizing smart meters to come up with a temperature dependent thermal load model. Sensitivity analysis is implemented to reflect the impact of the uncertainties contained in the model. A hybrid model was applied in [17, 18, 19].

In [17], multiple data from single users is aggregated to generate the residential MG load profile. There are eight Major Electricity Consumption (MEC) events that when aggregated, a residential house load profile is acquired. The model parameters for each event are acquired using Ant Colony Optimization (ACO) algorithm. The load modeling method was then validated using a real MG in Ohio, USA. While in [18], a dynamic equivalent Active Distribution Network Cell (ADNC) model was presented and examined. The model allows for more penetration of unconventional energy sources such as PV and wind in the distribution network. The performance of the model was tested using the modified IEEE nine bus system during different levels of disturbances.

Although load modeling was appropriately studied in the literature, very few papers tackled exploring the load composition and percentages of real load data using simply the total load information and statistical data based on the location, ToU of the appliances, approximated number of units per house and load daily operation patterns. In this paper, a detailed load

modeling will be implemented on real and local residential loads data from Saudi Arabia. Firstly, a top-down approach will be utilized to acquire annual, monthly and daily load profiles. Then, a bottom-up approach will be modeled on the residential load sector to identify the composition of loads and consumption percentage of each appliance to the whole consumption in summer and winter.

In the following section the residential load structure and load composition modeling will be presented and the hybrid approach will be formulated and explained. The simplistic method to find load structures is discussed in section 3, and the results follow in section 4. Lastly, section 4 conclude the research with some remarks and outcomes of the study.

## II. RESIDENTIAL LOAD MODELING

The majority of energy sales in Saudi Arabia is attributed to residential costumers (Table I). As a result, it is essential to investigate the load composition and percentages of household costumers. Utilities carefully study the consumer behavior, which is mainly governed by the type of appliances, devices and machines the consumer is using. Each of these loads has a certain contribution to the residential load profile, which varies by seasons, weather, special events and prices. In order to conduct load controlling and hence demand-side management in a MG, a detailed identification of the load composition and its percentages must be determined.

The location of data used in this paper is the Eastern province in Saudi Arabia, which is the largest province by area (Fig. 2). The coordinates of the data location are 26.2361° N, 50.0393° E. The load data was acquired based on supervisory control and data acquisition (SCADA) measurements.

TABLE I  
ENERGY SALES IN SAUDI ARABIA PER CATEGORY [20]

Classification	Ratings	Energy Sales (GWh)	Energy sale (%)
Residential	0.4kV/0.22kV	143,055	49.6%
Commercial	0.4kV/0.22kV	48,252	16.72%
Industrial	13.8kV	47,230	16.4%
Governmental	0.4kV/0.22kV	38,422	13.3%
Others	13.8kV/0.4kV/0.22kV	11,698	4.1%




Fig. 2. Eastern province in Saudi Arabia indicated with a tick mark.

Using the measurement based method, which is a top-down approach, we acquire the residential annual and daily load profiles shown in Figs. 3 & 4. The residential daily load profile shows the peculiar habit of household consumption in Saudi Arabia, where the load peaks at around 3 P.M due to consumers coming out of work and schools. The consumption is minimum at 6 A.M that is when most customers are sleeping. Most of the manually operated loads (i.e., oven, vacuum cleaner, and TV) in this period are idle while the automatically and semi-automatically operated loads (i.e., refrigerator and air conditioner) are less affected by the factor of time.

The annual average and peak load profile are displayed in Fig. 3 & 4. All figures were scaled as per the following equation:

$$P_s(t) = \frac{P_l(t)}{P_{max}} \quad (1)$$

Where,  $\{P_s \in \mathbb{R}_+ \mid 0 < P_s < 1\}$ .  $P_{max} \in \mathbb{R}_+$  is the daily maximum power, and  $P_l(t) \in \mathbb{R}_+$  is the hourly load at hour  $t$ .

The annual load profile in Fig. 4 highlights the effect of seasons on the residential load profile, where it the consumption peaks in summer months starting from May to July and it less in winter months starting from October to February. The effect of weather resulted in an increase in electricity usage of more than 130% between February and June. It is observed that the average load is approximately 86% of the peak load in most months. The primary reason for this change is the air conditioning loads as will be investigated in the next section.




Fig. 3. Residential daily load profile.

### III. RESIDENTIAL LOAD STRUCTURE AND LOAD COMPOSITION

To apply demand side management, a precise specification of the load composition is essential in order to know the contribution percentage of every device to the overall load profile. In the previous section, the daily and annual load profiles were presented using a top-down approach. In this section, a bottom-up approach will be used and matched with the top-down approach.

Data acquired by the Saudi Arabian General Authority for Statistics (GAS) in 2016, shows the usage hours of different




Fig. 4. Residential annual load profile.

home appliances and devices per day [2] (Table II). We rely on this data for the bottom-up approach, where we back-project the consumption of each device/appliance to the top-down load profile to properly scale the percentage of consumption of each load activity.

Considering that the consumption of devices might be affected by the level of loading, we introduce two loading states, i.e., active and idle. The total energy consumption  $C$  (\$/kWh) of each load is given as:

$$C^s = \left( \omega_R^d \gamma_R^{d,s} + \omega_I^d \gamma_I^{d,s} \right) t^{d,s} \quad (2)$$

where  $s = \{0, 1\}$  is a set resembling winter and summer seasons, respectively. Winter months are assumed to be from October to February and the period from March to September is considered as summer.  $t \in \mathbb{Z}_+$  is the device daily time of use measured in hours.  $\omega_R, \omega_I \in \mathbb{R}_+$  are the wattage consumption in run-mode and idle-mode, respectively.  $\gamma_R^{d,s}$  and  $\gamma_I^{d,s}$  are the fractions of run-time and idle-time of device  $d$ , respectively, where  $d$  is a vector  $\vec{d} \in \mathbb{Z}_+^m$  s.t. for  $m > j > 0, d = \{d_j, d_{j+1}, \dots, d_m\}$ , where  $m$  is the total number of devices or appliances.  $\{\gamma_R, \gamma_I \in \mathbb{Q}_+\}$  is given such that:

$$\gamma_R + \gamma_I = 1 \quad (3)$$

Using the information in Table II, the following equation is applied to acquire the average energy consumed by every device:

$$\Psi^{d,s} = q^{d,s} C^s \quad (4)$$

$\Psi^{d,s}$  is the energy consumed by device  $d$  in season  $s$ . Lastly,  $\{q \in \mathbb{N}\}$  is the number of units of device  $d$  in a household.

### IV. RESULTS

After applying the collected data on our model in (4), the consumption of each load activity in summer and winter seasons is calculated (Table III). By matching the residential load profile in Fig.3, with the average energy consumed by every device using (4), the pie-charts in Fig. 5 and Fig. 6 are acquired. The pie-charts show the percentage share of each home activity during summer and winter months.

TABLE II  
HOUSEHOLD ACTIVITIES AND CALCULATION PARAMETERS

Activity	ToU (winter)	ToU (summer)	Number of units (winter)	Number of units (summer)	Rating (W)	Idle rating (W)	Operation	Run-time (%)	Idle-time (%)
Heating (oil-filled)	8	1.5	2	1	1500	0	Semi Auto	0.5	0.5
Air conditioning	3	10	2	5	1800	100	Semi Auto	0.6	0.4
Water heating	14	4.7	3	1	1500	30	Auto	0.3	0.7
Water coolers	10	17	1	1	250	10	Auto	0.5	0.5
Water Bump (Dynamo)	1.5	2.1	1	1	250	0	Auto	1	0
Washing & Drying	1.3	1.9	2	2	2000	0	Semi Auto	1	0
Ironing	1	1.8	1	1	1000	0	Manual	1	0
Vacuum cleaning	1	1.3	1	1	1000	0	Manual	1	0
Cooking	1.6	1.4	1	1	2150	0	Semi Auto	1	0
Electric kettle	1.3	2	1	1	1800	0	Manual	1	0
Lighting	7.3	7.5	50	50	10	0	Manual	1	0
Food preservation	24	24	2	2	100	0	Auto	1	0
TV	5.3	5.9	1	2	120	13	Manual	1	0
PC	2.1	2.6	2	2	150	7.5	Manual	1	0
Gaming devices	2.6	3	4	4	30	7.5	Manual	1	0

From Fig. 6, it is observed that Air-conditioning (AC) loads sums up to 62% of the total load in summer months. This finding is proven as SEC announced a similar percentage in their reports [21]. AC loads shrink to only 11% in winter as the temperature goes down, thus the heating loads rise, and we found that water and ambient heating constitutes to 50% of the monthly winter demand. As an indicator of the accuracy of the composition percentages, we observe that lighting in winter represented 6% of the profile, while it was 4% in summer. The reason is that at winter the evening time is longer and even the day time is cloudy sometimes; therefore, lighting usage in the winter is higher than summer. Other activities such as washing/drying, ironing, and cleaning have very similar consumption in both periods. It is worth mentioning that social behavior and psychological studies can also utilize these findings to investigate the home users patterns and the implication of seasons or holidays. These findings are the cornerstone of precise and successful application of Direct load control (DLC) by utilities, which in turn helps in maintaining grid and price stability, especially if the control is intelligent enough to be priority-based aware [22]

## V. CONCLUSION

In order to control the demand side, detailed knowledge of the load composition and the percentage of each load must be gained. The information about the load composition and

TABLE III  
SUMMER AND WINTER ENERGY CONSUMPTION PER ACTIVITY

Activity	Winter Energy Consumption (Wh/day)	Summer Energy Consumption (Wh/day)
Heating (oil-filled)	12000	1125
Air conditioning	6720	56000
Water heating	19782	2213.7
Water coolers	1300	2210
Water Bump (Dynamo)	375	525
Washing & Drying	5200	7600
Ironing	1000	1800
Vacuum cleaning	1000	1300
Cooking	3440	3010
Electric kettle	2340	3600
Lighting	3650	3750
Food preservation	4800	4800
TV	636	1416
PC	630	780
Gaming devices	312	360
Total (KWh/month)	1895.55	2714.69

percentages is highly correlated with time, season, weather and many other sociological and behavioural factors.

This paper presented a simplified approach for finding and understanding load compositions and percentage of each load type. A hybrid top-down and bottom-up approach was used. The top-down approach is represented by acquiring the data from SCADA systems on residential substation. Then the bottom-up approach maps the acquired load composition




Fig. 5. Percentage of household appliances in winter.




Fig. 6. Percentage of household appliances in summer.

with the load profile acquired from the top-down approach to obtain the household load composition and the corresponding percentages. The paper uses real and local load data from the eastern province in Saudi Arabia to apply the methodology and present the findings.

Using this simple model, the percentage and composition of the household in the region of study were both identified. The acquired data highly matches the anticipated and historical load composition and percentages.

## ACKNOWLEDGMENT

The authors would like to acknowledge the support provided by the Deanship of Scientific Research (DSR) at King Fahd University of Petroleum and Minerals (KFUPM) for funding this work through project No. IN161043.

## REFERENCES

- [1] A. S. Alahmed and M. M. Almuahini, "Hybrid top-down and bottom-up approach for residential load compositions and percentages," in *2021 Power System and Green Energy Conference (PSGEC)*, 2021, pp. 1–6. DOI: 10.1109/PSGEC51302.2021.9542219.
- [2] *Household energy survey 2017*. [Online]. Available: <https://www.stats.gov.sa/en>.
- [3] A. Arif, Z. Wang, J. Wang, B. Mather, H. Bashualdo, and D. Zhao, "Load modeling - a review," *IEEE Transactions on Smart Grid*, pp. 1–1, 2017. DOI: 10.1109/tsg.2017.2700436.
- [4] J. Lim, P. Ji, A. Ozdemir, and C. Singh, "Component-based load modeling including capacitor banks," *2001 Power Engineering Society Summer Meeting. Conference Proceedings (Cat. No.01CH37262)*, 2001. DOI: 10.1109/pess.2001.970235.
- [5] I. Dzafic, M. Glavic, and S. Tesnjak, "A component-based power system model-driven architecture," *IEEE Trans. Power Syst.*, vol. 19, no. 4, pp. 2109–2110, Nov. 2004.
- [6] D. Kosterev, A. Meklin, J. Undrill, B. Lesieutre, W. Price, D. Chassin, R. Bravo, and S. Yang, "Load modeling in power system studies: Wecc progress update," in *2008 IEEE Power and Energy Society General Meeting - Conversion and Delivery of Electrical Energy in the 21st Century*, 2008, pp. 1–8.
- [7] A. Gaikwad, P. Markham, and P. Pourbeik, "Implementation of the WECC Composite Load Model for utilities using the component-based modeling approach, in *Proc IEEE/pes Transmission and Distribution Conf*," pp. 1–5, 2016.
- [8] L. Zhu, X. Li, H. Ouyang, Y. Wang, W. Liu, and K. Shao, "Research on component-based approach load modeling based on energy management system and load control system," in *IEEE PES Innovative Smart Grid Technologies*, 2012, pp. 1–6.
- [9] T. Porsinger, P. Janik, Z. Leonowicz, and R. Gono, "Component modelling for microgrids," *2016 IEEE 16th International Conference on Environment and Electrical Engineering (EEEIC)*, 2016. DOI: 10.1109/eeeic.2016.7555869.
- [10] T. Papadopoulos, E. Tzanidakis, P. Papadopoulos, P. Crolla, G. Papagiannis, and G. Burt, "Aggregate load modeling in microgrids using online measurements," *MedPower 2014*, 2014. DOI: 10.1049/cp.2014.1665.

- [11] B.-K. Choi, H.-D. Chiang, Y. Li, H. Li, Y.-T. Chen, D.-H. Huang, and M. Lauby, "Measurement-based dynamic load models: Derivation, comparison, and validation," *IEEE Transactions on Power Systems*, vol. 21, no. 3, pp. 1276–1283, 2006. DOI: 10.1109/tpwrs.2006.876700.
- [12] J. Hou, Z. Xu, and Z. Y. Dong, "Measurement-based load modeling at distribution level with complete model structure," *2012 IEEE Power and Energy Society General Meeting*, 2012. DOI: 10.1109/pesgm.2012.6344939.
- [13] D. P. Stojanovic, L. M. Korunovic, and J. Milanovic, "Dynamic load modelling based on measurements in medium voltage distribution network," *Electric Power Systems Research*, vol. 78, no. 2, pp. 228–238, 2008. DOI: 10.1016/j.epsr.2007.02.003.
- [14] A. Maitra, A. Gaikwad, P. Zhang, M. Ingram, D. Mercado, and W. Woitt, "Using system disturbance measurement data to develop improved load models," *2006 IEEE PES Power Systems Conference and Exposition*, 2006. DOI: 10.1109/psce.2006.296230.
- [15] E. O. Kontis, T. A. Papadopoulos, A. I. Chrysochos, and G. K. Papagiannis, "Measurement-based dynamic load modeling using the vector fitting technique," *IEEE Transactions on Power Systems*, vol. 33, no. 1, pp. 338–351, 2018. DOI: 10.1109/tpwrs.2017.2697004.
- [16] M. Tasdighi, H. Ghasemi, and A. Rahimi-Kian, "Residential microgrid scheduling based on smart meters data and temperature dependent thermal load modeling," *IEEE Transactions on Smart Grid*, vol. 5, no. 1, pp. 349–357, 2014. DOI: 10.1109/tsg.2013.2261829.
- [17] H. Li, C. Yao, J. Wang, L. Zhu, and S. Yang, "Events identification based load modeling for residential microgrid," *2015 IEEE Energy Conversion Congress and Exposition (ECCE)*, 2015. DOI: 10.1109/ecce.2015.7310144.
- [18] J. V. Milanovic and S. M. Zali, "Validation of equivalent dynamic model of active distribution network cell," *IEEE Transactions on Power Systems*, vol. 28, no. 3, pp. 2101–2110, 2013. DOI: 10.1109/tpwrs.2012.2227844.
- [19] V. V. S. Chakrabarti, and S. Srivastava, "Classification and modelling of loads in power systems using svm and optimization approach," *2015 IEEE Power & Energy Society General Meeting*, 2015. DOI: 10.1109/pesgm.2015.7285917.
- [20] *Customers and energy sales*. [Online]. Available: <https://www.ecra.gov.sa/en-us/DataAndStatistics/NationalRecord/SubscriberNumbersAndEnergySold/Pages/Chart.aspx?frm=SE&C=2&Cmp=0&YF=2015&YT=2018&T=0&CompId=1&ClassificationIndex=1>.
- [21] [Online]. Available: <https://www.se.com.sa/en-us/Pages/home.aspx>.
- [22] A. S. Alahmed and M. M. Al-Muhaini, "An intelligent load priority list-based integrated energy management system in microgrids," *Electric Power Systems Research*, vol. 185, p. 106404, 2020, ISSN: 0378-7796.

DOI: <https://doi.org/10.1016/j.epsr.2020.106404>.  
 [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0378779620302108>.