

DeepOPF-AL: Augmented Learning for Solving AC-OPF Problems with Multiple Load-Solution Mappings

Xiang Pan, Wanjun Huang, Minghua Chen, and Steven H. Low

Abstract—The existence of multiple load-solution mappings of non-convex AC-OPF problems poses a fundamental challenge to deep neural network (DNN) schemes. As the training dataset may contain a mixture of data points corresponding to different load-solution mappings, the DNN can fail to learn a legitimate mapping and generate inferior solutions. We propose **DeepOPF-AL** as an *augmented-learning* approach to tackle this issue. The idea is to train a DNN to learn a *unique* mapping from an augmented input, i.e., (load, initial point), to the solution generated by an iterative OPF solver with the load and initial point as intake. We then apply the learned augmented mapping to solve AC-OPF problems much faster than conventional solvers. Simulation results over IEEE test cases show that **DeepOPF-AL** achieves noticeably better optimality and similar feasibility and speedup performance, as compared to a recent DNN scheme, with the same DNN size yet elevated training complexity.

Index Terms—optimal power flow; augmented learning

I. INTRODUCTION

Machine learning has recently been employed to solve optimal power flow (OPF) problems efficiently. By applying supervised learning techniques and using prepared (load, optimal solution) data, [1], [2] indicate deep neural network (DNN) could reduce the computation time of the conventional method by determining active constraints upon the given load. The studies in [3] and later in [4]–[6] train DNN for solving OPF problems by learning the high-dimensional load-solution mapping, which could directly generate feasible and close-to-optimal solutions much faster than conventional solvers.

While existing works suggest the potential of DNN in solving AC-OPF problems, the presence of multiple load-solution mappings poses a fundamental challenge to the supervised learning-based schemes. As the non-convex AC-OPF problem may admit multiple optimal solutions for a load input [7], the training dataset may contain “mixed” data points, i.e., the solutions to different load inputs correspond to different mappings, making the learning task inherently difficult. Consequently, the trained DNN can fail to learn a legitimate mapping (one of the multiple target mappings) and generate inferior solutions [8]. See Fig. 1 for an illustrating example. Since the solutions to a load from different mappings can derive similar objective values or exhibit similar solution structures (e.g., both solutions have “high-voltage” solutions on the same buses and “low-voltage” solutions on the remaining buses), it is non-trivial to differentiate them from each other. Consequently, intuitive methods such as selecting the least-cost and “high-voltage” solution for each load may fail to address the issue.

There exist two approaches to tackle the challenge. One is to prepare the training dataset so that it contains data points from only one mapping [8]. The other is to apply unsupervised learning to train DNN without labeling data points [9]. Yet, their limitations lie in (i) substantial computational complexity in preparing training data and in unsupervised learning and (ii) no guarantee to learn a legitimate mapping for AC-OPF problems with multiple load-solution correspondences.

In this paper, we propose **DeepOPF-AL** as an augmented learning approach to learn a *unique* mapping from an augmented load input to the corresponding solution, and then use it to solve AC-OPF problems. Our contribution is two-fold. First, after presenting a simple example showing AC-OPF problems can indeed admit multiple load-solution mappings, we develop **DeepOPF-AL** following a particular augmented-learning design. Specifically, we train a DNN to learn the mapping from (load, initial point) to the unique OPF solution generated by the Newton-Raphson method with the load and initial point as intake¹. Second, simulation results on IEEE test cases show that **DeepOPF-AL** achieves better AC-OPF optimality and similar feasibility and speedup performance, as compared to a recent scheme [4], with the same DNN size yet elevated training complexity. Simulation results also show robust performance of **DeepOPF-AL**.

II. AC-OPF AND MULTIPLE LOAD-SOLUTION MAPPINGS

The standard AC-OPF problem is formulated as

$$\min \sum_{i \in \mathcal{N}} C_i(P_{Gi}) \quad (1)$$

$$\text{s.t.} \sum_{(i,j) \in \mathcal{E}} \text{Re} \{V_i (V_i^* - V_j^*) y_{ij}^*\} = P_{Gi} - P_{Di}, i \in \mathcal{N}, \quad (2)$$

$$\sum_{(i,j) \in \mathcal{E}} \text{Im} \{V_i (V_i^* - V_j^*) y_{ij}^*\} = Q_{Gi} - Q_{Di}, i \in \mathcal{N}, \quad (3)$$

$$P_{Gi}^{\min} \leq P_{Gi} \leq P_{Gi}^{\max}, i \in \mathcal{N}, \quad (4)$$

$$Q_{Gi}^{\min} \leq Q_{Gi} \leq Q_{Gi}^{\max}, i \in \mathcal{N}, \quad (5)$$

$$V_i^{\min} \leq |V_i| \leq V_i^{\max}, i \in \mathcal{N}, \quad (6)$$

$$|V_i (V_i^* - V_j^*) y_{ij}^*| \leq S_{ij}^{\max}, (i,j) \in \mathcal{E}, \quad (7)$$

$$\text{var. } P_{Gi}, Q_{Gi}, V_i, i \in \mathcal{N}.$$

$\text{Re}\{z\}$, $\text{Im}\{z\}$, z^* , and $|z|$ denote the real part, the imaginary part, the conjugate, and the magnitude of a complex variable z , respectively. \mathcal{N} and \mathcal{E} denote the set of buses and the set of edges, respectively. P_{Gi} (resp. Q_{Gi}) and P_{Di} (resp. Q_{Di}) denote the active (resp. reactive) power generation and active (resp. reactive) load on bus i , respectively. V_i represents complex voltage, including the magnitude $|V_i|$ and the phase

X. Pan and W. Huang are with The Chinese University of Hong Kong. M. Chen is with City University of Hong Kong. S. Low is with California Institute of Technology. Corresponding author: Minghua Chen.

¹We note that **DeepOPF-AL** is different from the approach in [10] in that it directly outputs the solution in one pass while the latter is an iterative scheme that replaces the update function in the Newton-Raphson method by a DNN.




Fig. 1: (a) A 2-bus power network with $|V_1| = 0.9$ p.u., $\theta_1 = 0$, $r = 0$ p.u., $x = 0.25$ p.u., and $P_D = 343$ MW. (b) The AC-OPF problem in (1)-(6) over the 2-bus network has two legitimate mappings from the load Q_D to $|V_2^*|$ in the optimal solution. A DNN trained with data uniformly sampled from all possible $(Q_D, |V_2^*|)$ pairs and using ℓ_2 distance as the loss function fails to learn any of the two mappings.

angle θ_i , on bus i . y_{ij} and S_{ij}^{\max} denote the admittance and the branch flow limit of the branch $(i, j) \in \mathcal{E}$, respectively. (2) and (3) represent power-flow balance equations. (4) and (5) represent the active and reactive generation limits. (6) represents the voltage magnitude limit, and (7) represents the branch flows limits. The objective is to minimize the total cost of active power generation, where $C_i(\cdot)$ is the quadratic cost function of the generator at bus i . We set $C_i(P_{Gi}) = 0$ and $P_{Gi}^{\min} = P_{Gi}^{\max} = Q_{Gi}^{\min} = Q_{Gi}^{\max} = 0$ if bus i has no generator. As shown in Fig. 1, existing learning-based schemes fail to learn either of two legitimate mappings.

III. DEEPOPF-AL: SOLVING AC-OPF PROBLEMS BY LEARNING UNIQUE AUGMENTED MAPPING

The schematic of the proposed DeepOPF-AL is shown in Fig. 2. It follows a particular augmented-learning design to train a DNN to learn the mapping from (load, initial point) to the unique AC-OPF solution generated by the Newton-Raphson method with the load and initial point as intake. We build the DNN model on the multi-layer feed-forward neural network structure with ReLU as the activation function of hidden layers. We design the loss function as the total mean square error between the generated solution and the ground truth (the generated AC-OPF solution). We apply the popular Adam algorithm to update the DNN's parameters in training. DeepOPF-AL uses the trained DNN to predict the bus voltages and reconstructs the bus injections, i.e., RHS values of (2)-(3), and finally the generations, all by simple scalar calculation. Such a predict-and-reconstruct framework [3], [4], [11] guarantees the power-flow equality constraints and reduces the number of variables to predict. Lastly, DeepOPF-AL employs the post-processing process in [4] to help keep the obtained solution within the box constraints in (4)-(6).

We now explain the *unique* augmented mapping learned by DeepOPF-AL. Denote $\mathcal{L}(\mathbf{Z})$ as the Lagrangian of the AC-OPF problem in (1)-(7), where \mathbf{Z} is the concatenation of the primal variables, the dual variables, the slack variables, and the load input (denoted as \mathbf{D}). Let \mathbf{Z}_0 and \mathbf{Z}_t denote the initial values of \mathbf{Z} , and the updated ones by the Newton-Raphson method after the t -th iteration, respectively. Similarly, let $\mathbf{X}_0 := (P_{Gi}^{\text{init}}, Q_{Gi}^{\text{init}}, V_i^{\text{init}}, i \in \mathcal{N})$ and \mathbf{X}_t denote the




Fig. 2: Illustration of the DeepOPF-AL approach. Given a load input and an initial point, we employ a DNN model to predict the bus voltages and reconstruct the remaining bus injection and generation solutions by simple scalar computations using power flow equations.

initial conditions for the primal variables and the updated ones after the t -th iteration, respectively. Recall that the Newton-Raphson method works as follows: for the t -th iteration, it first computes the gradient and Hessian of the Lagrangian with respect to \mathbf{Z}_t , i.e., $\nabla \mathcal{L}(\mathbf{Z}_t)$ and $\nabla^2 \mathcal{L}(\mathbf{Z}_t)$. It then computes the update step for \mathbf{Z}_t as $\Delta \mathbf{Z}_t = -\nabla \mathcal{L}(\mathbf{Z}_t) \cdot (\nabla^2 \mathcal{L}(\mathbf{Z}_t))^{-1}$. It extracts $\Delta \mathbf{X}_t$ from $\Delta \mathbf{Z}_t$ and generates $\mathbf{X}_{t+1} = \mathbf{X}_t + \alpha_t \Delta \mathbf{X}_t$ with a pre-determined step-size α_t . Hence, given \mathbf{X}_0 and \mathbf{D} , \mathbf{X}_1 and all follow-up \mathbf{X}_t s are uniquely determined. Finally, the iterations terminate when pre-specified termination criteria are satisfied. Both the total number of iterations and final solution are unique for given initial point \mathbf{X}_0 and load \mathbf{D} . Overall, we observe a unique mapping from $(\mathbf{X}_0, \mathbf{D})$ to the corresponding final solution, described as $\mathbf{X}_{\text{NR}}(\mathbf{X}_0, \mathbf{D}) = \psi_{\text{NR}}(\mathbf{X}_0, \mathbf{D})$. DeepOPF-AL aims to learn this unique mapping $\psi_{\text{NR}}(\cdot)$.

Discussion: (i) DeepOPF-AL can learn the augmented mapping of any deterministic iterative algorithm. We choose to learn that of the popular Newton-Raphson method. For a load input, one can run several DeepOPF-AL in parallel with different initial points and output the least-cost solution. (ii) DeepOPF-AL learns a unique augmented mapping, but requiring a larger DNN and more training data than learning a standard load-solution one, as observed in Sec. IV. (iii) As we will also see in Sec. IV, for the set of (load, initial point) inputs for which the Newton-Raphson method fails to converge, DeepOPF-AL can still generate solutions with decent optimality performance. This indicates better practicability of DNN schemes over iterative solvers, in addition to speedup.

IV. NUMERICAL EXPERIMENTS

We conduct simulations in CentOS 7.6 with quad-core (i7-3770@3.40G Hz) CPU and 16GB RAM. We compare performance of DeepOPF-AL and a recent scheme DeepOPF-V [4] on IEEE 39-/300-bus systems. We generate realistic load on each bus by multiplying the default value by an interpolated demand curve based on 11-hour California's net load in Jul. – Sept. 2021, with a time granularity of 30 seconds thus 2,760 load instances per day. For each load, we randomly generate initial points and fed them together with the loads into the Matpower Interior Point Solver (MIPS) solver [12], which implements the Newton-Raphson method, to obtain reference AC-OPF solutions. Our DNN models consist of 3 hidden layers with 1024/768/512 neurons for the 39-bus system and 4 hidden layers with 1024/768/512/256 neurons for the 300-bus system. We set the batch size, maximum epoch, and learning rate to be 50, 4000, and $1e-4$, respectively.

TABLE I: Simulation results for the IEEE 39-bus system.

Metric	Balanced Dataset		Unbalanced Dataset	
	DeepOPF-AL	DeepOPF-V	DeepOPF-AL	DeepOPF-V
$\eta_{opt}(\%)$	0.48	-8.56	0.66	-5.98
$\eta_{P_G}(\%)$	97.5	99.3	97.4	99.8
$\eta_{Q_G}(\%)$	94.6	91.7	98.4	96.7
$\eta_{S_l}(\%)$	99.9	100	99.9	100
$\eta_{P_D}(\%)$	0.19	0.61	0.09	0.32
$\eta_{Q_D}(\%)$	6.47	27.6	0.49	12.9
$t_{mips}(\text{ms})$	1621	1621	1987	1987
$t_{dnn}(\text{ms})$	1.4	1.3	1.3	1.2
η_{sp}	$\times 1157$	$\times 1247$	$\times 1528$	$\times 1655$

TABLE II: Simulation results for the IEEE 300-bus system.

Metric	Convergent Dataset		Non-convergent Dataset	
	DeepOPF-AL	DeepOPF-V	DeepOPF-AL	MIPS
$\eta_{opt}(\%)$	0.01	-0.01	-0.13	20.4
$\eta_{P_G}(\%)$	100	100	99.9	23.2
$\eta_{Q_G}(\%)$	100	100	100	78.3
$\eta_{S_l}(\%)$	100	100	100	80.7
$\eta_{P_D}(\%)$	0.0	-0.01	-0.1	-73.4
$\eta_{Q_D}(\%)$	0.02	0.02	-0.02	-109.2
$t_{mips}(\text{ms})$	2978	2978	-	-
$t_{dnn}(\text{ms})$	2.2	1.8	2.2	-
η_{sp}	$\times 1353$	$\times 1654$	-	-

Performance metrics: (i) the relative optimality difference, i.e., η_{opt} , between the objective values obtained by DeepOPF-AL and MIPS; (ii) the average running times of the MIPS solver, i.e., t_{mips} , the DNN schemes, i.e., t_{dnn} , and the corresponding average speedup ratios, i.e., η_{sp} ; (iii) the average constraint satisfaction percentages for active/reactive generation and branch flow limit, i.e., η_{P_G} , η_{Q_G} , and η_{S_l} , respectively; (iv) the average load-serving mismatch percentage of active and reactive loads, i.e., η_{P_D} and η_{Q_D} , respectively.

The case with multiple load-solution mappings: We evaluate the performance of DeepOPF-AL and DeepOPF-V with the same DNN size and training/testing data (for fair comparisons) on an IEEE 39-bus system having two load-solution mappings with on average 30% difference in objective values [7]. We design two datasets: balanced dataset (with 89,972 data points; for each load, the ratio between the numbers of two solutions is 1:1) and unbalanced dataset (with 52,384 data points; for each load, the ratio between the numbers of the low-cost solutions and the high-cost solutions are 9:1). We split each dataset with the “80/20” strategy to obtain the training set and test set, respectively. The results are shown in Table I. As seen, DeepOPF-AL outperforms DeepOPF-V in both datasets and achieves smaller optimality gap and similar constraint and load satisfaction percentages. DeepOPF-AL performs more consistently than DeepOPF-V over the two datasets, demonstrating its effectiveness in solving AC-OPF problems with multiple load-solution mappings.

The case with unique load-solution mapping and robust performance: We evaluate the performance of DeepOPF-AL and DeepOPF-V on the IEEE 300-bus test system, which we observe has a unique load-solution mapping. We use the same size DNN but different size dataset, following the “80/20” training/testing splitting rule. The training set for DeepOPF-V contains 2,760 (load, solution) data pairs. The training set for DeepOPF-AL has 110,400 ((load, initial point), solution) data

points, where we randomly sample 40 initial points for each load. The results in Table II show that DeepOPF-AL achieves similar optimality gap, feasibility, and speedup performance, as compared to DeepOPF-V. These results confirm that, for this setting with a unique load-solution mapping, the (higher-dimensional) augmented mapping to learn by DeepOPF-AL is degenerated and can be represented using the same-size DNN as the (lower-dimensional) load-solution one to learn by DeepOPF-V. Meanwhile, the augmented mapping still requires more data to train, if one has no prior knowledge of its degenerated dimension, as in this simulation.

We also test DeepOPF-AL using 2760×20 (load, initial point) data for which the MIPS solver fails to converge. We observe in Table II that it still attains decent performance, while the non-convergent solutions by the MIPS solver suffer from significant performance degradation. This implies that DeepOPF-AL, while trained with data generated by the MIPS solver, achieves more robust performance than the solver.

V. CONCLUDING REMARK

We propose DeepOPF-AL as the first learning-based approach that guarantees to learn a unique augmented mapping for solving AC-OPF problems that potentially admit multiple load-solution correspondences. Simulation results show that it achieves a smaller optimality gap and similar feasibility and speedup performances compared to a recent DNN scheme, with elevated training complexity. A future direction is to improve augmented-learning designs for better training efficiency for solving AC-OPF and other non-convex problems.

REFERENCES

- [1] Y. Ng, S. Misra, L. A. Roald, and S. Backhaus, “Statistical learning for DC optimal power flow,” in *Proc. of IEEE PSCC*, 2018.
- [2] L. Zhang, Y. Chen, and B. Zhang, “A convex neural network solver for dcopf with generalization guarantees,” *IEEE Trans. Control. Netw. Syst.*, *Early Access*, 2021.
- [3] X. Pan, T. Zhao, and M. Chen, “DeepOPF: Deep Neural Network for DC Optimal Power Flow,” in *Proc. IEEE SmartGridComm*, Beijing, China, Oct. 2019, available on arXiv in May 2019 (arXiv:1905.04479v1).
- [4] W. Huang, X. Pan, M. Chen, and S. H. Low, “Deepopf-v: Solving acopf problems efficiently,” *IEEE Trans. Power Syst.*, vol. 37, no. 1, pp. 800–803, 2021.
- [5] F. Fioretto, T. W. Mak, and P. Van Hentenryck, “Predicting ac optimal power flows: Combining deep learning and lagrangian dual methods,” in *Proc. AAAI*, vol. 34, no. 01, 2020, pp. 630–637.
- [6] A. S. Zamzam and K. Baker, “Learning optimal solutions for extremely fast AC optimal power flow,” in *Proc. IEEE SmartGridComm*, 2020.
- [7] W. A. Bukhsh, A. Grothey, K. I. McKinnon, and P. A. Trodden, “Local solutions of the optimal power flow problem,” *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 4780–4788, 2013.
- [8] J. Kotary, F. Fioretto, and P. Van Hentenryck, “Learning hard optimization problems: A data generation perspective,” *arXiv preprint arXiv:2106.02601*, 2021.
- [9] W. Huang and M. Chen, “DeepOPF-NGT: A Fast Unsupervised Learning Approach for Solving AC-OPF Problems without Ground Truth,” in *ICML Workshop on Tackling Climate Change with Learning*, 2021.
- [10] K. Baker, “A Learning-boosted Quasi-Newton Method for AC Optimal Power Flow,” *arXiv preprint arXiv:2007.06074*, 2020.
- [11] X. Pan, T. Zhao, M. Chen, and S. Zhang, “DeepOPF: A Deep Neural Network Approach for Security-Constrained DC Optimal Power Flow,” *IEEE Trans. Power Syst.*, vol. 36, no. 3, pp. 1725–1735, May 2021.
- [12] R. D. Zimmerman, C. E. Murillo-Sánchez, R. J. Thomas *et al.*, “MATPOWER: Steady-state operations, planning, and analysis tools for power systems research and education,” *IEEE Trans. Power Syst.*, vol. 26, no. 1, pp. 12–19, Feb. 2011.