

Investigating the Cybersecurity of Smart Grids Based on Cyber-Physical Twin Approach

Ömer Sen*, Florian Schmidtke*, Federico Carere[†], Francesca Santori[†], Andreas Ulbig*, Antonello Monti[‡]

^{*}IAEW, RWTH Aachen University, Aachen, Germany

Email: {o.sen, f.schmidtke, a.ulbig}@iaew.rwth-aachen.de

[†]ASM Terni S.p.A. Terni, Italy

Email: {federico.carere, francesca.santori}@asmterni.it

[‡]ACS, RWTH Aachen University, Aachen, Germany

Email: amonti@eonerc.rwth-aachen.de

Abstract—While the increasing penetration of information and communication technology into distribution grid brings numerous benefits, it also opens up a new threat landscape, particularly through cyberattacks. To provide a basis for countermeasures against such threats, this paper addresses the investigation of the impact and manifestations of cyberattacks on smart grids by replicating the power grid in a secure, isolated, and controlled laboratory environment as a cyber-physical twin. Currently, detecting intrusions by unauthorized third parties into the central monitoring and control system of grid operators, especially attacks within the grid perimeter, is a major challenge. The development and validation of methods to detect and prevent coordinated and timed attacks on electric power systems depends not only on the availability and quality of data from such attack scenarios, but also on suitable realistic investigation environments. However, to create a comprehensive investigation environment, a realistic representation of the study object is required to thoroughly investigate critical cyberattacks on grid operations and evaluate their impact on the power grid using real data. In this paper, we demonstrate our cyber-physical twin approach using a microgrid in the context of a cyberattack case study.

Index Terms—Cyber-Physical System, Smart Grid, Cyber attacks, Cyber Security, Digital Twin

I. INTRODUCTION

The increasing penetration of information and communication technology (ICT) in the power grid [1] is leading to new opportunities for active grid operation, especially at the distribution grid levels that form the backbone for smart grid (SG) operation [2]. However, this increasing interconnection of systems and actors is leading to the emergence of threats [3] and thus a new threat landscape composed of cyberattacks that threaten the stable and reliable state of the grid [4]. To adequately address these new threats, mitigation and countermeasures must be integrated as an essential part of the grid infrastructure, consisting not only of preventive but also reactive measures [5]. One challenge in integrating countermeasures in the form of security concepts, especially new and active mitigation measures, is evaluating their effectiveness and their own impact on the grid [6]. This requires testing and validation of these measures in these systems by replicating attack

scenarios, which is often not feasible in productive operated grids [7]. In addition, the development and validation of these measures, in particular data-driven approaches, requires attack data that often cannot be accessed [8]. Alternatively, attack data could be generated synthetically, but approaches in this area are still under research and require further validation [9]. Another approach to this issue might be to generate attack data on the basis of replicas of the grid, such as Digital Twins (DTs), that enable security investigations [10].

To provide a basis for studying the cybersecurity of the power grid by enabling the generation of attack data, a feasible approach is needed without compromising the grid itself. The challenges we seek to address in this paper are therefore the following:

- (i) The replication of the grid including all layers of interest such as communication layer, process field and control layer in a safe and controlled environment.
- (ii) The execution of realistic attack scenarios without affecting the reference grid itself, thus avoiding harmful repercussions on the grid.
- (iii) The generation of attack data during the attack experiment, including process and communication data.

Therefore, in this paper, we propose a Cyber-Physical Twin (CPT) approach that enables the investigation of power grid cybersecurity without compromising grid security. This allows the generation of attack data through cyberattack replications in SG. To this end, we present an approach built on a co-simulation framework integrated into a laboratory environment with the ability to replicate SG in its process and ICT layers, and demonstrate it using a real microgrid. In particular, our contributions in this paper are:

- 1) We present the current state of the art in the DT based test and investigation environment and highlight the problem of attack data generation (Section II).
- 2) We describe the overall CPT approach, which consists of the co-simulation framework, the laboratory environment, and the reference grid (Section III).
- 3) We demonstrate and discuss the cybersecurity investigation capabilities of our proposed approach through a case study of cyberattack (Section IV).

II. APPLICATION OF DIGITAL TWINS

In this section, we present the state of the art in DT approaches based on the use case of cybersecurity analysis. In particular, Section II-A presents different research directions of DT in SG, while Section II-B presents cybersecurity-oriented testbed approaches, and Section II-C highlights current problems in attack data generation.

A. Digital Twins in Smart Grid

In the context of this work, we understand the term DT to describe a system that replicates a physical target system through continuous model-based simulation of the physical target system's functionalities [11]. This requires an exchange of data between the DT and the physical target system, based on which the physical state of the system and its composition can be determined and updated. The capabilities of the DT can therefore be used to predict, control, and optimize the functionalities of the target physical system, while also interacting in the form of feedback to adapt to environmental changes.

Several use cases are being pursued with the DT approaches, in particular the work of Olivares et al. [12] presents a DT in advanced metering infrastructures within home area networks consisting of smart meters and Internet-of-Things (IoT)-devices. Their approach includes a DT framework controller that is responsible for orchestrating and coordinating physical state variables with the virtualized components that represent their physical counterparts. The authors demonstrate their DT approach by examining specific attack vectors to be detected by the DT model.

In light of the increasing integration of IoT-devices and the associated lifecycle management challenges, the work by Atalay et al. [7] presents a DT-based approach to SG lifecycle security assessment. Their approach includes threat modeling-based security assessment, where the DT represents the target system and attack simulation tools are used in conjunction with risk assessment analysis to examine the level of security. However, this work was presented only on a conceptual basis.

The work by et al. [13] presents a DT designed with the goal of achieving high performance through the use of virtual machines and Docker containers. They test the setup in real industrial control systems. Furthermore, the twin replicates the target system's communication stack to enable seamless integration of existing security approaches, which use data-centric analysis methods, for benchmark testing. In particular, the authors demonstrate their approach in a case study representing a zone consisting of multiple smart homes where a Man-in-the-Middle (MITM) attack is carried out.

B. Cybersecurity Analysis

A particular use case that we are pursuing in this work is the investigation of cybersecurity of critical infrastructures such as power grids in a secure and controlled environment. In this area, several research works have been conducted to investigate the security state of power grids using cyber-physical system (CPS) testbeds.

The work of Oyewumi et al. [14] presents a testbed for real-time experimental research aimed at investigating and monitoring the impact of potential cyberattacks and evaluating the performance of new cybersecurity solutions for SG. Based on Supervisory Control and Data Acquisition (SCADA) systems, the testbed uses real-time simulation of the power grid as well as remote human monitoring and control of substations and a TCP/IP stack for communication protocols. The lab environment is designed to provide a secure and closed environment that facilitates forensic investigations, penetration testing, and experimental analysis to secure critical infrastructure.

The work by Noorizadeh et al. [15] presents a hybrid testbed for industrial control systems implemented by real-time simulation of the Tennessee-Eastman process as the physical component of the testbed is combined with emulation of field devices. In their work, they address the challenge of obtaining hard-to-access field data by generating and logging the data from the physical part of the proposed testbed. The authors emphasize the security investigation of the physical grid reference, especially based on the PROFINET protocol that was attacked by a MITM scenario where real-time data injection was performed.

With respect to a combined environment consisting of a testbed and a co-simulation framework, the work by Hammad et al. [16] presents an offline co-simulation approach for CPS power systems. In particular, the authors pursue an offline co-simulation approach in which the time step of one or multiple simulation software is longer than that of the physical system being simulated to provide a more accessible SG testbed. The corresponding simulation components integrated using a discrete-event scheduler are the energy simulator PSCAD and the open-source communication simulator OMNeT++.

C. Problem Analysis

When analysing the cybersecurity of power grids, many problems and challenges must be considered. In particular, the problem of missing and insufficient attack data in the critical infrastructure domain poses a challenge for the validation and testing of security concepts. Many of the related works propose a DT or a CPS testbed to replicate the target physical system and perform the security investigation without compromising the real grid reference. However, some of these approaches integrate simulations, virtualized components, and simplified communication interaction models into their investigation environment, which can potentially affect the quality of the output data. Considering a fully physical operated testbed is, however, not feasible due to the costly and inefficient scaling factor. Moreover, it is often not flexible enough to fit diverse use case scenarios. Therefore, a hybrid approach, where certain grid segments of interest are fully replicated in a physical environment while the remaining grid segments are virtualized, may provide a suitable trade-off between data quality and flexibility. This could be, in particular, a flexible constellation of hardware-in-the-loop (HITL) simulation of selected grid segments enabled by coupled simulators to simulate environmental effects by segments not considered in the

physical laboratory. Moreover, attack scenarios with real attack vectors can be fully emulated within the physically replicated segments, avoiding the use of simplifications and assumptions, thus improving overall data quality. Consequently, in this paper, we take a hybrid approach between CPS testbed and DT in the form of a CPT, on which basis we perform security analysis within cyberattack case study fully emulated in the environment.

III. CYBER-PHYSICAL TWIN APPROACH

In this section we introduce our CPT approach. First, we provide in Section III-A a general overview about the approach and the architecture. Second, we describe in Section III-B the real-world grid segment and the laboratory environment we use for the CPT in Section III-C. Finally, we present in Section III-D the HITL Simulation used for the control of our laboratory.

A. Approach Overview

Figure 1 illustrates the overview of our CPT approach. The CPT in our laboratory environment is a replica of a real grid segment in Italy. The key characteristics of the real-world topology and assets are replicated in the encapsulated environment. Using multiple measurements of the grid segment, we can control loads and generators to emulate the real-world grid utilisation. We implement management algorithms for controllable assets like battery storage systems (BSSs) based on the residual load measured in the laboratory grid. Therefore, we are able to test those algorithms independently of the real-world situation and without effecting the normal operation in Italy. On this basis, we are also able to carry out cyberattacks on the ICT. This allows us to carry out a realistic cyberattack without affecting normal operations in the respective grid segment.

B. Grid Reference

The grid segment for which we are creating the CPT is located in Terni, Italy, at the headquarters of the local multi-utility operator ASM. The initial grid consists of two secondary substations with two sub-grids. There is one cross branch connecting the underlying parts of the substations. The grid segment consists of two large-scale photovoltaic (PV) systems. Besides the normal loads, two charging points for electric vehicles exist - one fast-charging-station and one with a power of 22 kW. Also, one BSS exists in the grid segment.

There are seven measurement points to monitor characteristic values like power, voltage, and, frequency. Each measurement device uploads the measurements via MQTT broker. Therefore, our CPT performs power flow analysis and management algorithm replication based on these measurements.

C. Laboratory Environment

In this section, we describe the structure of our laboratory environment as the core of our CPT approach. Due to physical constraints, it is not feasible to replicate the exact structure of the grid segment in our lab. Therefore, we must create




Fig. 1. Overview of the CPT approach consisting of the co-simulation framework and the SG lab.

a suitable grid structure, taking into account the available resources, first.

Our laboratory environment consists of multiple PV inverters with maximum power in the range of 10 kW to 36 kW, multiple loads with a maximum power of 20 kW and 45 kW and a BSS inverter with rated power of 15 kW. In addition to those end-user devices, a secondary substation with a rated power of 630 kVA is also part of our lab. Given the physical limitations of scalability, the measured values of the grid segment are scaled down.

We can create various grid topologies using multiple low-voltage cables and distribution boxes. Figure 2 illustrates in a simplified view the topology we created in our laboratory environment. There are two branches connected to the secondary substation. The PV inverter with a rated power of 36 kW is connected to the left branch. To ensure controllable generation profiles, the inverters are connected to controllable DC power supplies. The BSS inverter (15 kW / 22 kWh) and a load bank (20 kW) are connected to the right branch. To monitor the power flow in our laboratory grid, we install *Janitza* power analysers at the inverters grid crossing points and the low voltage level of the transformer. In addition, we also install network taps to capture the communication traffic.

Besides the electrical connection, we also construct an ICT infrastructure. We connect the end-user devices via their Ethernet interfaces over a replicated process network to an Energy Management System (EMS). It communicates with the assets using the Modbus TCP protocol. The EMS logic is embedded in the framework implemented for the HITL simulation.

The CPT is not an exact duplicate of the real-world grid topology and ICT. Due to limited information about the




Fig. 2. Grid topology of the CPT in our SG laboratory.

detailed grid topology and limited asset resources in our laboratory we can replicate only a similar infrastructure. Nevertheless, it is possible to scale down the system to appropriate power limits and replicate the measured power for generators and consumers. Therefore, we can replicate the general behaviour of the real-world system by our CPT with sufficient accuracy for our case of investigation.

D. HITL Simulation

For the time-dependent control of our laboratory, we implemented a HITL simulation environment. This environment is implemented as *co-simulation* environment [17]. It allows time-discrete simulation steps. Part of the co-simulation environment are various simulators. A central scheduler handles the connections between these simulators and manages the exchange of information at each time instance. The advantage of the proposed approach is the modular design and the flexible scheduling process. For this reason, simulated components and real world assets flexibly can be connected and analysed. The depth of detail can vary for different investigation scenarios depending on evaluated part of the system. E.g. the communication part can be simulated only with the relevant exchange of information or communication adapters can be used for protocol conform communication.

The *co-simulation* framework allows connecting various simulators and organizes the time scheduling process and data management. Figure 3 shows the schematic connection of simulated parts and controlled assets. Relevant for this use case are the time-series simulator, the controller for the DC supply and the load bank, and the simulator representing the building management including the EMS. The co-simulation is the connector for the management algorithm implemented as software module and the assets controlled in the laboratory. Due to the investigation of attacks on the communication infrastructure, the protocol conform communications adapters




Fig. 3. Co-Simulation - Schematic scheduling and controlling process.
Black: electric connection; Blue: measurements; Orange: Control commands;
Green: Profiles

are used. The time-series simulator applies the measurement data from the real grid to the grid segment in the laboratory. Those fixed time series for demand and generation are then used as input for the controller of the DC supply and the load bank. The simulator for the building management system includes an EMS as logic part and communication and control interfaces for the assets in the grid segment.

In the normal operation mode the EMS manages the load balancing using controllable assets. For this, real-time measurement data provided by the *Janitza* measurement device are used. Based on the measurement data, the BSS tries to shave load and solar peaks. Therefore, the EMS processes the measurement data and sends control commands to the flexible assets. In the real-time simulation measurement data is collected at each scheduled time instance. The data processing including the determination of new control commands also happens in real time.

IV. CASE STUDY & DISCUSSION

In this section, we demonstrate our CPT approach in the context of a selected case study and discuss the results with respect to its use case in the cybersecurity domain. First, we introduce the cybersecurity condition adopted in the case study in section IV-A. Afterwards, we describe our case study scenarios in Section IV-B, while we present the case study results in Section IV-C and discuss the results in Section IV-D.

A. Cybersecurity Condition in Case Study

To proceed with the study of cybersecurity using the CPT approach, we first establish the security state conditions in our lab. The relevant components used in the lab are the workstation as a Demand Side Response (DSR) platform,




Fig. 4. STRIDE-based threat model for the case study scenario.

TABLE I
OVERVIEW OF SECURITY AND FUNCTIONAL FEATURES

Component	Function	Security Issue
DSR Platform	Optimization of self-consumption via controlling of DER	-EOL of OS -Legacy protocols -Outdated software -Weak password protection
DER Inverter	IED functions for remote monitoring and control	-Legacy protocols -Default password -No encryption
Load Bank	Replication of the load profiles of the reference system	-Legacy protocols -Default password -Fragile software

the load bank with integrated Programmable Logic Controller (PLC) for remote control, and the distributed energy resource (DER) inverters connected via a ICT switch.

A common vulnerability within the site is the outdated state of software and services that are not patched with the latest security updates or are no longer supported due to end-of-life. The DSR platform, as the control system within the use case, runs on an outdated operating system with no security updates or support. Specifically, the critical vulnerabilities within the component are insecure remote control functions (e.g., remote desktop protocol), a weak password hash function, and default credentials.

When examining other components within the system, default credentials that are sometimes difficult to change or not requested for critical operations are a major security concern. This is especially a typical characteristic for the Operational Technology (OT) facilities with default password that can be searched online. In addition, communication channels within the network do not use security mechanisms such as encryption or authentication. Critical access points via facility web interfaces are also not encrypted. In particular, the use of legacy protocols such as Modbus lacks security mechanisms and often contains functions that can be accessed without authentication procedures that expose process information.

The resource-constrained conditions of the hardware also allow for potential attacks on the endpoint without adequate safeguards. Table I summarizes the security and functional features of the case study. Overall, the security conditions in the lab environment reflect typical security conditions in OT networks that have neglected security concerns of their




Fig. 5. Sequence diagram of the case study scenarios. One scenario represents normal operation (indicated by blue arrows) and one represents the attack scenario (indicated by red arrows).

systems due to historically isolated and closed environments that are now exposed over the Internet.

B. Case Study Scenarios

In our case study, we examine two scenarios for the CPT approach (cf. Figure 5). The first scenario is the reference scenario, which is the normal grid situation replicated based on the grid reference. This scenario also serves as the benchmark against which the attack scenario is compared. The second scenario is the attack scenario in which cyberattacks against the grid within the infrastructure with the objective to maximize the power imbalance are replicated. Based on the STRIDE threat model [18], the threats and attack vectors of the case study are identified (cf. Figure 4). In particular, the attacker performs a sequence of attack actions composed of network scanning, role identification, MITM, and control command manipulation to achieve its final objective. Specifically, for the MITM attack, we use Address Resolution Protocol (ARP) spoofing, which poisons the switch's ARP table to associate the target system's IP address with the attacker's media access control (MAC) address to forward packets to the attacker instead of the original targets. For instance, the attack scenario sets a power limit for the PV inverter and the maximum charging power for the BSS. The power limit for the PV inverter is 3.5 kW and the maximum charging power for the BSS is 14 kW. For the BSS, this means that it behaves like an additional load. The simulation starts at 9:15am (real time) and the attack starts at 11:30am. The duration of the attack is 1h 45 min and thus ends at 2:15 pm.

C. Case Study Results

Figure 6 illustrates on the left side the resulting power over time for the normal grid operation scenario. Furthermore, Figure 7 additionally illustrates the data flow within the normal




Fig. 6. Results of the normal scenario (left) and attack scenario (right) which is conducted between 11:30 am and 2:15 pm.




Fig. 7. Data flow of the normal scenario (a) and attack scenario (b) which is conducted between 11:30 am and 2:15 pm.

and attack scenarios of the experiment. The load situation here is provided by the grid reference, where one day's data is used to replicate the load situation. The high load situation within this reference is very early in the day around 10 am as well as spread out over time throughout the day (e.g. 1:30 pm, 2:30 pm). Based on this load situation, the EMS in our co-simulation performs autonomous coordination of DERs to minimize power exchange with the external (overlying) grid. We can observe that the BSS tries to balance the residual power at any time. When the PV generation is low, the BSS supplies almost all the consumed power. When the PV generation is higher than the demand, the remaining power is used to recharge the BSS. The transformer output exhibits some ripple due to the short time required for the power management algorithm to rebalance the output. Regarding the communication structure within the CPT approach, it can be seen that the EMS communicates bidirectionally with the controllable devices such as PV inverter and BSS with the star-shaped communication flow. This indicates the centralized communication structure of the control system based on a web technology-based DSR platform that could be deployed in a

cloud infrastructure.

When looking at the attack scenario, certain characteristics can be identified. In Figure 6 on the right side, it can be observed that the attack (11:30 am - 2:15 pm) increases the BSS power from one moment to another, while the PV power decreases. Therefore, the total power during the attack period is constantly very high. Compared to the normal scenario, this is a significant difference. Normally, the power should be balanced using the BSS, which means that the total power at the transformer should be close to 0 kW. We can observe that the BSS management works properly after the end of the attack scenario. In contrast, the limitation set by the attack is not reset. The PV generation does not exceed the power limit. Only when the power generation is below the power limit the power injected into the site grid changes. This could be due to an error in the management algorithm, which does not actively set a power limit for times when there is no limit. Looking again at the data flow structure of the communication traces within the attack scenario, it is noticeable that the star-shaped structure of the EMS is replicated with the ARP spoofing. The real EMS communicates with the PV and BSS

inverters; however, these are spoofed endpoints of the attacker, i.e., ARP spoofed the communication channel between EMS and the respective endpoints. As can also be observed, the attacker's fake EMS communicates with the real inverter endpoints so that the communication channel is intercepted. The representation of the data flows here implies a parallel structure set up by the attacker, where the original EMS is supposedly still communicating with the inverter endpoints, but when looking at the MAC addresses, it becomes clear that these are interfaces spoofed by the attacker. However, the original inverter appears to be communicating with the EMS, but looking again at the MAC addresses shows that the EMS interface has also been spoofed by the attacker. This creates what appears to be a parallel data flow structure, with the original EMS communicating with the attacker's spoofed interfaces, while the inverters communicate with the EMS's spoofed interfaces.

D. Discussion

In our case study, the scenarios replicated in the CPT environment demonstrate the capabilities of a HITL-oriented simulation environment that not only provides a basis for investigating security conditions in the real productive operated grids without actively intervening the grid operations. A key vulnerability exploited by the cyberattack is the legacy characteristics of the technology, particularly the industrial protocols that do not provide for security mechanisms such as encryption or authorization. The network architecture also contributed to the success of the attack, as it has a flat structure with no enforced segmentation or access control. A vulnerable part of the system is also the DSR platform, which runs outdated software that provides an attack surface for direct interference with the control logic. Since the CPT environment can only replicate a specific grid segment due to the physical constraints of scalability of real hardware, the data generation of the experiment must focus on the specific grid segments that are emulated in the CPT. However, the co-simulation component of the CPT environment can be used as a substitute for the missing hardware to replicate the entire grid by virtually extending the replicated scenario. Thus, a hybrid approach based on HITL and DT simulation can be pursued, where the HITL simulation is used to replicate a specific grid segment in the physical environment and the DT simulation is used to fully replicate the remaining segments in the digital world. Thus, the CPT environment can also be used as a validation reference for simulation. Nonetheless, the CPT approach in this paper demonstrates the capabilities of investigating specific coordinated cyberattack scenarios within a combined physical and virtual simulated environment that can be used for detailed security investigation of the grid reference without affecting the real grid.

V. CONCLUSION

The increasing digitization of the power grid will lead to an emerging threat landscape for which countermeasures must be developed, but are faced with limited data from critical

infrastructure during an attack. In this paper, we demonstrate that our CPT approach provides a basis for replicating severe cyber incidents in a secure, controllable, and isolated environment that includes a realistic grid and ICT infrastructure with real-world components. In our case study, we observed the impact of specifically replicated cyberattacks, such as control command interception in a SG use case where DER components are provided with control commands that are harmful to the grid. Using advanced measurement infrastructure, we collected process and communication data during the cyberattacks. In particular, this approach can provide dataset to support the development, testing, and validation of such detection approaches that leverage not only the data within the communication layer but also inconsistencies or anomalies within the process data. Future work will therefore include the creation of a benchmark dataset that replicates various attack scenarios in the grid with coordinated attack patterns that can be used to improve countermeasures.

ACKNOWLEDGMENTS This work has partly been funded by the European Union's Horizon 2020 research and Innovation programme under grant agreement N°832989.

REFERENCES

- [1] I. A. Tøndel *et al.*, "Interdependencies and reliability in the combined ICT and power system: An overview of current research," *Applied computing and informatics*, 2018.
- [2] S. Davarzani *et al.*, "Residential demand response strategies and applications in active distribution network management," *Renewable and Sustainable Energy Reviews*, 2021.
- [3] C.-M. Mathas *et al.*, "Threat landscape for smart grid systems," in *ARES*, 2020.
- [4] T. Krause *et al.*, "Cybersecurity in Power Grids: Challenges and Opportunities," *Sensors*, 2021.
- [5] D. van der Velde *et al.*, "Methods for Actors in the Electric Power System to Prevent, Detect and React to ICT Attacks and Failures," in *ENERGYCon*, 2020.
- [6] G. Dán *et al.*, "Challenges in power system information security," *IEEE Security & Privacy Magazine*, 2012.
- [7] M. Atalay *et al.*, "A digital twins approach to smart grid security testing and standardization," in *MetroInd4.0&IoT*, 2020.
- [8] A. J. Burstein, "Toward a culture of cybersecurity research," *UC Berkeley Public Law Research Paper*, 2008.
- [9] S. Abt *et al.*, "A plea for utilising synthetic data when performing machine learning based cyber-security experiments," in *AISec*, 2014.
- [10] K. Alshammari *et al.*, "Cybersecurity for digital twins in the built environment: current research and future directions," *ITcon*, 2021.
- [11] C. Qian *et al.*, "Digital Twin—Cyber Replica of Physical Things: Architecture, Applications and Future Research Directions," *Future Internet*, 2022.
- [12] J. C. Olivares-Rojas *et al.*, "Towards Cybersecurity of the Smart Grid using Digital Twins," *IEEE Internet Computing*, 2021.
- [13] N. K. Kandasamy *et al.*, "EPICTWIN: An Electric Power Digital Twin for Cyber Security Testing, Research and Education," *arXiv preprint arXiv:2105.04260*, 2021.
- [14] I. A. Oyewumi *et al.*, "Isaac: The idaho cps smart grid cybersecurity testbed," in *TPEC*, 2019.
- [15] M. Noorzadeh *et al.*, "A cyber-security methodology for a cyber-physical industrial control system testbed," *IEEE Access*, 2021.
- [16] E. Hammad *et al.*, "Implementation and development of an offline co-simulation testbed for studies of power systems cyber security and control verification," *JEPE*, 2019.
- [17] D. van der Velde *et al.*, "Towards a Scalable and Flexible Smart Grid Co-Simulation Environment to Investigate Communication Infrastructures for Resilient Distribution Grid Operation," in *SEST*, 2021.
- [18] A. Shostack, "Experiences threat modeling at microsoft," *MODSEC@MoDELS*, 2008.