# RAPTOR: Advanced Persistent Threat Detection in Industrial IoT via Attack Stage Correlation

Ayush Kumar and Vrizlynn L.L. Thing Cyber Security Strategic Technology Centre ST Engineering Email: ayush.kumar@u.nus.edu, vriz@ieee.org

Abstract—IIoT (Industrial Internet-of-Things) systems are getting more prone to attacks by APT (Advanced Persistent Threat) adversaries. Past APT attacks on IIoT systems such as the 2016 Ukrainian power grid attack which cut off the capital Kyiv off power for an hour and the 2017 Saudi petrochemical plant attack which almost shut down the plant's safety controllers have shown that APT campaigns can disrupt industrial processes, shut down critical systems and endanger human lives. In this work, we propose RAPTOR, a system to detect APT campaigns in IIoT environments. RAPTOR detects and correlates various APT attack stages (adapted to IIoT) using multiple data sources. Subsequently, it constructs a high-level APT campaign graph which can be used by cybersecurity analysts towards attack analysis and mitigation. A performance evaluation of RAPTOR's APT stage detection stages shows high precision and low false positive/negative rates. We also show that RAPTOR is able to construct the APT campaign graph for APT attacks (modelled after real-world attacks on ICS/OT infrastructure) executed on our HoT testbed.

Index Terms—Industrial Internet of Things, IoT, IIoT, Advanced Persistent Threat, APT, APT Detection

#### I. INTRODUCTION

The Internet of Things (IoT) is a network of sensing devices with low-power and limited processing capability, which exchange data with each other and/or systems (e.g., gateways, cloud servers), normally using wired and wireless technologies. Industrial IoT (IIoT) refers to the extension of IoT in industrial sectors and applications. With a strong focus on machine-to-machine (M2M) communication, big data, and machine learning, the IIoT enables industries and enterprises to have better efficiency and reliability in their operations. What makes IIoT distinct from IoT is the intersection of information technology (IT) and operational technology (OT). However, this convergence has widened the attack surface and increased the potential risks of cyberattacks being launched against such critical systems. A more significant concern relates to legacy OT systems (i.e., brownfield IIoTs) which are usually isolated but are becoming more connected with new IT technologies. Sophisticated attackers can easily gain access to such brownfield IIoT systems and damage their operation for lengthy periods of time.

IIoT systems are more prone to attacks by APT adversaries than traditional ICS (Industrial Control Systems)/OT (Operational Technology) networks [1] mainly due to addition of

Corresponding author: A. Kumar (email: ayush.kumar@u.nus.edu).

connectivity to IT networks (enabling lateral movement for attackers) and introduction of M2M communications which connect various new and intelligent devices. Furthermore, ICS assets themselves are prime targets for APT campaigns. This is because ICS devices often run on legacy, proprietary software which were not designed with security in mind and are not patched/updated regularly due to concerns over downtime in critical systems. APT attacks can be used to gather ICS-related intelligence, disrupt industrial processes, shut down critical systems and endanger human lives. Such APT attacks by wellresourced groups have happened a number of times in the past, e.g., the 2010 Stuxnet attack which damaged centrifuges in Iranian uranium enrichment plants and caused a significant setback to Iranian nuclear program [2], the 2014 attack on a German steel mill [3] which prevented the blast furnace from shutting down causing massive damage, the 2015 attack on Ukrainian power companies which disconnected substations from the power grid leaving 225,000+ customers without power for more than 6 hours [4], the 2016 attack on Ukranian transmission level substation which cut a fifth of the capital Kyiv off power for an hour [5] and the 2017 attack on a Saudi petrochemical plant which almost shut down the plant's safety controllers which could have caused an explosion [6]. Industrover/Crashoverride, the malware behind 2016 Ukraine power grid attack and TRITON, the malware behind 2017 Saudi petrochemical plant attack are still active, targeting electrical substations and energy utilities respectively [7], [8]. New IIoT malware such as Incontroller/Pipedream [9], which was revealed as recently as 2022, contains modules that target specific ICS devices such as OPC servers, Schneider Electric PLCs using Modbus and Codesys protocols, and Omron PLCs and servo drives.

Security solutions which are commonly deployed in IT networks such as firewalls, NIDS (Network Intrusion Detection System), SIEM (Security Information and Event Management) products are not common in ICS/OT networks. Thus, there is an impending need to design systems which can detect ongoing APT attack campaigns in IIoT environments early before they cause substantial damage. Such systems should satisfy the following requirements:

 Not dependent on deployment of proprietary, third-party security solutions whose features can vary across vendors. Instead, the system should use existing open-source and readily available information sources for its operation.

- Detect the APT attack tactics with high accuracy and low number of false positives/negatives
- Able to reconstruct the APT attack campaign with sufficient details and present them in a compact, high-level form which cybersecurity analysts can use for further analysis and attack mitigation.

An APT campaign typically consists of various stages which occur one after another (this will be explained later in the paper). However, not all stages defined in existing attack frameworks are found together in real-world APT campaigns. Each stage in an APT campaign is linked to the previously executed stages, e.g., in terms of chronology of execution, target hosts affected. Thus, if we are able to detect some of the individual attack stages, the above fact can be exploited to correlate the detected stages and reconstruct the APT campaign with some acceptable margin of error. In this work, we present RAPTOR, a system for detecting ongoing APT campaigns in IIoT environments. RAPTOR's main component is an APT attack-stage detection and correlation engine. It takes as input a variety of readily available, non-proprietary data sources (such as host logs, network traffic traces) and detects attack tactics (including those specific to IIoT environments) which are part of an ongoing APT campaign. The attack tactics are then stitched together based on their attributes to produce the APT attack campaign graph, which is a high-level representation of APT activity across the target IIoT network.

The main contributions of our work are as follows:

- We present, RAPTOR, a system for detecting ongoing APT campaigns in IIoT environments.
- We employ a novel attack-stage detection and correlation approach which uses open source, readily available data sources for its operation.
- RAPTOR constructs a compact, high level APT campaign graph which can be useful for cybersecurity analysts.
- We evaluate RAPTOR's performance using a new dataset which includes attack TTPs close to real-world APT attacks on ICS/OT environments.

#### II. RELATED WORK

#### A. APT detection in Enterprise networks

APT detection in enterprise network settings has received significant attention in computer security literature in recent years. Milajerdi et al. [10] have presented HOLMES, a system for APT campaign detection with high confidence. It maps activities in host audit logs and enterprise security alerts to the cyber kill-chain, correlates the alerts generated by APT steps based on information flow between low-level entities (files, processes, etc.) and builds a high-level scenario graph encapsulating the attack TTPs and information flows between entities involved in the TTPs. CONAN [11] is an APT detection system which makes two major modifications to HOLMES's approach: one, it utilizes a state-based detection framework where all processes and files are represented as data structures similar to finite-state automata and two, it focuses on three constant attack phases of APTs-1) deploy and execute the attacker's code, 2) collect sensitive information or cause damage, and 3) communicate with the C&C server or exfiltrate sensitive data. Wilkens et al. [12] have proposed a method to construct APT attack graphs from IDS (Intrusion Detection System) alerts to assist human analysts. IDS alerts are clustered into meta-alerts and single alerts, assigned potential attack stages and finally used to synthesize APT scenario graphs based on a *kill chain state machine*.

Irshad et al. [13] have proposed TRACE, a provenance tracking system for enterprise-wide APT detection. TRACE offers host-level provenance tracking at the granularity of program executions units and integrates provenance collected from individual hosts to construct distributed enterprise-wide causal graphs. Hopper [14] instead focuses on the detection of a single APT attack stage: lateral movement, within enterprise networks. It does so by building a graph of login activity among machines in a network and identifying suspicious login sequences. A path inference algorithm is then deployed to identify the broader paths that each login belongs to, "caused" by the same user. Finally, an anomaly detection algorithm is applied to conservatively infer the set of login paths most likely to reflect lateral movement.

However, all the above works suffer from certain limitations:

- [10]–[14] focus on enterprise networks only.
- While [10], [11], [13] have been designed using audit logs-based provenance and [14] has been designed using enterprise logs, [12] has been designed using network IDS alerts. Since each of these works is based on a single data source, they are unable to leverage the information provided by other data sources. Further, these works are only able to detect a subset of APT attack stages.
- Exclusively graph-based approaches [10], [13] tend to suffer from dependency explosion problem which means that with time, each graph node gives rise to many edges which in turn give rise to new nodes and so on. A backward trace through the graph to infer a path exponentially increases the number of probable paths.
- [12], [14] work offline and not in real-time which means that they assume that all the data required for APT detection is available at once. Though [10], [11], [13] claim that they work in real-time, they don't provide the time delays encountered in APT detection.
- Except for [12], no other work mentioned above detects an APT campaign from a whole-network perspective.

Unfortunately, there has been no research work yet on detecting APT campaigns in IIoT settings which is the focus of this paper. Our work differs from [10]–[14] in the following aspects:

- The focus is on APT detection in IIoT settings which combines both IT and OT environments. The APT attack stages used to design the detection system in our paper have been adapted to IIoT settings.
- We leverage data from various sources such as network packet traces, host logs (including audit logs) as well as NIDS/HIDS alerts instead of limiting ourselves to a specific or *proprietary* data source. The optimal data source(s) for detection of each APT attack stage is(are) identified and used.

• We perform APT campaign detection from a wholenetwork perspective instead of detecting APT artifacts on individual hosts only.

# B. ICS/IIoT datasets

In the past, researchers have built datasets (consisting of network traffic, system logs, etc.) to design IDSes for ICS (Industrial Control System). Morris et al. [15] have provided a labeled dataset which includes network traffic captured from a laboratory scale gas pipeline system during normal operation and during 35 cyber-attacks that affect the Modbus protocol such as reconnaissance, response injection, command injection and DoS. Similarly, Pan et al. [16] have produced a dataset consisting of synchrophasor measurement data and audit logs from a power system testbed, amounting to a total of 10,000 simulated instances. The dataset includes 25 scenarios consisting of power system single-line-to-ground (SLG) faults, normal operation and cyber-attacks (relay trip command injection, relay function disabling and SLG fault replay). Another dataset has been collected from the Secure Water Treatment (SWaT) testbed [17] and includes sensor/actuator readings both during normal operation and under 36 attacks such as bias attack, replay, single and multiple point attacks. The final dataset includes 946,772 samples consisting of 51 attributes.

More recently, Myers et al. [18] have generated two datasets consisting of ICS device logs and network traffic captures from two separate industrial process setups respectively, during normal operation and during attacks on the testbed PLCs (command injection, flooding, etc.). Marcio et al. [19] have built a dataset consisting of six pre-decided ML-based flowlevel features extracted from the network traffic captured during normal as well as under attack operation of a SCADA system testbed consisting of a water storage tank's control system. Finally, Muna et al. [20] have presented the X-IIoTID intrusion dataset which targets modern IIoT systems. The dataset covers various attack scenarios and attacks related to newer IIoT connectivity protocols generated according to a pre-defined attack taxonomy. The data collected includes endto-end network traffic (from physical field devices to the edge gateway and from edge gateway to the cloud and enterprise devices), host logs and computing resources, and IDS alert logs (OSSEC, Zeek) collected at the edge gateway for both normal and under attack operation of the testbed. The final dataset consists of 820.834 instances and 59 features.

However, the above datasets suffer from certain limitations:

- Many of the existing ICS datasets [15]–[19] highly depend on features related to sensor measurements, actuators' statuses, and specific parameters of industrial protocol packets, which limit their use for diverse industrial systems.
- Most of those datasets lack a clear attack taxonomy and have not incorporated multi-stage attacks related to newer IIoT connectivity protocols and services (e.g., CoAP, MQTT).
- The X-IIoTID dataset addresses the above shortcomings of previous datasets. However, all the above datasets including X-IIoTID provide pre-decided ML features

extracted from network flows only and do not include raw traffic traces from which additional features can be extracted. Further, the X-IIoTID dataset provides host logs and IDS alert logs collected at the edge gateway only since according to the dataset authors, edge gateway is the highest priority target for attackers. The dataset does not include APT campaigns.

To address the limitations of X-IIoTID dataset for APT detection, we build a new dataset using an IIoT testbed based on Brown-IIoTbed [21] architecture. Our dataset includes raw traffic traces from testbed hosts, host logs, audit-based system provenance at hosts as well as host/network IDS alerts collected during normal operation of the testbed, individual APT attack stages and APT campaigns based on real-world attacks. Our dataset also includes IIoT-specific attack stages/tactics.

#### III. BACKGROUND

#### A. Existing Attack Frameworks for IIoT

The authors in [20] have proposed a generic IIoT attack life-cycle framework consisting of the following stages: reconnaissance, weaponization, exploitation, lateral movement, command & control, exfiltration and tampering. MITRE has also released an Adversarial Tactics, Techniques and Common Knowledge (ATT&CK) framework for ICS [22] consisting of the following tactics/stages: initial access, execution, persistence, privilege escalation, evasion, discovery, lateral movement, collection, command and control, inhibit response function, impair process control, and impact.

#### B. IIoT APT Invariant State Machine

It should be noted that real-world APT campaigns in IIoT environments do not follow all the stages in attack frameworks mentioned above. Further, each tactic in an attack framework consists of many techniques, with new ones being added regularly. It is almost impossible to model all the possible attack techniques and then use them towards detection during ongoing APT campaigns. Therefore, using the IIoT attack lifecycle framework [20] and the MITRE ATT&CK framework for ICS [22], we have identified certain attack stages/tactics which are 'invariant': Command-and-control, Discovery, Lateral movement, Fieldbus scanning and CE communication *spoofing*. These attack tactics consist of only a few techniques and those techniques have not changed significantly across APT campaigns over the years (and are not expected to change significantly in future). It is easier to model these invariant attack tactics and use them towards APT detection. We propose an IIoT APT Invariant State Machine (IASM) as shown in Fig. 1 which models a typical APT campaign in an IIoT environment as a finite-state machine. The states in IASM represent the states of the APT campaign while the state transitions are brought about by the deployment of invariant APT tactics identified earlier. Most real-world APT campaigns in IIoT environments such as those described in Section I follow our proposed IASM.

IASM Description: Once the APT attackers have acquired all the resources and information required for attack campaign (Ready for attack state), they move by compromising one or more of the public network-facing hosts to gain entry into the target IIoT network (Infected entry host state) and establish communication with a Command-and-control or C&C server (Establish foothold state). Next, the attackers scan for other hosts connected to the compromised machine and attempt to gain control of one of the discovered hosts (Infected new host state) either by using CVE vulnerabilities or by stealing the remote access credentials for the discovered host and then logging in to it. The attackers may attempt to move across the HoT network by gaining control of more hosts, thus remaining in the same Infected new host state and using the same tactics as outlined earlier. Once the attackers reach the edge gateway (Infected edge gateway stage), they scan for control elements (PLC/RTU/SIS) and their slave devices connected via fieldbus protocols. Fieldbus refers to Modbus and other similar opensource or proprietary vendor protocols (e.g., Profibus/Profinet, CAN) which are used to communicate with respective vendor control elements. Subsequently, they spoof communications with the discovered control elements and their slaves to gain more information about them (Collect ICS intelligence state) and execute commands on control elements remotely (Execute CE commands state). Depending on the target(s) set by the APT adversaries (just collection of ICS intelligence or execution of desired commands on CE), they might end the campaign wilfully or forcibly due to detection by cybersecurity analysts (Goals achieved/APT detected state).

#### C. Threat Model

We assume that only a few machines in the enterprise tier of the target IIoT network are connected to the Internet (through firewall/IDS). All other machines in the enterprise tier and other tiers (platform, edge) are isolated from the Internet though some of them can still communicate with the Internetconnected machines in enterprise tier. The APT attackers can enter the target IIoT network through the internet-facing enterprise tier machines (remote access) or other machines to which plant operators/engineers have access (insider attack). Once inside the enterprise tier network, the attackers can move laterally across machines till they reach the edge tier consisting of edge gateway, control elements and sensors/actuators. The attackers are assumed to be well-resourced in terms of computational resources, financial backing, hacking skills and time which is true of most APT groups.

## **IV. SYSTEM OVERVIEW**

## A. RAPTOR Architecture

As shown in Fig. 2, RAPTOR consumes data from different sources such as network traffic traces, *audit* logs, HIDS/NIDS alerts and host logs. The data is processed prior to extraction of features and then the features are processed before being sent to the *APT attack-stage detection & correlation engine* which detects the invariant APT attack stages in IASM using the optimal data source(s) identified in the following sub-section. The detection methods employed for detection of the attacks-stages are explained in sub-section IV-C. The attack stages are detected and correlated using their attributes to re-construct the

APT campaign which is presented in the form of a graph as described in sub-sections IV-E and IV-F. The APT Campaign Graph (ACG) thus constructed can be utilized by cybersecurity analysts to come up with appropriate actions to mitigate the attack campaign or for forensic analysis.

#### B. Selection of optimal data sources

As outlined in Section II-A, we utilize data from various sources towards APT detection instead of limiting ourselves to a specific or proprietary data source. However, not all of those data sources are required for detection of each APT stage. Some of the data sources might be redundant or have limitations compared to other data sources. Therefore, we analyse our data sources in the context of each invariant APT stage and select the optimal ones.

- Command-and-Control: Most rootkits and malware regularly exchange keep-alive packets with a C&C server to maintain connection throughout the duration of infection which can be captured by network traffic traces. By default, network IDS rules are not configured to detect C&C server message exchange. Audit-based provenance which captures network socket file read/write operations can also be used to detect the establishment of a connection between the compromised host and public C&C server. However, due to the issues of pruning spurious dependencies and noise in provenance graphs due to benign activities, we feel that using audit-based provenance to extract C&C communication might not justify the computational cost incurred and therefore, network traffic traces alone can be sufficient for this purpose.
- *Discovery*: This stage can be detected through network traffic traces since scanning for other targets results in TCP/UDP packets being sent from the compromised machine to other machines in the target network. This stage can also be detected from alerts generated by an open source network IDS such as Snort or Suricata. However, not all organizations can be expected to deploy network IDSes. Further, slow stealth scans might be able to evade IDSes altogether. In case network IDS alerts are available, we can use them to increase the accuracy of detection.
- Lateral Movement: This stage can be detected using login logs on target machines since during lateral movement, the attacker logs in to a target machine which is connected to the same or different subnet as the compromised machine. IDS alerts would not be helpful in detecting lateral movement since by default, IDS rules are not configured to do so and lateral movements are not that frequent compared to the events that IDSes are expected to detect such as DoS attacks, port scans, SMB probes, etc. Network traffic traces can contain evidence of lateral movement in terms of TCP/UDP packets exchanged between compromised source and target machines and hence, they can be used to increase the accuracy of lateral movement detection.
- Fieldbus scanning: This stage can be detected through network traffic traces since scanning for target control



Fig. 1: IIoT APT Invariant State Machine

elements over fieldbus protocols results in TCP packets being sent from the edge gateway to connected control elements at specific port numbers. This stage can also be detected from alerts generated by an open source network IDS such as Snort or Suricata configured with customized modules. In case network IDS alerts are available, we can use them to increase the accuracy of detection.

• *CE communication spoofing*: Since the attacker needs to send appropriately crafted packets over the link between edge gateway and control elements, network traffic traces can be used to detect the attacker's spoofing of communications with control elements.

Our findings regarding optimal data sources for detecting various APT attack stages for IIoT are summarized in Table I.

#### C. APT attack-stage detection

**Detection of Command-and-control stage**: In this stage, a compromised machine establishes connection with a C&C server, which is a public server, and communicates with it at regular time intervals. Therefore, multiple packet exchanges of a suspected host with public server IP address indicates communication with C&C server. We filter the TCP [PSH,ACK], [ACK]/UDP packets sent/received by public server IP addresses (except VPN server) to/from IIoT testbed host IP addresses from network traffic traces (in pcap format). If the filter yields multiple such packets, we extract the packet arrival timings. Further, since many malware enforce periodic communication between the compromised machine and C&C server, we test for periodicity in packet arrival timings obtained earlier using the algorithm proposed in [23] which is based on discrete-time signal encoding and autocorrelation function. If the packet arrivals are found to be periodic, it can be inferred that the Command-and-control stage has been detected. It should be noted that there may be machines in the enterprise tier which talk to public servers, e.g., to retrieve a web page over HTTPS from a web server. The packets exchanged with such legitimate public servers contribute as noise to our extracted timings for periodicity detection. The ACF (autocorrelation function) can detect periodicity reliably in presence of such noise.

Detection of Discovery stage: The network traffic traces

TABLE I: Optimal data sources for detecting APT attack stages in IIoT. (P) indicates primary data source.

Attack Stage	Audit provenance	Network traffic traces	IDS alerts	Host logs
Command-and-control	X	$\checkmark$	X	X
Discovery	X	✓ (P)	$\checkmark$	X
Lateral Movement	X	$\checkmark$	X	√(P)
Fieldbus scanning	X	✓ (P)	$\checkmark$	X
CE communication spoofing	X	$\checkmark$	X	X

collected at a host are split into smaller traces of fixed time duration. These traces are assumed to belong to either of two classes: *normal* or *scanning*. A *normal* trace is one which does not consist of network scanning packets while a *scanning* trace is one that does. Each trace is classified using an ML algorithm (e.g., Decision Trees, SVM, etc.). If a trace is classified as belonging to *scanning* class, it can be inferred that the *Discovery* attack stage has been detected. For each trace, the features for ML classification are extracted from TCP/UDP headers only and not the payloads of the respective packets since the network traffic might be encrypted. The ML features selected for detection of scanning traffic are shown in Table II.

Motivation behind feature selection: The intuition behind selecting the first two features is that port scanning tools used by attackers send TCP/UDP requests to multiple IP addresses to find out open ports and the services running on them. The third set of features was selected because during port scan targeting an IP address, many of the ports to which TCP connection requests are sent are not open and no response/acknowledgement is sent back, so the TCP connections formed remain half-open. The fourth feature seeks to exploit the fact that once TCP connection is formed with an IP address at a certain port number, port scanning tools exchange data only for a short time and the connection is subsequently reset. Compared to packet length in normal TCP connections, port scanning packet lengths are generally shorter making the fifth set of features useful for classification. Finally, the sixth feature set targets the short time intervals between the transmission of port scanning packets as compared to normal packets.

**Detection of Lateral movement stage**: According to our approach, the authentication logs on network hosts are used to detect this stage. We look for logins that satisfy the following suspicious property: the machine from which a user is initiating the login to another machine is a part of other detected APT attack stages that usually precede lateral movement, e.g., command-and-control and discovery. For example, if *user1* logs in to *machine-B* from *machine-A*, *machine-A* is in a different subnet as *machine-B* and *machine-A* has been identified as part of *Discovery* stage detected earlier, we can conclude that lateral movement has been detected from *machine-A* to *machine-B*.

**Detection of Fieldbus scanning**: Similar to the detection of *Discovery* stage, the network traffic traces collected at edge gateway network interfaces connected to control elements are split into smaller traces of fixed time duration. These traces are assumed to belong to either of two classes: *normal* or *fieldbus scanning*. A *normal* trace is one which does not consist of Fieldbus scanning packets while a *fieldbus scanning*  trace is one that does. Each trace is classified using an ML algorithm. If a trace is classified as belonging to *fieldbus scanning* class, it can be inferred that the *Fieldbus scanning* attack stage has been detected. For each trace, the features for ML classification are extracted from TCP headers only and not the payloads of the respective packets since the network traffic might be encrypted. The ML features selected for detection of Fieldbus scanning traffic are shown in Table II.

Motivation behind feature selection: The intuition behind selecting the first three features is that typically during fielbus scanning, attackers attempt to set up a TCP connection with a fieldbus device (PLC/RTU) which is unsuccessful for the first few times. Once the connection is set up, the fieldbus scanner requests device enumeration data and finally, the connection is closed. If the scanner is also trying to enumerate fieldbus slaves, it iterates through the list of slave IDs sequentially. Since slaves are not present at all SIDs, the TCP connection may be reset only for the fieldbus scanner to set up a new connection. Again, compared to packet length in normal TCP connections, fieldbus scanning packet lengths are generally shorter making the fourth set of features useful for classification. Finally, the fifth feature set targets the short time intervals between the transmission of fieldbus scanning packets as compared to normal packets.

**Detection of CE communication spoofing**: If an attacker is trying to spoof communications with a control element using one of the standard industrial automation (IA) protocols (e.g., IEC 61850, IEC 61131-3), there would either be more than one TCP connections from the edge gateway to the control element at the destination port specific to that IA protocol, or the original TCP connection would be terminated by the attacker leaving only the attacker's TCP connections from the edge gateway to the control element at the destination one TCP connection specific to that IA protocol, or the original TCP connection would be terminated by the attacker leaving only the attacker's TCP connections from the edge gateway to the control element at the destination port specific to that IA protocol or the original TCP connection has been terminated, it can be inferred that the *CE communication spoofing* stage has been detected.

#### D. Detection using multiple data sources

As explained in Section IV-B, there can be more than one data sources which can be used to detect each APT attack stage. For an attack stage,  $a \in \{\text{Command-and-control}, \text{Discovery, Lateral movement, Fieldbus scanning, CE commu$  $nication spoofing}\}$ , we define the aggregate detection score as:

$$d_a = \sum_i w_{ia} \mathbb{1}_{ia},\tag{1}$$

where  $w_{ia}$  is the weight assigned to the *i*<sup>th</sup> data source for detection of attack stage *a*, and the indicator function,  $\mathbb{1}_{ia}$  is

Attack stage	ML features
Discovery	Number of unique TCP SYN/UDP destina-
	tion IP addresses, Number of unique TCP
	SYN/UDP destination ports per destination IP
	address (maximum, minimum, mean), Number
	of half-open TCP connections, Number of TCP
	RESET packets, Packet length in bytes (max-
	imum, minimum, mean), Packet inter-arrival
	time in seconds (maximum, minimum, mean)
Fieldbus scanning	Number of TCP 3-way handshakes with a
	destination IP address (maximum, minimum,
	mean), Number of TCP RESET packets, Num-
	ber of TCP FIN packets, Packet length in bytes
	(maximum, minimum, mean), Packet inter-
	arrival time in seconds (maximum, minimum,
	mean)

TABLE II: ML features selected for detection for APT attack stages

defined as:

$$\mathbb{1}_{ia} = \begin{cases} 1, & \text{if } i^{th} \text{ data source is optimal for detection} \\ & \text{of attack stage } a \quad (2) \\ 0, & \text{otherwise} \end{cases}$$

The weight assigned to the primary optimal data source identified for an attack stage should be greater than the weight assigned to secondary data sources. If the aggregate detection score,  $d_a$  is greater than a pre-defined threshold,  $\tau$ , then the attack stage *a* is considered as detected, otherwise not.

#### E. Correlation of APT attack stages

There are three conditions which need to be satisfied for an attack stage A to be followed by an attack stage B:

- The *source IP address* for stage A should match with the *source IP address* for stage B.
- When stage A involves movement of the attacker from one machine to another (e.g., Lateral movement), then the *destination IP address* for stage A should match with the *source IP address* for stage B.
- The time stamp for stage A should fall earlier than the time stamp for stage B.

The APT attack stage detection & correlation (ASDC) engine first checks if the initial stage of Command-and-control) in the proposed IASM can be detected at any of the Internetfacing hosts in enterprise tier. If the detection is successful, ASDC engine checks for the (Discovery) stage at the same host where Command-and-control) stage was detected. If the Discovery stage is detected, ASDC engine looks for signs of the Lateral movement stage at the same host. If the Lateral movement stage is detected, ASDC engine proceeds to check for the Discovery stage again followed by the Lateral movement stage as outlined above at the host accessed after lateral movement. If the host accessed after lateral movement is the edge gateway, ASDC engine starts looking for the Fieldbus scanning stage at the edge gateway and if it is detected, ASDC engine checks if CE communication spoofing stage can also be detected. The complete attack stage detection and correlation algorithm proposed above is shown in Algorithm 1.

Handling false positives/negatives in ML classification: RAPTOR is designed to handle false positives/negatives in Algorithm 1 Detect\_Correlate\_Attack\_Stages (list\_host\_IP\_add)

- 1: **INPUT**: list\_host\_IP\_add (List of IP addresses of Internetfacing hosts)
- 2:  $det_status = APT_DET_START$
- 3: for *host\_ip*  $\in$  list\_host\_IP\_add do
- 4: **if** Check\_C&C\_stage (host\_ip)[1] = TRUE **then**
- 5: src\_host\_ip = host\_ip

- 7: end for
- 8: if Check\_Discovery\_stage (src\_host\_ip)[1] = TRUE
   && Check\_Discovery\_stage (src\_host\_ip)[2] >
   Check\_C&C\_stage (src\_host\_ip)[2] then
- 9: **for** tgt\_host\_ip ∈ Check\_Discovery\_stage (src\_host\_ip)[4] **do**
- 10: if Check\_Lateral\_Movement\_stage
   (src\_host\_ip, tgt\_host\_ip)[1] = TRUE &&
   Check\_Lateral\_Movement\_stage (src\_host\_ip,
   tgt\_host\_ip)[2] > Check\_Discovery\_stage
   (src\_host\_ip)[2] then

11: **if** tgt\_host\_ip = edge\_gw\_IP **then** 

- 12: if Check\_Fieldbus\_scan\_stage ()[1] = TRUE && Check\_Fieldbus\_scan\_stage ()[2] > Check\_Lateral\_Movement\_stage (src\_host\_ip, tgt\_host\_ip)[2] then
- 13: if Check\_CE\_comm\_stage ()[1] = TRUE && Check\_CE\_comm\_stage ()[2] > Check Fieldbus scan stage ()[2] then
- 14:  $det_status = APT_DET_STOP$ 
  - return (det\_status)
- 16: **end if**
- 17: **end if**
- 18: **end if**
- 19: **end if**
- 20: **end for**
- 21: end if

15:

- 22: **Function** Check\_C&C\_stage (host\_ip), *Returns* {bool\_val, time\_det, C&C\_server\_IP}
- 23: Function Check\_Discovery\_stage (host\_ip), Returns
  {bool\_val, time\_det, scan\_type, list\_target\_host\_IPs}
- 24: **Function** Check\_Lateral\_Movement\_stage (src\_host\_ip, dst\_host\_ip), *Returns* {bool\_val, time\_det}
- 25: Function Check\_Fieldbus\_scan\_stage (), Returns
  {bool\_val, time\_det}
- 26: Function Check\_CE\_comm\_stage (), Returns
  {bool\_val, time\_det}

ML-based detection. For example, let us assume that there is a false positive, i.e., a packet trace is classified as *scanning* though it is *normal* and the *Discovery* stage is marked as detected. The subsequent attack stages in IASM would not be detected by the ASDC engine and therefore, **RAPTOR** would know that there was a false positive in detection of an earlier attack stage. It is also possible that there is a false negative, i.e., a packet trace is classified as *normal* though it is *scanning*, and therefore, the ASDC engine would not invoke detection of subsequent attack stages in IASM. We propose to

<sup>6:</sup> **end if** 

handle both false positives and negatives by taking the mode of classification results for a packet trace for a sufficiently large number of iterations.

#### F. APT campaign graph

As the ASDC engine proceeds to detect various stages of an APT campaign, it uses the detected stages and their attributes to construct the APT campaign graph. It is a directed graph, G(V,E) where each node,  $v_i \in V \ \forall i \in \{1,2,...,N_v\}$ , where  $N_v$  is the total number of nodes in the graph, corresponds to a machine (denoted by its IP address) which is a part of one of the detected attack stages. An edge,  $e_j \in E \ \forall j \in \{1,2,...,N_e\}$ , where  $N_e$  is the total number of edges in the graph, is extended from node  $v_i$  to another node  $v_k$  in the graph if there is a connection from the machine corresponding to node  $v_k$  during one or more of the APT attack stages. Each edge has an attribute  $\{s_1, s_2, ...\}$  where  $s_l \ \forall l \in \{1, 2, ...\}$  is an attack stage which enables the connection between the two machines corresponding to the nodes at either end of the edge.

#### V. EXPERIMENTS

#### A. IIoT Testbed

To generate a realistic IIoT APT dataset which can be used to evaluate RAPTOR's performance, we built an IIoT testbed modelled after Brown-IIoTbed [21] whose architecture is reproduced in Fig. 3. The implementation of IIoT testbeds is still in its early stages, with most existing implementations [4] being special projects and publicly unavailable. Brown-HoTbed is designed based on the IIC (Industrial Internet Consortium)'s IIRA (Industrial Internet Reference Architecture) model and consists of three tiers- edge, platform and enterprise. It supports a number of real-world IIoT functionalities such as e-mail notifications to plant workers regarding important OT events, web-based SCADA interface (viewing real-time sensor values and trends, actuator status change notifications, tuning of PLC parameters), remote maintenance of edge gateway, query to edge data historian, etc. The testbed also supports a number of real-world IIoT protocols such as CoAP, MQTT, and Modbus.

#### B. Experimental Methodology and Results

We need to collect data from our IIoT testbed under normal operation as well during APT attack stages. We collect data from our testbed in the form of network traffic traces from hosts, audit-based provenance at each x86-based host, host logs (login records, authentication logs, syslog) and alerts from Snort network IDS. However, we use only the optimal data sources identified in Section IV-B towards the final attack detection.

*Command-and-control stage*: To emulate this stage, we use open-source tools such as *dnscat2* to create a communication channel between a C&C server and a compromised machine using tunneling over DNS protocol which is one of the most common C&C communication protocols used by attackers since most firewalls do not block it. We run a public *dnscat2*  C&C server and the client on a Windows 10 Pro and a Ubuntu 20.04 machine in our testbed. The packet traces generated on those client machines are collected using *tcpdump* in sets of 1 minute duration. A total of 1000 packet traces were collected for each type of host and fed as input to the detection phase of *Algorithm 2* proposed in [23] for detection of C&C communication.

The performance is evaluated in terms of detection rate (DR) and missed-detection rate (MDR). *Detection Rate* is the fraction of the total number of packet traces which have been correctly detected as containing C&C traffic, and *Missed-detection Rate* is the fraction of the total number of packet traces which have been incorrectly detected as not containing C&C traffic. Using the parameter values (given in Table III), the detection performance for both the scenarios specified above is shown in Table IV. It can be seen that the algorithm gives a DR of 1.0 and a MDR of 0.0.

Traffic sampling frequency	0.1
Min. autocorrelation peak height	$0.7 \times (Max. peak height)$
Inter-peak gap variance threshold	0.01

TABLE III: Parameter Values for C&C Communication Periodicity Detection

Discovery stage: To emulate this stage, we use open-source network scanning tools such as *nmap* which is either used directly or is the inspiration for customized port scanners used by most APT groups. We run the default *nmap* SYN scans on a Windows 10 Pro and a Ubuntu 20.04 machine in our testbed to enumerate connected hosts, their OS versions and the services running on them. Nmap is run in both normal mode as well as *sneaky* or as well call it, slow mode, with the latter mode targeted at evading IDSes [24]. The packet traces thus generated on those machines are collected using tcpdump in sets of 1 minute duration. In real-world APT campaigns, attackers may slow down network scanning to evade detection by IDS and therefore, we may need to increase the duration of packet captures. A total of 1000 packet traces are collected from both the Windows and Ubuntu machines under normal operation and further 1000 packet traces are collected during the network scanning operation. The packet traces are used to extract features mentioned in Section IV-C and appropriate class labels ('normal' or 'scanning') are assigned to them. The extracted features vectors are further processed (handling of missing values, scaling) and randomly divided into training and *test* datasets using an 80:20 split. Using  $\chi^2$  test statistic, we select the best features (test statistic value above a preselected threshold) out of the existing ones. The final feature vectors thus obtained are used to train Support Vector Machine (SVM) and Random Forest (RForest) models. The trained ML models are then used to predict class labels for the test dataset and finally, the detection performance of the models is evaluated. We use a 10-fold cross validation approach to tune the hyper-parameters of the ML classifiers for achieving the

DATASET	METHOD	DR	MDR
IIoT Testbed Ubuntu host	Algorithm 2 [23]	1.0	0.0
IIoT Testbed Windows host	Algorithm 2 [23]	1.0	0.0

TABLE IV: C&C Stage Detection Performance

Fig. 3: IIoT Testbed Architecture [21]



DATASET	MODEL	PR	RC
HoT testbed Ubuntu host	Rforest	0.996	1.0
(Discovery-normal)	SVM	1.0	1.0
HoT testbed Ubuntu host	Rforest	0.991	1.0
(Discovery- slow)	SVM	0.978	0.974
IIoT testbed Windows host	Rforest	0.996	1.0
(Discovery-normal)	SVM	0.979	1.0
IIoT testbed Windows host	Rforest	1.0	1.0
(Discovery- slow)	SVM	0.912	0.978
UoT testbed	Rforest	1.0	0.992
(Fieldbus (Modbus) Scanning- agg.)	SVM	1.0	0.996
IIoT testbed	Rforest	0.996	1.0
(Fieldbus (Modbus) Scanning- non-agg)	SVM	0.996	0.983
IIoT testbed	Rforest	0.992	1.0
(Fieldbus (Profibus) Scanning)	SVM	0.988	0.996

TABLE V: Raptor's ML performance for detection of Discovery and Fieldbus scanning stages

highest possible CV scores. The cross validation is based on training data only without using any information from the test dataset.

Fieldbus scanning stage: To emulate this stage, we run nmap with modbus-discover script on the edge-gateway for enumerating Modbus slave IDs and collecting details about the slave devices. We run the modbus-discover script in both 'aggressive' and 'non-aggressive' modes, where the former mode refers to finding all slave IDs and the latter mode refers to finding just the first slave ID. Though Modbus is one of the common protocols used for communication with PLCs/RTUs, there are other protocols as well which are used in the industry, e.g., DNP3 (Distributed Network Protocol), Profibus/Profinet, CAN (Controller Area Network). Therefore, in a separate experiment, we connect a Seimens S7-1200 PLC to the edge gateway network and run nmap with s7-info script on the gateway for enumerating Seimens S7 PLC devices and collecting their device information. The steps for packet trace collection under normal and fieldbus scanning operations, feature vector extraction, processing and selection, ML model training and performance evaluation remain similar to the ones outlined for Discovery stage above.

The performance of ML classifiers is typically evaluated in terms of precision (PR) and recall (RC) scores. Precision is the ratio  $\frac{TP}{TP+FP}$ , where TP is the number of true positives and FP is the number of false positives. It represents the ability of a classifier to avoid labeling samples that are negative as positive. *Recall* is the ratio  $\frac{TP}{TP+FN}$ , where *TP* is the number of true positives and FN is the number of false negatives. It represents the ability of a classifier to avoid labeling samples that are positive as negative. Using the tuned hyper-parameters' values, the average classification precision (PR) and recall (RC) scores obtained for the final classifiers over 10 runs are shown in Table V. It can be observed that for the detection of Discovery stage on Ubuntu as well as Windows hosts using normal and slow scan speeds, Random Forest performs slightly better than SVM. In general, both the ML classifiers perform better with normal scanning speed compared to slow scanning speed which is expected since within the trace duration (1 min), more number of network scanning packets would be captured during normal versus slow speed scanning. For the detection of *Fieldbus scanning* stage using Modbus protocol in 'aggressive' and 'non-aggressive' modes, Random Forest performs almost equally as SVM in terms of precision but SVM performs quite poorly compared to Random Forest in terms of recall for 'non-aggressive' mode. For the detection of Fieldbus scanning stage using Profibus protocol, Random Forest performs slightly better than SVM in terms of both precision and recall. Based on the performance results obtained above, it would be preferable to select Random Forest classifier for detection of Discovery and Fieldbus scanning stages in RAPTOR's implementation since SVM's performance degrades significantly at slow network scanning speed and for 'non-aggressive' fieldbus scanning mode.

Finally, to emulate an APT attack on our testbed for construction of APT campaign graphs, we develop three attack storylines from an APT group's perspective, i.e., their background, motivation for attack, steps taken for attack and final attack objective. The TTPs (Techniques, Tactics and Procedures) used in our storylines are close to the ones used in real-world APT attacks on IIoT environments such as those mentioned in Section I. For reasons of space, we present RAPTOR's evaluation with only one of the APT attack storylines here. The rest of the storylines are presented in Appendix Sections A and B. Steps 1-2 (Initial Access), step 4 (Command-and-control), step 6 (Discovery) and step 10 (Credential Access, Lateral Movement) of the attack storyline are based on the 2014 German steel mill and 2015/2016 Ukraine power grid attacks. Step 16 (Fieldbus scanning, CE communication spoofing) of the attack storyline is based on the 2016 Ukraine power grid attack and the 2017 Saudi petrochemical plant attack. Steps 18-19 (Impact) of the attack storyline are based on the 2015 Ukraine power grid attack. We run the attack storyline on our IIoT testbed over the course of a few hours and collect the data generated from testbed hosts. Since real-world APT campaigns can stretch over months and it is not possible to emulate them on our testbed, we assume that our APT storylines are executed in an accelerated timeframe and therefore our performance evaluation of RAPTOR holds. The complete APT attack storyline used for evaluating RAPTOR is as follows.

### APT attack storyline 1

*Background*: Attackers belong to a nation-state (or APT) group which has been tasked with targeting a prominent stateowned steel manufacturing plant. The APT group plans to steal ICS related data which can be used to understand the ICS design and components which can further be used to plan for later attacks.

*Goals*: To steal sensitive OT data (e.g., blast furnace temperature sensor measurements, PLC configuration, credentials). OT data such as blast furnace temperature readings are sensitive because they can be used to learn the normal temperature range and temporal trends. Attackers can use this information to modify the settings of the furnace temperature controller to damage the furnace. The temperature readings can also be used to infer the furnace design.

Steps:

- The attacker sends a spear phishing email (including a malicious VPN portal web link) to one of the steel plant employees posing as legitimate company email and obtains their VPN login credentials.
- It uses the employee's company email address and phished credentials to remotely login to the maintenance machine connected to enterprise network (password reuse) through the VPN service.
- The attacker changes the employee's VPN account password for persistence.
- The compromised machine connects to an external C&C server through DNS tunnelling and forwards a shell to the attacker.
- Attacker installs a malware on the compromised machine which exploits software vulnerabilities to gain root access.
- 6) The attacker controlling the compromised machine scans its local network and finds other hosts (firewall, MQTT

server, external API machine) as well as the services running on them.

- Attacker tries to find CVE vulnerabilities corresponding to the services running on other hosts but can not exploit them successfully.
- It goes through the shell command history on compromised machine and finds previous SSH connection attempts to the edge gateway containing *username* and *hostname* details.
- It tries to determine the SSH login password for the edge gateway as follows:
  - a) Accesses the shadow password file on compromised machine (using root access obtained earlier) which stores password hashes and corresponding hashing algorithms used.
  - b) Tries to crack the password hashes to obtain corresponding plaintext passwords.
- The attacker attempts to log in to the edge gateway by using one plaintext password at a time and is successful. It explores the files, folders (hidden and non-hidden) and the processes running on edge gateway.
- 11) It finds a web server, a CoAP server and Node-red application running on edge gateway.
- 12) The attacker tries to exploit CoAP related vulnerabilities but is unsuccessful. It remotely executes a script from the compromised maintenance machine to dump the CoAP resources.
- It executes a fake CoAP client code on the compromised maintenance machine to receive measurements from sensors directly connected to edge gateway.
- It scans devices connected to the edge gateway's Wi-Fi hotspot network and finds a host running DNP service (PLC master).
- 15) Attacker downloads a script from C&C server and copies it remotely to edge gateway.
- 16) It extracts PLC configuration data (e.g., hardware, firmware, manufacturer, serial number, slave IDs) by running the script on edge gateway.
- 17) The attacker compresses and encrypts all the targeted data collected in previous steps (e.g., PLC configuration, sensor measurements, login credentials) and exfiltrates it through the C&C channel.

We assigned a weight,  $w_{ia} = 0.5$  to the primary data sources for detecting an attack stage and a weight of of  $w_{ia}/2$  to the secondary data sources. The threshold for detection is selected as  $\tau = 0.5$ . The APT campaign graph generated by **RAPTOR** for *Storyline 1* is shown in Fig. IV-F. The graph captures broad details of the APT campaign including the IP addresses of the machines affected and the tactics used during the campaign which is quite useful for cybersecurity analysts. This shows that our proposed attack stage detection and correlation algorithm in Section IV-E works as intended. However, the campaign graph does not capture all the tactics employed by the APT attackers since our focus is on detecting invariant APT tactics/stages only as explained in Section III-B. Further, the campaign graph does not contain any details on the specific techniques employed by the APT attackers since our focus is not on detecting the individual techniques used for each tactic. The APT campaign graph can serve as a starting point for cybersecurity analysts to fill in the missing tactics based on the APT attack frameworks for ICS, further investigation and mitigation. The APT campaign graphs for *Storyline 2* and *Storyline 3* are shown in Fig. 4 and Fig. 6 respectively in the Appendix.



Fig. 4: APT campaign graph generated for Storyline 1

## VI. DISCUSSION

#### A. Comparison with State-of-the-art

We are unable to conduct a performance comparison of RAPTOR with [12] as they do not provide any source code for their proposed multi-stage attack detection algorithm. Further, the dataset used for performance evaluation in [12] which consist of a synthetic APT campaign injected into the CSE-IDC-2018 intrusion detection dataset [25] has not been publicly released. HOLMES [10] and CONAN [11] do not provide source codes for their proposed APT detection system as well though both use the DARPA Transparent Computing ((TC) Engagement dataset [26] for performance evaluation which has been released publicly. The DARPA TC dataset contains data from a red team deploying APT-style TTPs on a target system consisting of multiple interconnected hosts running different OSes and having exploitable CVE vulnerabilities. However, the DARPA TC dataset suffers from following limitations which reduce its applicability for RAPTOR's performance evaluation:

- The TC network setup is simple and does not emulate real-world enterprise/IIoT networks.
- The dataset provides only *json* files but no raw *pcap* files for us to extract network traffic-based features for a meaningful comparison with RAPTOR's performance on our IIoT testbed dataset<sup>1</sup>.
- None of the TTPs used in TC dataset are IIoT-specific.

#### **B.** Limitations

The design of RAPTOR introduces a few limitations which are discussed in this section. RAPTOR uses supervised ML algorithms for detection of certain APT attack stages which means that it can detect only known malicious traffic patterns produced by those attack stages. However, it should be noted that supervised ML algorithms are used much more commonly compared to unsupervised algorithms in real-world deployments of HIDS/NIDS. Advanced APT malware may attempt to evade detection by RAPTOR by slowing down the scanning activity (e.g., during Discovery, Fieldbus scanning stages) or changing the time period between scanning attempts to confuse the trained ML algorithms. This evasion technique can be countered by increasing the packet trace duration to capture enough attack packets though it may lead to longer classification delays. The ML classifiers used for detection of certain APT attack stages may have to be re-trained, for example, when the classification probability falls below a predefined threshold or the host OS is updated, and this may cause a delay in detection.

Evasive APT malware may also use some other C&C server messaging mechanism than the TCP ([PSH,ACK], [ACK])/UDP one to escape filtering and/or force the C&C communication to be non-periodic (by adding noise traffic for example). If the attacker does change the C&C messaging mechanism, the detection method can be changed accordingly. Moreover, the C&C communication periodicity detection algorithm uses an ACF (Autocorrelation Function)-based approach which can detect periodicity in the presence of noise as well if the noise is uncorrelated with the desired signal (discretetime sequence extracted from C&C server traffic). An attacker may evade the lateral movement detection logic by exploiting an RCE vulnerability instead of performing manual logins or using stealthy malware which blends the logins in its attack path with a previous legitimate user login. Finally, it is also possible that a few hosts may already be infected before RAPTOR is deployed in an IIoT environment.

#### VII. CONCLUSION

We have proposed RAPTOR, an APT detection system targeted at IIoT environments. It detects and correlates attack stages derived from an APT Attack Invariant State Machine using optimal data sources selected for each stage. The correlated attack stages are utilized to generate a compact, high-level APT Campaign Graph which can be used by cybersecurity analysts to track the progress of the APT campaign and deploy appropriate mitigation measures. A performance evaluation of RAPTOR shows that it can detect APT campaigns modelled after real-world attacks with high precision and low false positive/negative rates.

#### REFERENCES

- R. Schafer, "Protecting IoT devices and OT Networks from Cyber Attacks," https://blog.checkpoint.com/2020/07/06/ protecting-iot-devices-and-ot-networks-from-cyber-attacks/, June 2020.
- N. Falliere, L. O. Murchu, and E. Chien, "W32.Stuxnet Dossier," https://www.wired.com/images\_blogs/threatlevel/2010/11/w32\_stuxnet\_ dossier.pdf, Nov 2010.
- [3] R. M. Lee, M. J. Assante, and T. Conway, "German Steel Mill Cyber Attack," https://assets.contentstack.io/v3/assets/blt36c2e63521272fdc/ bltc79a41dbf7d1441e/607f235775873e466bcc539c/ ICS-CPPE-case-Study-2-German-Steelworks\_Facility.pdf, Dec 2014.

<sup>&</sup>lt;sup>1</sup>There is an active unresolved issue with the DARPA TC dataset. While loading data from the compressed \*.bin.1.gz files, the code get stuck at streaming records.

- [4] —, "Analysis of the Cyber Attack on the Ukrainian Power Grid," https://media.kasperskycontenthub.com/wp-content/uploads/sites/58/ 2016/12/21181126/E-ISAC\_SANS\_Ukraine\_DUC\_5.pdf, Mar 2016.
- [5] A. Cherepanov, "WIN32/INDUSTROYER: A new threat for industrial control systems," https://www.welivesecurity.com/wp-content/uploads/ 2017/06/Win32\_Industroyer.pdf, Jun 2017.
- [6] B. Johnson, D. Caban, M. Krotofil, D. Scali, N. Brubaker, and C. Glyer, "Attackers Deploy New ICS Attack Framework "TRITON" and Cause Operational Disruption to Critical Infrastructure," https://www.mandiant.com/resources/blog/ attackers-deploy-new-ics-attack-framework-triton, Dec 2017.
- [7] R. Wright, "Industroyer2: How Ukraine avoided another blackout attack," https://www.techtarget.com/searchsecurity/news/252523694/ Industroyer2-How-Ukraine-avoided-another-blackout-attack, Aug 2022.
- [8] D. R. Staff, "Triton Malware Still Targeting Energy Firms," https://www.darkreading.com/attacks-breaches/ triton-malware-still-targeting-energy-firms, Mar 2022.
- [9] N. Brubaker, K. Lunden, K. P. M. Umair, D. K. Zafra, C. Hildebrandt, and R. Caldwell, "INCONTROLLER: New State-Sponsored Cyber Attack Tools Target Multiple Industrial Control Systems," https://www. mandiant.com/resources/blog/incontroller-state-sponsored-ics-tool, Apr 2022.
- [10] S. M. Milajerdi, R. Gjomemo, B. Eshete, R. Sekar, and V. Venkatakrishnan, "HOLMES: Real-Time APT Detection through Correlation of Suspicious Information Flows," in 2019 IEEE Symposium on Security and Privacy (SP), 2019, pp. 1137–1152.
- [11] C. Xiong, T. Zhu, W. Dong, L. Ruan, R. Yang, Y. Cheng, Y. Chen, S. Cheng, and X. Chen, "Conan: A Practical Real-Time APT Detection System With High Accuracy and Efficiency," *IEEE Transactions on Dependable and Secure Computing*, vol. 19, no. 1, pp. 551–565, 2022.
- [12] F. Wilkens, F. Ortmann, S. Haas, M. Vallentin, and M. Fischer, "Multi-Stage Attack Detection via Kill Chain State Machines," ser. CYSARM '21. New York, NY, USA: Association for Computing Machinery, 2021, p. 13–24. [Online]. Available: https://doi.org/10.1145/3474374.3486918
- [13] H. Irshad, G. Ciocarlie, A. Gehani, V. Yegneswaran, K. H. Lee, J. Patel, S. Jha, Y. Kwon, D. Xu, and X. Zhang, "TRACE: Enterprise-Wide Provenance Tracking for Real-Time APT Detection," *IEEE Transactions on Information Forensics and Security*, vol. 16, pp. 4363–4376, 2021.
- [14] G. Ho, M. Dhiman, D. Akhawe, V. Paxson, S. Savage, G. M. Voelker, and D. Wagner, "Hopper: Modeling and Detecting Lateral Movement," in *30th USENIX Security Symposium (USENIX Security 21)*. USENIX Association, Aug 2021, pp. 3093–3110. [Online]. Available: https://www.usenix.org/conference/usenixsecurity21/presentation/ho
- [15] T. H. Morris, Z. Thornton, and I. Turnipseed, "Industrial control system simulation and data logging for intrusion detection system research," *7th Annual Southeastern Cyber Security Summit*, pp. 3–4, 2015.
- [16] S. Pan, T. Morris, and U. Adhikari, "Developing a Hybrid Intrusion Detection System Using Data Mining for Power Systems," *IEEE Transactions on Smart Grid*, vol. 6, no. 6, pp. 3104–3113, 2015.
- [17] J. Goh, S. Adepu, K. N. Junejo, and A. Mathur, "A Dataset to Support Research in the Design of Secure Water Treatment Systems," in *Critical Information Infrastructures Security - 11th International Conference, CRITIS 2016, Paris, France, October 10-12, 2016, Revised Selected Papers*, ser. Lecture Notes in Computer Science, G. M. Havârneanu, R. Setola, H. Nassopoulos, and S. D. Wolthusen, Eds., vol. 10242. Springer, 2016, pp. 88–99. [Online]. Available: https://doi.org/10.1007/978-3-319-71368-7\_8
- [18] D. Myers, S. Suriadi, K. Radke, and E. Foo, "Anomaly detection for industrial control systems using process mining," *Computers & Security*, vol. 78, pp. 103–125, 2018. [Online]. Available: https://www.sciencedirect.com/science/article/pii/S0167404818306795
- [19] M. A. Teixeira, T. Salman, M. Zolanvari, R. Jain, N. Meskin, and M. Samaka, "SCADA System Testbed for Cybersecurity Research Using Machine Learning Approach," *Future Internet*, vol. 10, no. 8, 2018. [Online]. Available: https://www.mdpi.com/1999-5903/10/8/76
- [20] M. Al-Hawawreh, E. Sitnikova, and N. Aboutorab, "X-IIoTID: A Connectivity-Agnostic and Device-Agnostic Intrusion Data Set for Industrial Internet of Things," *IEEE Internet of Things Journal*, vol. 9, no. 5, pp. 3962–3977, 2022.
- [21] M. Al-Hawawreh and E. Sitnikova, "Developing a Security Testbed for Industrial Internet of Things," *IEEE Internet of Things Journal*, vol. 8, no. 7, pp. 5558–5573, 2021.
- [22] M. ATT&CK, "ICS tactics," https://attack.mitre.org/tactics/ics/.

- [23] A. Kumar, M. Shridhar, S. Swaminathan, and T. J. Lim, "Machine learning-based early detection of IoT botnets using network-edge traffic," *Computers & Security*, vol. 117, p. 102693, 2022. [Online]. Available:
- https://www.sciencedirect.com/science/article/pii/S0167404822000918 [24] Nmap.org, "NMAP Timing Templates,"
- https://nmap.org/book/performance-timing-templates.html.
  [25] I. Sharafaldin, A. H. Lashkari, and A. A. Ghorbani, "Toward Generating a New Intrusion Detection Dataset and Intrusion Traffic Characterization," in *Proceedings of the 4th International Conference* on Information Systems Security and Privacy, ICISSP 2018, Funchal, Madeira - Portugal, January 22-24, 2018, P. Mori, S. Furnell, and O. Camp, Eds. SciTePress, 2018, pp. 108–116. [Online]. Available: https://doi.org/10.5220/0006639801080116
- [26] J. Torrey, "Transparent Computing Engagement 5 Data Release," https://github.com/darpa-i2o/Transparent-Computing.

### APPENDIX A

# APT ATTACK STORYLINE 2

*Background*: Attackers belong to a nation-state (or APT) group which has been tasked with targeting a prominent stateowned steel manufacturing plant. The APT group plans to disrupt the steel production and thereby affect other industries dependent on steel and exports.

*Goals*: To shut the blast furnace down by controlling the furnace relays (LEDs in our testbed). This may damage the plant operations temporarily or permanently.

- Steps:
- An insider recruited by the APT group installs malware on the maintenance machine through a USB stick. The malware exploits software vulnerabilities on the machine to gain root access.
- The compromised machine connects to an external C&C server through DNS tunnelling and forwards a remote display to the attacker.
- Attacker installs a malware on the compromised machine which exploits software vulnerabilities to gain root access.
- 4) The attacker controlling the compromised machine scans its local network and finds other hosts (firewall, MQTT server, external API machine) as well as the services running on them.
- 5) Attacker tries to find CVE vulnerabilities corresponding to the services running on other hosts but can not exploit them successfully.
- 6) It accesses the shadow password file on compromised machine (using root access obtained earlier) which stores password hashes and corresponding hashing algorithms used.
- Attacker successfully opens an RDP (Remote Desktop Protocol) session to the external API machine using one of the stolen password hashes.
- It accesses the SCADA/HMI web interface on the external API machine and turns off the LEDs directly connected to edge gateway.

#### APPENDIX B

#### APT ATTACK STORYLINE 3

*Background*: Attackers belong to a nation-state (or APT) group which has been tasked with targeting a prominent stateowned steel manufacturing plant. The APT group plans to



Fig. 5: APT campaign graph generated for Storyline 2

disrupt the steel production and thereby affect other industries dependent on steel and exports.

*Goals*: To damage the plant equipment by tampering with the operation of safety controllers which prevent the blast furnace from entering an unsafe state. The safety controllers may be reprogrammed to allow the blast furnace to enter a dangerous state without any corrective action leading to physical damage to the plant and even loss of human lives.

Steps:

- 1) The attacker sends a spear phishing email (including a malicious VPN portal web link) to one of the steel plant employees posing as legitimate company email and obtains their VPN login credentials.
- It uses the employee's company email address and phished credentials to remotely login to the maintenance machine connected to enterprise network (password reuse) through the VPN service.
- 3) The attacker changes the employee's VPN account password for persistence.
- 4) The compromised machine connects to an external C&C server through DNS tunnelling and forwards a shell to the attacker.
- Attacker installs a malware on the compromised machine which exploits software vulnerabilities to gain root access.
- 6) The attacker controlling the compromised machine scans its local network and finds other hosts (firewall, MQTT server, external API machine) as well as the services running on them.
- Attacker tries to find CVE vulnerabilities corresponding to the services running on other hosts but can not exploit them successfully.
- 8) It goes through the shell command history on compromised machine and finds previous SSH connection attempts to the edge gateway containing *username* and *hostname* details.
- 9) It hijacks any future SSH session between the compromised machine (started by an employee performing remote maintenance) and the edge gateway.
- 10) The attacker explores the files, folders (hidden and nonhidden) and the processes running on edge gateway.
- 11) It finds a web server, a CoAP server and Node-red application running on edge gateway.
- 12) The attacker scans devices connected to the edge gateway's Wi-Fi hotspot network and finds a host running DNP service (PLC device).

- 13) It downloads a payload from C&C server, copies it remotely to edge gateway and executes it.
- 14) The attacker terminates the existing process which is communicating with the PLC device.
- 15) It collects more information about the PLC device and enumerates all the slave IDs using the payload commands.
- 16) The attacker uses the payload to send a command to the targeted slave to read its current state.
- 17) It remotely uploads a new program to the PLC device while it continues to operate.



Fig. 6: APT campaign graph generated for Storyline 3